

5

10

DESCRIPTION

METHOD FOR OPERATING A COMBINED CYCLE POWER PLANT

15

TECHNICAL FIELD

The present invention relates to the field of power plant technology. It refers to a method for operating a combined cycle power plant according to the preamble of claim 1.

20

BACKGROUND OF THE INVENTION

25

In the event of a total breakdown of the electrical transmission system (AC network), selected power-generating units have the capability for restoring the network. On account of the very limited size of the network, it is very difficult, however, to maintain the balance between power generation and power consumption. As a consequence thereof, frequency changes occur, which are considerable compared with the normal conditions for the network operation.

30

Independently of the type of plant which is provided and set up for carrying out such a black start, the capability for accepting the immediate satisfaction of demand blocks, which lie typically within the range of 30 - 50 MW, is required. The power-generating unit must be in the position to control the frequency and voltage level within acceptable limits when satisfying such blocks.

Large power plants are particularly suitable for the restoration of networks. An example of such a suitable power plant is a combined cycle power plant, as is shown schematically and greatly simplified in Fig. 1. The combined cycle power plant 10 of Fig. 1 comprises a gas turbine 11 and a water-steam cycle 12 which are interlinked via a heat restoration steam generator 13. The gas turbine 11 draws in air 19 by a compressor 15, compresses this, and discharges it to a combustion chamber 16, to which a fuel 20 is fed. The fuel 20 is combusted with the aid of the compressed air and produces a hot gas which is expanded in a subsequent turbine 17, performing work. In the process, the turbine 17 drives the compressor 15 on one side and, on the other side, drives a generator 18 which generates alternating current or alternating voltage. The flue gas 21 which issues from the turbine 17 is directed through the heat restoration steam generator 13 and discharges it to the environment via a flue gas stack 22.

Arranged in the heat restoration steam generator 13 is an evaporator 27 of the water-steam cycle 12 in which the water delivered by a feedwater pump 26 is evaporated. The steam which is produced is expanded in a steam turbine 23, performing work, and drives an additional generator 24 for current or voltage generation. The steam which issues from the steam turbine 23 is condensed in a condenser 25 and, completing the cycle, is fed to the feedwater pump 26.

The current (alternating current) which is generated by the generators 18 and 24 is fed into an AC network 28 which is connected to the combined cycle power plant 10. A control unit 14 ensures that the requirements of the AC network 28 are fulfilled as far as possible in the process with regard to frequency and level of output.

A method for the primary control of a combined cycle power plant operating on the network is generally known from printed publication US 2009/0320493 A1, in which by the corresponding operation of a valve which acts upon the steam turbine a reserve power of the steam turbine is constantly held in readiness in order to boost the network frequency in the event of a frequency drop in the network. The case of a black start is not taken into consideration in this case.

In the case of gas-turbine modules of a combined cycle power plant, the transient operation of the gas turbine can lead to significant changes in the exhaust temperature. This generally necessitates the arrangement of a bypass stack. This can be an important point when judging whether a gas-turbine module of a combined cycle power plant is suitable for a black start or not.

Modern high-performance gas turbines are particularly well-suited for network restoration. The flexibility during the operation of these machines within the range of low outputs, however, is restricted in general by process limitations. In the general case, an individual unit cannot therefore fulfill the aforesaid requirements for the entire operating range.

SUMMARY OF THE INVENTION

It is therefore the object of the invention to disclose a method for operating a combined cycle power plant with which network restoration can be achieved in a simple and reliable manner.

The object is achieved by means of the sum total of the features of claim 1.

The invention relates to a method for operating a combined cycle power plant, which comprises a gas turbine and a steam turbine which, via a connected electric generator in each case, generate alternating voltage of an assigned frequency and

deliver it to an AC network, wherein the flue gas of the gas turbine is used for producing steam for the steam turbine.

5 The method is characterized in that for network restoration during a black start, in a first step, in island mode, internal consumers are supplied by the gas turbine, wherein the operating point of the gas turbine is selected so that a minimum steam temperature is achieved for the steam turbine, in a second step, in island mode, the steam turbine is synchronized and ramped up to an operating point at which a maximum power increase can be achieved, wherein the resulting load change of
10 the steam turbine is compensated by the gas turbine, in a third step consumer loads are connected block by block, in a fourth step the increase in the demanded load is provided totally or partially and permanently or temporarily by the steam turbine, in a fifth step the load of the steam turbine is gradually reduced for increasing its load-increasing capacity, and steps three to five are repeated until
15 the base load of the combined cycle power plant is achieved.

One embodiment of the method according to the invention is distinguished by the fact that in the first step provision is made for the minimum steam temperature which is determined or controlled on account of the rotor temperature of the steam
20 turbine and by an optimum operating point of the gas turbine which allows a corresponding exhaust temperature of the gas-turbine flue gases.

When stationary, the rotor of the steam turbine cools down more slowly than the steam turbine casing. If the steam turbine is ramped up again after being stationary and after the corresponding cooling down, it is necessary for the steam
25 temperature to be at a sufficiently high level during the restarting so that thermally induced damage cannot occur. A correspondingly adjusted steam temperature, especially a correspondingly minimum temperature, can avoid excessive cooling down of the casing and in the process prevent the blades from coming into contact with the stator and the blade tips being damaged. A minimum steam temperature
30 for it can consequently be provided by the gas turbine being run at an operating point so that the flue gases when discharging from the gas turbine, and therefore entering the waste heat boiler, are sufficiently high so as to allow such a minimum

steam temperature. In order to bring about such a steam temperature, one of a large number of optimum operating points for the gas turbine can be selected. Depending upon the type of gas turbine, an operating point can be established inter alia by means of parameters such as fuel quantity, air feed temperature or guide wheel adjustments.

Another embodiment is characterized in that in the second step the total output power is used for the station service of the combined cycle power plant and, depending upon the optimum operating point of the gas turbine, the steam turbine alone, or the steam turbine and the gas turbine together, or the gas turbine alone, provides the power for the internal consumers.

Another embodiment is characterized in that the surplus power in island mode which cannot be used by the internal consumers can be used for operating the gas-turbine compressor (15).

Another embodiment is characterized in that in island mode of the power plant (10) the current generated by generators (18, 24) corresponds to a connected alternating current network zero.

A further embodiment is distinguished by the fact that in the fourth step the demanded load is provided totally by the steam turbine, or the gap between a demanded load and the total reaction of the gas turbine is covered by the steam turbine. Gas turbines do not react with equal speed in comparison to steam turbines, depending on the operating point, during the load increase. A steam turbine can react with sufficient speed in any case in order to realize a sharp load increase. Therefore, the operation of the steam turbine alone can realize the total load increase.

A gas turbine can also react quickly, wherein the degree of speed of the gas turbine in certain load ranges, mostly in low load ranges, is limited on account of the operating stability. It must also be operated, however, so as to observe, for example, emissions limit values, which in lower load ranges limits the operating

range of the gas turbine. If a sharper and quicker load increase is demanded and only the gas turbine is operated, an gap between demanded load increase and load increase realized by means of the gas turbine can be formed. This gap can be covered in this case by means of the additional operation of the steam turbine.

5 Yet another embodiment of the invention is characterized in that as a result of a permanent provision of the demanded load by the steam turbine the load ranges of the gas turbine operation which are restricted by process or emissions limits are avoided.

10 According to another embodiment, the steam turbine is operated so that both the possibility of load increasing and of load decreasing of the steam turbine is provided.

A further embodiment is characterized in that a minimum load of the steam turbine
15 is maintained in such a way that in the case of single-shaft configurations opening of the coupling, or in the case of multishaft configurations opening of the generator circuit-breaker, is avoided.

20 BRIEF EXPLANATION OF THE FIGURES

The invention shall subsequently be explained in more detail based on exemplary embodiments in conjunction with the drawing. In the drawing

25 Fig. 1 shows the principle construction of a combined cycle power plant, as is suitable for implementing the method according to the invention;

Fig. 2 shows different time curves during the synchronization of the
30 steam turbine of a combined cycle power plant during a black start according to an exemplary embodiment of the method according to the invention;

Fig. 3 shows different time curves when a load block is being connected to a combined cycle power plant according to an exemplary embodiment of the method according to the invention;

5

Fig. 4 shows different time curves during the stabilization of a combined cycle power plant after the connection of a load block according to an exemplary embodiment of the method according to the invention; and

10

Fig. 5 shows the further connection of a load block and the time curves associated therewith.

15 WAYS FOR IMPLEMENTING THE INVENTION

The method according to the invention is based on a tuned controlling of gas turbine and steam turbine over the entire operating range of the plant (from station service up to base load). The method is suitable in this case both for single-shaft plants and for multishaft plants and is distinguished by the following advantages:

20

I. Larger demand blocks can be connected. The contribution of the steam turbine compensates in this case for possible limitations for the gas turbine operation in the load range in the event of

a) process engineering limitations, and

25

b) flue gas-induced limitations.

II. On account of the superior dynamic characteristics of the steam turbine, improved control stability is created.

III. A capacity of the network restoration which extends up to the base load of the combined cycle power plant is created.

30

IV. A bypass stack is not necessary because excessive fluctuations in the gas temperature can be avoided.

The types of operation of the combined cycle power plant within the scope of the invention shall subsequently be explained in more detail with reference to Figs. 2 - 5. Fig. 2 relates in this case to the synchronization of the steam turbine, wherein in the figure - as well as in the other figures - power outputs (in megawatts) over time (in seconds) are plotted on the left-hand scale, and the frequency (in Hz) over time (in seconds) is plotted on the right-hand scale. The curve (a) (in all the Figures 2 - 5) represents the time characteristic of the thermal power of the combined cycle power plant (CC PWR THERM), the curve (b) represents the corresponding power consumption (LOAD CONSUMPTION), the curve (c) represents the corresponding thermal power of the gas turbine (GT PWR THERM), the curve (d) represents the corresponding thermal power of the steam turbine (ST PWR THERM), the curve (e) represents the corresponding frequency of the gas turbine (FREQ GT) and the curve (f) represents the corresponding frequency of the steam turbine (FREQ ST).

The starting point of the operation according to Fig. 2 is the island mode of the gas turbine, by means of which only the internal consumers are supplied (constant station service according to curve (b)). The steam which is produced is discharged by means of ST bypass stations (29) directly into the condenser. The operating point of the gas turbine is selected so that a minimum steam temperature for the operation of the steam turbine is achieved. The necessary steam temperature is primarily determined by the rotor temperature of the steam turbine.

The steam turbine is synchronized ("synchronization of ST" in Fig. 2) and is ramped up in power according to curve (d) to an ideal operating point for the connection of a first block of consumer loads (this is generally the point with the maximum steam-turbine load increase capacity). The total active output power of the plant (curve (b)) remains at the level of the station service (the net power delivery to the network is zero - that is to say zero-power operation). The steam turbine then supplies the internal consumers with power and, if necessary, supplies the compressor of the gas turbine with power, whereas the power of the

gas turbine is ramped down ("negative GT power output" of the curve (c); the constant curve (b) represents the internal consumption, the total thermal power (a) is the sum of the thermal gas-turbine power (c) and the thermal steam-turbine power (d)).

5

Fig. 3 relates to the connection of load blocks. After the connection of a block of consumer loads (step-like increase ("consumer load step") in curve (b)), the gas turbine and the steam turbine react at the same time to the frequency change associated therewith (at the start, this is a "frequency fall"; curve (f)). The coordination of both turbines is subject to the following characteristics:

10

- I. The general procedure is with some adjustments in the same way as has been described in printed publication US 2009/0320493 A1. The deviation between load setpoint value and the response of the gas turbine which is estimated and approximated by model computations is compensated by the contribution of the steam turbine. Depending upon the operating point of the plant, the steam turbine provides the increment in the load demand - totally or partially - on a temporally limited or permanent basis. The temporally limited contribution bridges the gap between the connection of a load block and the total reaction of the gas turbine. The permanent contribution serves for avoiding load ranges with restricted gas turbine operation (process-induced or emissions-induced limitations).
- II. The contribution of the steam turbine first and foremost improves the dynamic response of the power-generating unit. This is particularly important for load ranges with limited reaction dynamics of the gas turbine (typically during operation with low load). Therefore, the gas turbine is to be operated so that capacity of the steam turbine for a load increase as well as for a load reduction is available.
- III. A minimum steam turbine load is always to be maintained in order to avoid opening of the coupling (in the case of single-shaft configurations), or opening of the generator circuit-breaker (in the case of multishaft configurations).

15

20

25

30

Fig. 4 relates to stabilization after connection of the load blocks. After frequency stabilization, the plant is prepared for the connection of the next block of consumer loads (according to Fig. 5). Except for ranges of a limited operation, the gas turbine maintains the required power. The steam turbine load is gradually reduced (curve (d)) and consequently its capacity for a load increase is increased. The subsequent limits are created for the reduction of the steam turbine load:

- I. A minimum capacity for load reductions must be made available in order to maintain the system stability (operating ranges with limited reaction capability of the gas turbine).
- II. A minimum steam turbine load ("min. ST load" in curve (d)) must be maintained in order to avoid opening of the coupling (in the case of single-shaft configurations), or opening of the generator circuit-breaker (in the case of multishaft configurations).
- III. It may be possible that the steam turbine has to cover a portion of the demanded consumer load for an extended period of time in order to avoid load ranges which are critical for the continuous running operation of the gas turbine. A controlled bypass operation is necessary for this case.
- IV. The steam turbine is ramped up as soon as the predetermined capacity for the transient load increase is reached ("max. ST load increase capacity reached" in curve (d); Fig. 4)).

With the connection of a further load block according to Fig. 5, the steam turbine reacts immediately (curve (d)). The gas turbine follows with some delay (curve (c)), wherein the steam turbine is throttled back again as gas turbine power increases.

The connection of load blocks and the subsequent stabilization according to Figs. 3 - 5 are repeated consecutively until the base load of the combined cycle power plant is achieved.

LIST OF DESIGNATIONS

	10	Combined cycle power plant
	11	Gas turbine
	12	Water-steam cycle
	13	Waste heat steam generator
5	14	Control unit
	15	Compressor
	16	Combustion chamber
	17	Turbine
	18, 24	Generator
10	19	Air
	20	Fuel
	21	Flue gas
	22	Flue gas stack
	23	Steam turbine
15	25	Condenser
	26	Feedwater pump
	27	Evaporator
	28	(AC) network
	29	Steam-turbine (ST) bypass station
20		

PATENT CLAIMS

1. A method for operating a combined cycle power plant (10), which comprises a gas turbine (11) and a steam turbine (23) which, via a connected
5 electric generator (18, 24) in each case, generate alternating voltage of an assigned frequency and deliver it to an AC network (28), wherein the flue gas (21) of the gas turbine (11) is used for producing steam for the steam turbine (23), characterized in that for network restoration, during a black start, in a first step, in island mode, internal consumers are supplied by the gas turbine (11), wherein the
10 operating point of the gas turbine (11) is selected so that a minimum steam temperature is achieved for the steam turbine (23), in a second step, in island mode, the steam turbine (23) is synchronized and ramped up to an operating point at which a maximum power increase can be achieved, wherein the resulting load change of the steam turbine (23) is compensated by the gas turbine (11) and the
15 network-side power consumption corresponds to zero MW, in a third step consumer loads are connected block by block, in a fourth step the increase in the demanded load is provided totally or partially and permanently or temporarily by the steam turbine (23), in a fifth step the load of the steam turbine (23) is gradually reduced for increasing its load-increasing capacity, and steps three to five are
20 repeated until the base load of the combined cycle power plant (10) is achieved.

2. The method as claimed in claim 1, characterized in that in the first step provision is made for the minimum steam temperature which is determined or regulated on account of the rotor temperature of the steam turbine (23) and by the
25 optimum operating point of the gas turbine (17).

3. The method as claimed in claim 1 or 2, characterized in that in the second step the total output power is used for the station service of the combined cycle power plant (10), and that depending upon the optimum operating point of
30 the gas turbine (11), the steam turbine (23) alone, or the steam turbine (23) and the gas turbine (11) together, or the gas turbine (11) alone, provides the power for the internal consumers.

4. The method as claimed in one of claims 1 - 3, characterized in that in the second step the surplus power in island mode which cannot be used by the internal consumer can be used for operating the gas-turbine compressor (15).

5

5. The method as claimed in one of claims 1 - 4, characterized in that in the first and second step in island mode of the power plant (10) the current generated by generators (18, 24) corresponds to a connected alternating current network (28) zero.

10

6. The method as claimed in one of claims 1 - 5, characterized in that in the fourth step the demanded load is provided by a coordinated and simultaneous reaction of gas turbine (11), steam turbine (23) and ST bypass stations (29), wherein the network frequency is selectively controlled by the gas turbine (11) or the steam turbine (23).

15

7. The method as claimed in one of claims 1 - 6, characterized in that in the fourth step the demanded load is provided totally by the steam turbine (23), or the gap between a demanded load and the total reaction of the gas turbine (11) is covered by the steam turbine.

20

8. The method as claimed in one of claims 1 - 7, characterized in that as a result of a permanent provision of the demanded load by the steam turbine (23) the load ranges of the gas turbine operation which is restricted by process or emissions limitations are avoided.

25

9. The method as claimed in one of claims 1 - 8, characterized in that the steam turbine (23) is operated so that both the possibility of a load increase and of a load decrease of the steam turbine (23) is provided.

30

10. The method as claimed in one of claims 1 - 9, characterized in that a minimum load of the steam turbine is maintained in such a way that in the case of

single-shaft configurations opening of the coupling, or in the case of multishaft configurations opening of the generator circuit-breaker, is avoided.