

D E S C R I P T I O N

Title of Invention: ENERGY MANAGEMENT SERVER, ENERGY
MANAGEMENT METHOD, AND PROGRAM

Technical Field

5 Embodiments described herein relate generally to an
energy management server, energy management method, and
program applicable to energy management in relatively
large-scale structures such as buildings and factories.

Background Art

10 Buildings and factories consume large amounts of
energy. The energy consumption amount of the commercial
sector is particularly large and probably reaches 20% of
the whole. Therefore, effective energy-saving measures are
required in buildings. Also, the recent increasing
15 severity in power demand and supply has caused upper limits
to be placed on the power consumption of large users
(customers). Accordingly, energy-saving techniques such as
peak cutting and peak shifting to reduce energy consumption
are attracting attention.

20 Energy-related apparatuses include various apparatuses
such as an energy-consuming apparatus, energy-creating
apparatus, and energy-storing apparatus. To effectively
use energy, it is important to make these energy-related
apparatuses cooperate with each other. For example, it is
25 important to create an all-inclusive operation schedule to
operate the energy-related apparatuses.

 There is a proposal for determining an operation

schedule capable of minimizing the energy consumption amount, cost, and CO₂ generation amount in a predetermined period of an energy supply facility including a heat storage tank. Another proposal for increasing the overall energy efficiency of a building involves making an apparatus using renewable energy (e.g., a PV (PhotoVoltaic) system or solar water heater) cooperate with a storage battery, a heat storage device, or an existing electric apparatus.

10 Citation List

Patent Literatures

Patent Literature 1: Japanese Patent No. 4396557

Patent Literature 2: Jpn. Pat. Appln. KOKAI

Publication No. 2005-157685

15 Patent Literature 3: Jpn. Pat. Appln. KOKAI

Publication No. 2013-174412

Summary of Invention

Technical Problem

A technique called demand response, by which an energy supplier requests a customer to suppress energy consumption, is also known. When a building or factory receives a DR (Demand Response) signal, an energy-saving target value, power-saving target value, or the like is changed, and an operation schedule is also changed accordingly. A measure for when a structure such as a building or factory has received the DR (Demand Response) signal is presently being examined. Related techniques

have been applied as patents.

To timely execute an accurate operation schedule, it is desirable to reexamine an estimated demand immediately after the DR signal is received, and re-plan the operation
5 schedule as needed. However, no technique for practically implementing the processing as described above is known.

It is an object of the present invention to provide an energy management server, energy management method, and program capable of creating an accurate operation schedule
10 in accordance with the demand response signal.

Solution to Problem

According to an embodiment, an energy management server includes an estimation unit, scheduler, acquisition unit, monitoring unit, receiving unit, and setting unit.
15 The estimation unit calculates an estimated value of an energy demand in a building in which an electric appliance is installed. The scheduler creates an operation schedule of the electric appliance based on the estimated value. The acquisition unit acquires an actual value of the energy
20 demand. The monitoring unit monitors an error between the estimated value and actual value. The receiving unit receives a demand response signal containing information which prompts the suppression of energy consumption in a designated period. The setting unit sets a threshold
25 related to the demand response signal. The estimation unit recalculates the estimated value if the error is equal to or larger than a defined threshold. The scheduler reforms

the operation schedule based on the recalculated estimated value.

Brief Description of Drawings

5 [FIG. 1] FIG. 1 is a system view showing an example of an energy management system according to an embodiment.

[FIG. 2] FIG. 2 is a view showing an example of the flow of energy in a building 1.

[FIG. 3] FIG. 3 is a functional block diagram showing an example of an energy management server 4.

10 [FIG. 4] FIG. 4 is a view for explaining the relationship between functional blocks shown in FIG. 3.

[FIG. 5] FIG. 5 is a flowchart showing an example of a procedure in the energy management server 4.

15 [FIG. 6] FIG. 6 is a view showing an example of the relationship between processes in a monitoring unit 102.

[FIG. 7] FIG. 7 is a view showing another example of the relationship between the processes in the monitoring unit 102.

20 [FIG. 8] FIG. 8 is a view showing an example of a window displayed in a GUI 111 and used to set an estimated error determination threshold.

[FIG. 9] FIG. 9 is a view showing an example of the relationship between a re-planning threshold and estimated error with respect to a power demand.

25 [FIG. 10] FIG. 10 is a view showing an example of the relationship between a re-planning threshold and estimated error with respect to a received power amount.

[FIG. 11] FIG. 11 is a view showing an example of the relationship between processes in an estimation unit 106.

[FIG. 12] FIG. 12 is a view for explaining the effect of a re-estimation process.

5 [FIG. 13] FIG. 13 is a view showing an example of a window displayed on a display 42.

Description of Embodiments

FIG. 1 is a system view showing an example of an energy management system according to an embodiment. A building 1 shown in FIG. 1 includes a LAN (Local Area Network) 8, and monitoring apparatuses 5, local controllers 3, and an energy management server 4 connected to the LAN 8. As an upper-layer protocol of the LAN 8, it is possible to use, e.g., BACnet[®].

15 A plurality of nodes 2 are connected to the local controllers 3 via their respective communication lines. Each local controller 3 monitors the states of the nodes 2 connected to it, and performs various kinds of control over the nodes 2 connected to it. Each node 2 can be an energy-consuming apparatus, energy-creating apparatus, or energy-storing apparatus. For example, the node 2 is an air-conditioning apparatus, illumination apparatus, motive power apparatus, heat source apparatus, heat storage apparatus, chiller, PV system, storage battery, or the like. In the following description, these apparatuses will collectively be called electric appliances. Each monitoring apparatus 5 is an HMI (Human-Machine Interface)

20

25

which acts as an information transmission interface between the user (e.g., the building manager) and the system.

The energy management server 4 can be connected to a cloud computing system (to be referred to as a cloud hereinafter) 9. The energy management server 4 receives a DR (Demand Response) signal from a DR issuing server 6 of the cloud 9, and acquires weather data (e.g., weather forecast and the temperature in each period) from a weather server 7 of the cloud 9. The cloud 9 is an arithmetic processing system in which a plurality of servers and a plurality of databases are connected to an IP (Internet Protocol) network or dedicated network. The cloud 9 is implemented in the form of, e.g., a data center.

The main function of the energy management server 4 is a function of managing the energy of the building 1. In the embodiment, an electric appliance operation schedule creating function of the energy management server 4 will mainly be explained. Examples of the operation schedule are an activation/stop schedule of the nodes 2 based on a request (e.g., a peak-shift target) from the user, and an electricity storage/heat storage schedule based on electricity storage level settings.

FIG. 2 is a view showing an example of the flow of energy in the building 1. In the following description, a storage battery 20, PV system 21, air-cooling HP (Heat Pump) 22, water-cooling chiller 23, absorption chiller heater 25, heat storage tank 26, solar water heater 27, and

CGS (Co-Generation System) 28 will be enumerated as examples of the nodes 2. The energy exchange relationship between these appliances will be explained below with reference to FIG. 2.

5 Electric power and a gas are supplied to the building 1, and electricity and cold heat using the electric power and gas as energy sources are supplied to various places in the building 1. The received power is supplied to the storage battery 20 and stored in it, or supplied to an
10 energy-consuming apparatus and consumed in it. Similarly, electric power generated by the PV system 21 and CGS 28 is stored in the storage battery 20 or supplied to an energy-consuming apparatus. For example, electric power supplied to the air-cooling HP 22 or water-cooling chiller 23 is
15 consumed to manufacture cold heat.

 The gas supplied to the building 1 is supplied to the CGS 28. The CGS 28 generates electric power and hot heat. The generated electric power is supplied to a power line. The generated hot heat is supplied to a hot-water line.

20 The absorption chiller heater 25 receives the hot heat generated by the CGS 28 and solar water heater 27, and manufactures cold heat. The cold heat manufactured by the air-cooling HP 22, water-cooling chiller 23, and absorption chiller heater 25 is consumed by a heat demand or stored in
25 the heat storage tank 26.

 FIG. 3 is a functional block diagram showing an example of the energy management server 4. The energy

management server 4 includes an input unit 41, display 42,
interface unit 43, database unit 202, CPU (Central
Processing Unit) 44, and program memory 45. That is, the
energy management server 4 is a computer which functions
5 when the CPU 44 executes programs stored in the program
memory 45.

The input unit 41 is a human-machine interface such as
an operation panel and switches. The input unit 41 and
display 42 form a GUI (Graphical User Interface)
10 environment, receive information input from the user, and
provide information to the user. The interface unit 43 is
connected to the LAN 8 and cloud 9, and communicates with
the monitoring apparatuses 5, local controllers 3, nodes 2,
and remote servers (e.g., the DR issuing server 6 and
15 weather server 7).

The database unit 202 stores databases 202a and 202b
as data according to the embodiment, in addition to various
kinds of data concerning energy management.

The program memory 45 stores, as programs containing
20 instructions necessary for processing functions according
to this embodiment, a DR accepting program 101p, monitoring
program 102p, DR formulation program 103p, acquisition
program 104p, scheduling program 105p, estimation program
106p, weather data receiving program 107p, transmission
25 program 108p, approval program 109p, and determination
program 110p. These programs can be recorded on a
removable medium (recording medium) such as a CD-ROM, and

can also be downloaded via a communication line (including the cloud 9).

The CPU 44 reads out each program from the program memory 45, and performs arithmetic processing by hardware.

5 As its processing functions, the CPU 44 includes a DR accepting unit 101, monitoring unit 102, DR formulation unit 103, acquisition unit 104, scheduling unit 105, estimation unit 106, weather data receiving unit 107, transmission unit 108, approval unit 109, and determination
10 unit 110.

FIG. 4 is a view for explaining the relationship between the functional blocks shown in FIG. 3. The acquisition unit 104 collects the values of, e.g., the received power amount, power demand, and heat demand of the
15 node 2 as a control target apparatus in, e.g., a predetermined period (fixed period). These values are real values (actual values) collectively called process values, and input from the acquisition unit 104 to the monitoring unit 102.

20 The monitoring unit 102 monitors the process values transferred from the acquisition unit 104, and, based on the values, forms a trigger for demand estimation and scheduling in, e.g., a fixed period. The formed trigger is given to the estimation unit 106 and scheduling unit 105.

25 The estimation unit 106 estimates the power demand and heat demand in the building 1 for, e.g., every 30 min. These values as estimation targets will collectively be

called energy demands in the following description. The estimation process by the estimation unit 106 is performed as a periodic routine, and is also performed when a trigger is given from the monitoring unit 102.

5 When performing the estimation process, the estimation unit 106 uses weather data (e.g., weather forecast) received by the weather data receiving unit 107. The weather data receiving unit 107 regularly or irregularly acquires weather data from the weather server 7 of a
10 weather forecast company.

 The scheduling unit 105 creates an operation schedule of the node 2, which can optimize the energy balance in the building 1, based on the estimated values of the power demand and heat demand. The created operation schedule is
15 stored in the database 202a. The operation schedule can contain, e.g., the operation settings, operation time, and operation period of each node 2. As the viewpoints of optimization, viewpoints such as energy saving, cost saving, and exhaust CO₂ reduction are possible. In
20 addition, various other viewpoints of optimization are possible.

 The DR accepting unit 101 receives a DR signal transmitted from the DR issuing server 6. The DR signal contains information such as the type of the DR signal, a
25 period for requesting the suppression of power consumption, incentive, and the baseline of the power consumption amount. The determination unit 110 determines whether to

respond to the DR signal at the present point in time,
based on the output from the DR accepting unit 101 and the
present time. For example, if it is determined to respond
to the DR signal immediately after the signal is received,
5 the determination unit 110 outputs a DR trigger. This DR
trigger is given to the estimation unit 106 and scheduling
unit 105, and triggers off the creation of an operation
schedule based on the received DR signal.

The DR formulation unit 103 formulates the information
10 contained in the received DR signal into a numerical
expression usable in arithmetic processing. For example, a
PTR (Peak Time Rebate) type DR signal involves a rule by
which an incentive corresponding to a reduction amount from
the baseline of the received power amount in a designated
15 period is paid to the user. Information contained in a DR
signal of this kind can be formulated by the hourly power
rate, hourly incentive, and hourly baseline.

Based on the formulated information, the scheduling
unit 105 creates an operation schedule of each node 2 (an
20 electric appliance) in a predetermined period (e.g., one
day (24 hours)). The created operation schedule is stored
in the database 202b of the database unit 202. That is,
the operation schedule created by receiving the DR signal
is stored in the database 202b and processed separately
25 from an operation schedule (stored in the database 202a)
created without taking the DR signal into account.

For example, an operation schedule aiming at cost

saving can be created by minimizing an objective function C indicated by:

$$C = \sum_{i=1 \sim 24} \{k_i \times Li - m_i \times (Li - Bi) + n_i \times Pi\}$$

5 ... (1)

C :cost in operation period

k_i :power rate at time i

Li :received power amount at time i

m_i :incentive at time i

10 Bi :baseline at time i

n_i :gas rate at time i

Pi :gas consumption amount at time i

i :elapsed time from zero hours (unit: hour)

15 According to equation (1), it is possible to reduce the total cost including the gas rate in addition to the power rate.

The approval unit 109 displays a plurality of operation schedules on a GUI 111, and urges the user to approve one of the operation schedules. The approved operation schedule is read out from the database 202a or 202b, and transferred to the transmission unit 108. The transmission unit 108 generates a control signal (appliance command value) based on the operation schedule transferred from the approval unit 109. The control signal is supplied from the interface unit 43 (FIG. 3) to the node 2 via the LAN 8 and local controller 3. This implements electric appliance operation control based on the operation

20

25

schedule.

FIG. 5 is a flowchart showing an example of a procedure in the energy management server having the above-mentioned arrangement. The acquisition unit 104 monitors the arrival of a DR signal (step S1), and collects the process values such as the received power amount, power demand amount, and the heat demand amount of each node 2 (step S2). The monitoring unit 102 monitors the error (difference) between the process value and estimated value, and forms a trigger (to be referred to as a monitoring trigger hereinafter) if the error is equal to or larger than a defined threshold (step S3). If no monitoring trigger is formed (No in step S4), the procedure returns to step S1.

If the arrival of a DR signal is detected in step S1 (Yes), the DR accepting unit 101 executes a DR accepting process (step S10), and the determination unit 110 determines whether to respond to the accepted DR signal (step S11). If it is determined to respond to this DR signal, the determination unit 110 outputs a trigger (the DR trigger shown in FIG. 4) for creating an operation schedule corresponding to the DR signal.

If the monitoring trigger or DR trigger is generated, the estimation unit 106 executes a power demand/heat demand estimation process (step S5). The estimated demands are transferred to the scheduling unit 105, and an operation schedule for a predetermined period is created (step S6).

The operation schedule is transferred to the approval unit 109. If this operation schedule is approved (step S7), the operation schedule is transferred to the transmission unit 108.

5 The transmission unit 108 generates an appliance command value based on the operation schedule, and transmits the generated appliance command value to the control target (step S8). The above procedure is repeated until termination is determined (Yes in step S9). In this
10 flowchart shown in FIG. 5, an operation schedule corresponding to a DR signal can be executed immediately after the signal is received.

FIGS. 6 and 7 show examples of the relationship between the processes in the monitoring unit 102. FIG. 6
15 corresponds to a case in which no DR signal exists. Referring to FIG. 6, a threshold extraction process 1021 acquires, from the database unit 202, the value at the present time of a threshold (for normal time) to be compared with the error between the process value and
20 estimated value. That is, the threshold is a value which changes with time, and is set by, e.g., the user. Details of the threshold will be explained later with reference to FIG. 8.

An error calculation process 1022 calculates the error
25 (demand error) between the actual value and estimated value of the power demand. An error calculation process 1023 calculates the error (received power amount error) between

the actual value and estimated value of the received power amount. The demand error and received power amount error are transferred to a selection process 1024. The selection process 1024 selects one of these errors as a determination target, and transfers the selected error to a comparison process 1025. The comparison process 1025 compares the selected error with the present threshold, and stores a determination result indicating the magnitude relationship between them in the database unit 202.

FIG. 7 corresponds to a case in which a DR signal exists. Referring to FIG. 7, the threshold extraction process 1021 acquires, from the database unit 202, the value of a threshold (for DR) at the present time, and a DR receiving flag indicating that a DR signal is being received, in addition to the value of the threshold (for normal time) at the present time. The threshold extraction process 1021 outputs the threshold (for DR) while the DR signal is being received.

FIG. 8 is a view showing an example of a window displayed in the GUI 111 and used to set an estimated error determination threshold. That is, the GUI 111 functions as a setting unit for setting the threshold. Referring to FIG. 8, for example, the upper portion of the window shows a threshold input field for normal time, and the middle portion shows a threshold input field when a DR signal exists. Each threshold can be set for, e.g., every 30 min.

The user can determine the set value of the threshold

based on, e.g., past experience using the window shown in
FIG. 8. The lower portion of the window shows radio
buttons for designating one of the received power amount
and demand (electric power or heat) as a determination
5 target. When values at individual times are input and the
set button is clicked, the thresholds are set and stored in
the database unit 202.

FIG. 9 shows an example of the relationship between a
re-planned value and estimated error with respect to the
10 power demand. The one-dot dashed line shown in FIG. 9
indicates the change with time of a re-planning threshold T
set by using the window shown in FIG. 8. In a period of 30
min from 11:00, the re-planning threshold T is set at a
value much lower than that in other periods. In this
15 period, a curve indicating the error as the difference
between the estimated value and actual value is larger than
the threshold T, so the monitoring unit 102 generates an
estimation trigger.

This estimation trigger is input to the estimation
20 unit 106 and scheduling unit 105. Consequently, a process
of re-estimating the power demand or received power amount
and a re-planning process accompanying this process are
executed. FIG. 9 shows estimated values of one day
estimated until the previous day, and actual values on the
25 appointed day. For example, when the re-estimating process
is executed at 11:00, the error between the estimated value
and actual value becomes zero at that point in time.

FIG. 9 need only be able to explain the generation of the estimation trigger, and hence does not show any details, for the sake of simplicity.

FIG. 10 is a view showing an example of the
5 relationship between a re-planning threshold and estimated error with respect to the received power amount. FIG. 10 assumes that a DR signal exists. A DR period as a processing target is assumed to be 12:00 to 15:00. The re-planning threshold T is set at the lowest value from 11:00
10 to 11:30, at the second lowest value from 11:30 to 16:00, and a value higher than these values in other periods.

The error curve rises from about 6:00. On the other hand, since the threshold T becomes lowest at 11:00, the magnitude relationship between the error and threshold T is
15 inverted. Therefore, the re-estimating process and re-planning process are activated at this point in time. As a consequence, the error becomes 0. After that, the DR period comes, and a power reducing operation corresponding to the demand response is started, thereby reducing the
20 received power amount. The error changes in this DR period as well. For example, if the error exceeds the threshold at 15:00, the re-estimating process and re-planning process are activated even at this point in time.

When the DR period comes, the received power amount
25 can be reduced by activating, e.g., the CGS 28 (FIG. 2). The received power amount can also be reduced by reducing the necessary power amount of the air-cooling HP 22 by

manufacturing cold heat by the absorption chiller heater
25. However, FIG. 10 shows that the error starts
increasing from about 14:00 and exceeds the re-planning
threshold T at 15:00.

5 Accordingly, the error becomes 0 again by activating
the re-estimating process and re-planning process during
the DR period as well. By thus making the re-planning
threshold T in the DR period lower than those in other
periods, re-estimation and re-planning can be performed
10 even in the DR period. Also, re-planning can be performed
under stricter conditions during the DR period.

FIG. 11 is a view showing an example of the
relationship between processes in the estimation unit 106.
An error calculation process 1061 acquires an actual value
15 and estimated value of the power demand (or received power
amount) from the database unit 202, and calculates an error
at the present time. An expansion process 1062 expands
this error into values at individual times. The expanded
error string can be, e.g., an array in which errors at the
20 present times are arranged by the same value, but is not
limited to this.

An addition process 1063 acquires the error string
from the expansion process 1062, and acquires the estimated
value from the database unit 202. The addition process
25 1063 adds the error string to the estimated value, and
stores the obtained value as an estimation correction
result in the database unit 202.

FIG. 12 is a view for explaining the effect of the re-estimation process. A graph shown in FIG. 12 indicates an estimated value and actual value of the power demand on one day. There is an error between an estimated value $Pp0$ and
5 actual value Pa . If the error exceeds the re-planning threshold, the re-planning process is executed. Letting $\Delta P11$ be an error at present time 11:00, a new estimated value $Pp1$ can be obtained based on:

$$10 \quad Pp1 = Pp0 + \Delta P11 \quad \cdots (2)$$

By this re-planning process, the estimated error at 11:00 becomes 0.

FIG. 13 is a view showing an example of a window
15 displayed on the display 42. This window is displayed on the display 42 in step S7 of FIG. 5 in order to urge the user to approve an operation schedule. For example, different operation schedules are displayed on the right and left sides of the window. An operation button 301 is
20 displayed in the operation schedule on the left side. An operation button 302 is displayed in the operation schedule on the right side.

The left-side operation schedule indicates an operation schedule stored in the database 202b. The right-
25 side operation schedule indicates an operation schedule stored in the database 202a. That is, the schedule displayed on the left side indicates an operation schedule

created by the scheduling unit 105 when DR is received.

An incentive, cost, total cost, and peak power are displayed for each operation schedule. The operation schedule indicates the relationship between the received power amount and the heat storage and heat dissipation energy amounts.

The schedule on the left side of FIG. 13 shows that an incentive of 15,000 yen can be received by performing heat storage and heat dissipation, but the cost is 133,000 yen, so the total cost is 118,000 yen. The schedule on the right side shows that neither heat storage nor heat dissipation is performed based on a DR signal, so the total cost is 123,000 yen.

To give priority to cost reduction, the user need only select the left-side schedule. Therefore, the user can convey his or her intention to the system by clicking the operation button 301. Consequently, control based on the operation schedule taking account of DR is started.

Note that the peak of the received power amount for each schedule is also displayed. The peak power of the left-side schedule is 620 kW, and that of the right-side schedule is 900 kW. These numerical values can be used for reference in a case in which the received power amount is restricted. Note that the cost and peak power displayed in FIG. 13 are values supposed in a case where the operation schedule is executed (i.e., values calculated by the scheduling unit 105).

In the embodiment as described above, the error between the actual value and estimated value is calculated. If this error becomes equal to or larger than the preset threshold, a trigger for executing re-estimation of the demand and re-planning of the operation schedule is
5 generated. The user can freely set the error by using the interface as shown in FIG. 8.

The sensitivities of the estimation process and planning process can be increased by setting a small value
10 as the error in a desired period. This makes it possible to prepare an accurate operation schedule before a DR signal comes.

Also, in this embodiment, a trigger is generated based on the presence/absence of a demand response signal as
15 well. In addition, the threshold is variably set even in the DR period. These features make it possible to finely follow information and requirements contained in the demand response signal, and create an advantageous operation schedule.

That is, in the embodiment, it is possible to rapidly
20 review the operation schedule when a DR (Demand Response) signal is received. By immediately recalculating the operation schedule, it is possible to review estimation and perform re-planning in accordance with an error (the power
25 demand or received power amount) immediately after the DR signal is received. Accordingly, an accurate operation schedule can rapidly be executed.

From the foregoing, it is possible to provide an energy management server, energy management method, and program capable of creating an accurate operation schedule with respect to a demand response signal.

5 Note that the present invention is not limited to the above-mentioned embodiment. For example, at least one of the DR accepting unit 101, monitoring unit 102, DR formulation unit 103, acquisition unit 104, scheduling unit 105, estimation unit 106, weather data receiving unit 107,
10 transmission unit 108, approval unit 109, and determination unit 110 can also be implemented as a function of the cloud 9. Programs for implementing the functions of these functional blocks may be installed in a single computer, and may also be distributed to and installed in a plurality
15 of computers. How to implement these functional objects in the system will readily be understood by those skilled in the art.

 While certain embodiments of the inventions have been described, these embodiments have been presented by way of
20 examples only, and are not intended to limit the scope of the inventions. Indeed, the novel methods and systems described herein may be embodied in a variety of other forms; furthermore, various omissions, substitutions and changes in the form of the methods and systems described
25 herein may be made without departing from the spirit of the inventions. The appended claims and their equivalents are intended to cover such forms or modifications as would fall

within the scope and spirit of the inventions.

C L A I M S

1. An energy management server comprising:
 - an estimation unit configured to calculate an
 - 5 estimated value of an energy demand in a building in which an electric appliance is installed;
 - a scheduler configured to create an operation schedule of the electric appliance based on the estimated value of the energy demand;
 - 10 an acquisition unit configured to acquire an actual value of the energy demand;
 - a monitoring unit configured to monitor an error between the estimated value of the energy demand and the actual value of the energy demand;
 - 15 a receiving unit configured to receive a demand response signal containing information which prompts suppression of energy consumption in a designated period; and
 - a setting unit configured to set a threshold related
 - 20 to the demand response signal,
 - wherein the estimation unit recalculates the estimated value of the energy demand if the error is equal or more than the threshold, and
 - the scheduler reforms the operation schedule based on
 - 25 the recalculated estimated value of the energy demand.
2. The energy management server according to claim 1, wherein the threshold is variably set with respect to time.
- 30 3. The energy management server according to claim 1, wherein the threshold is set lower in the designated period than that in other periods.

4. The energy management server according to claim 1, further comprising a selection unit configured to select one of a power demand and a received power amount as the energy demand.

5

5. The energy management server according to claim 1, further comprising a determination unit configured to determine whether to respond to the demand response signal.

10

6. An energy management method applicable to a server which manages energy in a building in which an electric appliance is installed, the method comprising, in the server,

calculating an estimated value of an energy demand in
15 the building,

creating an operation schedule of the electric appliance based on the estimated value of the energy demand,

acquiring an actual value of the energy demand, and
20 monitoring an error between the estimated value of the energy demand and the actual value of the energy demand,

the calculating comprising recalculating the estimated value of the energy demand if the error is equal or more than a threshold set in association with a demand response
25 signal containing information which prompts suppression of energy consumption in a designated period, and

the creating comprising reforming the operation schedule based on the recalculated estimated value of the energy demand.

30

7. The energy management method according to claim 6, wherein the threshold is variably set with respect to time.

8. The energy management method according to claim 6, wherein the threshold is set lower in the designated period than that in other periods.

5 9. The energy management method according to claim 6, wherein the server further selects one of a power demand and a received power amount as the energy demand.

10 10. The energy management method according to claim 6, wherein the server further determines whether to respond to the demand response signal.

15 11. A program including an instruction for causing a computer to execute an energy management method cited in any one of claims 6 to 10.