

## WATER PURIFICATION SYSTEM AND PROCESS

### [0001] Background

[0002] 1. *Field:* Low cost and efficient, water purification system and process treats effluent or other contaminated water and other liquids and desalinates saltwater.

[0003] 2. *Related Application:* This application claims priority to provisional application No. 62/639,399, filed March 6, 2018, titled “Water Purification System and Process.”

[0004] 3. *State of the Art:* Applicants’ Patent No. 6,695,951 (2004) describes prior art water purification systems including those using distillation and reverse osmosis (RO). The patent also discusses the high energy and capital costs for systems that predate the ‘951 patent. Applicants incorporate those discussions and the rest of the ‘951 patent by reference.

[0005] The United Nations suggests 20 to 50 liters of water per person daily satisfies basic needs for drinking, cooking and cleaning. A United Nations report suggests at least 1.8 billion people use fecal-contaminated drinking water sources. Nearly 6,000 children die daily due to preventable water and sanitation-related diseases. Though the proportion of the global population with better drinking water sources increased from 76% to over 90% in the last 15 years, water scarcity still affects millions.

[0006] Applicants’ ‘951 patent teaches a system for generating safe drinking water from effluent or other contaminated water and saltwater. The patent’s system relies on, but is not limited to, low-pressure, low-temperature boiling from a rotating, thin boiler-condenser shell. Rotation takes advantage of “centrifugal” forces, i.e., the apparent outward forces that urge rotating bodies away from the center of rotation. The rotational forces thin the fluid layer and enhance heat transfer. The system can boil water with less heat energy expenditure than conventional systems expend due to increased thermodynamic heat transfer. The system centrifugally assists condensate removal from the condenser, which also improves condensing.

[0007] Operating at the low temperature also maintains contaminants below temperatures that could cause adverse chemical reactions. The reactions form scale buildup that diminishes the boiler heat-transfer coefficient. The low temperature operation also prevents contaminants from turning into vapor and migrating with the boiled water vapor toward the condenser. The centrifugal forces also aid in preventing dissolved and suspended contaminants from migrating with the water vapor towards the condenser because these centrifugal forces keep contaminants in the waste stream and direct them along the boiler surface where they exit the processor as part of the wastewater output.

[0008] The systems described in applicants' earlier patent are complex. Their capital costs may be less than conventional distillation or RO systems, but each unit may be costly relative to the wealth of persons or groups of persons in developing countries. Government and NGO funds also may be inadequate to support these systems' use throughout developing countries.

[0009] Larger systems designed to provide clean water for many persons also might require infrastructure to distribute the water. If the system were at a site with access to electricity to run it, the system's owner would need pumps, valves, water mains, pipes and other components to distribute water to houses, apartments, businesses, government offices, hospitals, schools or communal outlets. Centralized systems also are subject to political control and can be targets for terrorists, criminals and political opponents. Persons or families could use smaller, less complex devices to purify water for themselves without depending on larger systems tied into centralized water distribution systems.

[0010] The '951 patent has subsystems and jet-spray nozzles that clean the boiler walls automatically. Designing the system so individual users could take apart their units and clean or replace components quickly and return them to operation without a long downtime may avoid the need for the '951 patent's cleaning system. Even if the owners of system would not work on their own system, it is likely that at least one person in the surrounding area could repair it. Some of the '951 patent's other subsystems also may be unnecessary in smaller, individually owned devices.

[0011] The '951 patent's thin boiler-condenser walls provided high efficiency but may be costly to machine or form. The earlier patent's system has concentric walls, which can provide a greater output in the same space. That design also allows an array of units to occupy less area for the same clean water output. Space occupied by each new unit may be less critical because persons usually have enough space for small units where they live or work.

[0012] Using a thin boiler-condenser wall thickness with metals with high heat conductivity is important. The wall thickness may be 0.004 in. to 0.015 in. ( $\approx 0.10$  mm to 0.38 mm) (unit conversions are approximations). Thicker walls are possible, but they increase material cost and impede conductive heat transfer. The heat conductivity for steel, a typical, conventional boiler wall, is about 25 BTU/(ft.  $\times$  hr.  $\times$   $^{\circ}$ F)  $\approx$  (43 W/m  $^{\circ}$ C). That for aluminum is over five times higher, 136 Btu/ (ft.  $\times$  hr.  $\times$   $^{\circ}$ F)  $\approx$  (235 W/m  $^{\circ}$ C). Those figures are approximate because heat conductivity varies with temperature and alloying materials. Aluminum can be anodized to form a microscopic ( $\approx 6.35 \times 10^{-6}$  mm) protective oxide film. The film prevents uncontrolled corrosion and oxidation, which decreases conductivity. Copper's heat conductivity is about twice that of aluminum,

but aluminum is less costly (normally about ¼ of copper's price), is more available, lighter and may be easier to form.

[0013] Draining excess fluid and contaminants when the processor is off may be helpful. It can avoid contaminants from drying on the boiler-condenser walls or from having algae or fungi grow inside the processor. Circulating warm air or subjecting the processor to vacuum also enhances drying.

[0014] The system can use ordinary AC electrical power, but its low power needs may allow it to use solar-generated DC power, a 12 V DC vehicle battery or other sources of electricity.

[0015] Conventional processes used to make aluminum beverage cans (without a top or bottom) could form the boiler-condenser wall. United States companies manufacture about 100 billion ( $1 \times 10^{11}$ ) aluminum beverage cans yearly.

[0016] Applicants' systems can use thin-walled aluminum cylinders formed by impact extrusion. That process uses aluminum disks or slugs, which mount in a closed, cylindrical die. For can manufacturing, the aluminum usually is alloyed with small percentages of magnesium and manganese. A punch impacts the slug, which causes the aluminum to flow around the punch and form the cylindrical can. Additional processing finishes the can.

[0017] Other processes also fabricate aluminum cans. A cupping press cuts circular discs from sheet aluminum as shallow cups. The cups are drawn up into higher cups through a series of rings. When the cups reach their nominal height, the tops are cut off, so the cups are the same height. Again, additional processing finishes the can.

[0018] Twelve-ounce (355 ml) aluminum soft drink and beer cans with a 0.004 in. (0.10 mm) thick wall are standard in North America. The typical can's diameter is about 2.6 in. (6.6 cm). Standard European beverage cans are smaller and hold 330 ml (11.2 oz.). Different sized aluminum beverage cans exist, however. Brewers also sell beer in 16 oz. (473 ml), 24 oz. (710 ml) and 25 oz. (740 ml), but some so-called "energy drinks" use small, 250 ml (8.5 oz.) cans. Other sizes may be used, especially outside North America. Using larger size cans (height and diameter) for this process can deliver greater throughput.

[0019] Because cans are inexpensive, the boiler-condenser wall in a small water purification system could be an aluminum beverage can (without tops or bottoms). Their use could lower system fabrication costs because cans are so readily available.

[0020] Standard extrusion processes (i.e., forcing aluminum through a series of dies) also can create thin-walled aluminum cylinders for applicants' system. Using this process eliminates the need to cut off the bottom that forms during impact extrusion, but applicants' system and process

could use “used” cans with their top and bottom cut off. Using some of the billions of cans created annually may be advantageous because they can be ready sources of inexpensive, thin-walled, aluminum cylinders. But aluminum cans are the most recycled consumer product with an average can containing 70% recycled metal. It may be advantageous to recycle cans and use recycled or new aluminum to make the walls for applicants’ system.

[0021] Another possible method for constructing cylindrical shells of chosen diameter and length is to use thin sheet aluminum, 0.004 in. to 0.015 in. ( $\approx$  0.10 mm to 0.38 mm) thick, rolled around specific cylindrical molds. They may be spot-welded or glued together with a slight shell over-lap at the seam.

[0022] Whatever method makes the aluminum cylinders, forming new cylinders with proper diameters and heights probably is better than relying on used aluminum beverage cans. Multiple-cylinder systems require cylinders of different diameters. Those systems may require cylinders made specifically for applicants’ system.

[0023] Outside air pressure, acting on a vacuum container is 14.7 psia (101 kPa) at sea level. The wall thickness required to resist the crushing force acting inward on the walls increases disproportionately with the vacuum container’s diameter. If the total volume under vacuum is small due to a container’s relatively small diameter, the vacuum chamber’s outer wall can be thinner and use lighter-weight materials without collapsing under outside air pressure. Using a ribbed housing also could reduce wall thickness. This smaller system may offer advantages over the system that the ‘951 patent teaches.

[0024] As the ‘951 patent teaches, minimizing the fluid thickness against the boiler surface significantly improves heat transfer to the fluid. By rotating the boiler wall fast enough, centripetal “g” loads cause the fluid to form a thin, almost uniform film, for example between about 0.001 in. and 0.002 in. (0.025 mm to 0.051 mm) against the boiler shell’s surface.

[0025] **Summary**

[0026] References to “contaminated water” mean water or other liquid—the application uses “water” and “liquid” interchangeably—having undesirable components. Saltwater is contaminated because the salt prevents people from drinking the water.

[0027] Applicants’ small, low-cost processor converts saltwater, effluent or other contaminated water into potable water. The processor has two major subsystems, a boiler-condenser unit and a compressor unit. Both operate under low pressure of about 0.5 psia ( $\approx 3.5$  kPa or 1.0 in-Hg) at a commensurate 80°F ( $\approx 26.7^\circ\text{C}$ ) inlet water temperature. Different inlet water temperatures cause different operating pressures commensurate with the saturation temperature – pressure. When this application uses “vacuum,” it means low pressure, not a hard vacuum.

[0028] The boiler-condenser unit includes one or more thin-walled shells, preferably of aluminum. The shells rotate together at moderate speeds in the boiler-condenser unit. Each cylindrical shell has an inside surface, the boiler side. Each outside surface of the shells is the condenser side. The shells’ rotation causes contaminated water directed into each shell’s inside, boiler side to form a thin film. Wipers contacting or close to the boiler side may help form the thin film. This inlet contaminated water boils (heat of evaporation) on the shell’s inside surface because the processor pressure gradually elevates from the initial vacuum pump-down conditions up to the fixed saturation pressure of the inlet water (typically at ambient temperature). The evaporating vapor from the boiler side flows into the compressor. The compressed vapor flows to the shells’ condenser surfaces where it condenses. The phase-change back from vapor to liquid (heat of condensation) provides heat energy to the condenser surfaces. That energy is transferred across the shell from the condenser side to the boiler side. The heat of condensation on the condenser side produces the heat of evaporation on the boiler side (plus the additional entropy losses and small inefficiency losses from the processor).

[0029] Low friction wipers on each shell’s outside may help remove condensate from the shell and may leave an exposed surface for new condensate to form. This enhances the condensing heat transfer coefficient substantially and improves overall thermodynamic efficiency, which reduces the required energy per unit mass of freshwater produced. The inside and outside wipers increase the overall heat transfer coefficient over conventional distillation heat transfer mechanisms. The wipers further act as automatic mechanical mechanisms to clean the boiling and condensing wall surfaces from particulate build-up and corrosion.

[0030] The compressor and boiler-condenser units are in vapor communication with each other. They may mount in the same housing, but if they mount in separate, spaced-apart housings,

ducts can provide the vapor communication. Boiling at near vacuum produces vapor, which flows toward the compressor's upstream end. The system does not boil all incoming contaminated water. Some remains on the boiling surfaces and then flows as concentrated wastewater off the boiling surfaces. This is the Recovery Ratio = (Volume Fresh Out/Volume Input). The term "wastewater" also includes the contaminants remaining in the water. Because of boiling the incoming water, the contaminants are at a higher concentration in the wastewater than in the incoming contaminated water. The compressor increases the vapor's pressure typically about 0.04 psia to 0.15 psia (at ambient input temperatures), though higher or lower pressure increases may be advantageous. The vapor from the compressor is directed to the condenser surfaces of the shells where it condenses as freshwater. Structure in applicants' device collects the freshwater and directs vapor from the shells' boiler sides to the compressor and then to the shells' condenser side. Structure also directs the freshwater and wastewater to output pumps for storage.

[0031] Shell rotation enhances low-pressure boiling by increasing the boiling heat transfer coefficient. The rotation also enhances condensation (and the condensing heat transfer coefficient) because the condensate flings off the condenser surface so fresh vapor reaches the condenser surface more efficiently and quickly. Wipers, which help form thin films on the boiler surfaces and which remove condensate from the condenser surfaces, also enhance thermodynamic heat transfer coefficients and system throughput.

**[0032] Brief Description of the Drawings**

[0033] Fig. 1 is a sectional view of the water purification system where the blower assembly mounts above the condenser assembly in a housing.

[0034] Fig. 2 is a sectional view of the boiler-condenser assembly of the water purification system.

[0035] Fig. 3 is a sectional view of the blower assembly of the water purification system.

[0036] Fig. 4 is a sectional view of a rotating seal between the condenser assembly and boiler assembly of Fig. 1.

[0037] Fig. 5 is a schematic view of a pumping system of the water purification system for getting rid of waste and freshwater from a low-pressure water purification system.

[0038] Fig. 6 is a sectional view of the water purification system, which mounts in a canister.

[0039] Fig. 7 is a sectional view of the inlets and outlets of the water purification system.

[0040] Figs. 8 and 9 are sectional views of a multi-shell version of the boiler-condenser assembly. Fig. 9 is an enlarged view of Fig. 8's right side.

[0041] Fig. 10 is a sectional elevation of the multi-shell version of the water purification system.

[0042] Fig. 11 is an enlarged (from Fig. 10), sectional elevation of the lower portion for the multi-shell version of the water purification system.

[0043] Fig. 12 is cutaway, perspective drawing of the boiler-condenser shells and associated structure of the multi-shell version.

[0044] Fig. 13 is a sectional elevation of one-half of the boiler-condenser assembly of the water purification system.

[0045] Fig. 14 is an enlarged view of a portion of Fig. 13.

[0046] Fig. 15 is a cutaway perspective view of the boiler-condenser assembly and that assembly's connection to output pitot pumps.

[0047] Fig. 16 is a partial, cutaway perspective showing structure associated with the boiler-condenser assembly, lower rotating seal, and freshwater output pump drive mechanism.

[0048] Fig. 17 is an exploded view of parts for the boiler-condenser assembly, including the boiler and condenser wiper assemblies.

[0049] Fig. 18 also is a cutaway, perspective looking upward showing four concentric stationary boiler-wiper supports and for supplying contaminated water to the rotating shells.

- [0050] Fig. 19 is a perspective looking downward showing four concentric, stationary boiler-wiper supports and structure supplying contaminated water to the rotating shells.
- [0051] Fig. 20 is a cutaway, perspective looking downward showing four concentric stationary supports for wipers associated with the condenser surfaces of the rotating-condenser shells.
- [0052] Fig. 21 is a cutaway perspective view of a pitot pump that can be used with applicants' boiler-condenser assembly.
- [0053] Fig. 22 is another cutaway perspective view of the pitot pump in Fig. 21 looking from a different direction.
- [0054] Fig. 23 is a cutaway view of the lower assembly structure for rotating the moving parts of pitot pumps.
- [0055] Fig. 24 is a cutaway perspective view of a bearing support used in applicants' boiler-condenser assembly.
- [0056] Fig. 25 is a perspective view of applicants' boiler-condenser unit showing the shells and their associated structure forming the four, concentric boiler-condenser chambers.
- [0057] Fig. 26 is a perspective cutaway view of a lower portion of applicant's device below the boiler-condenser shells.
- [0058] Fig. 27 is a perspective view of the lower diverter of applicants' device.
- [0059] Fig. 28 is a cutaway view showing the inside of applicants' lower vacuum housing.
- [0060] Fig. 29 is a block diagram flow chart relating boiling and compression
- [0061] Fig. 30 is a graph of temperature–entropy for the process.
- [0062] Fig. 31 is a plan view of different version of the processor.
- [0063] Fig. 32 is partial front cutaway, perspective view of the Fig. 31 processor.
- [0064] Fig. 33 is a cutaway, perspective view of the shell used with the processor of Fig. 31.
- [0065] Fig. 34 is a top cutaway, perspective view of the Fig. 31 processor with the compressor removed.
- [0066] Fig. 35 is a partial cutaway perspective of the processor of Fig. 31, which shows details of the drive for the shell.
- [0067] Fig. 36 is a partial front sectional view of the processor of Fig. 31, which shows details of the drive for the shell and the lower seal.
- [0068] Fig. 37 is a partial front sectional view of the processor of Fig. 31, which shows details of the upper seal.

[0069] Fig. 38 is a perspective view in cross-section of one pitot pump used with the processor of Fig. 31.

[0070] Fig. 39 is front sectional view showing a mounting for the pitot pumps for the processor of Fig. 31.

[0071] Fig. 40 shows the drive components for the pitot pump assemblies.

[0073] **Detailed Description**

[0074] Reference to components of one or more drawing figures doesn't mean the component is visible only in those figures. To avoid overcrowding of reference numerals, some components may not be numbered in all figures in which they are visible.

[0075] **The Boiler-Condenser and Blower-Compressor Units of Figs. 1–9:** The water purification system **10** of Fig. 1 has two major components: (a) boiler-condenser unit **100** and (b) blower or compressor unit **200**. See Figs. 1, 2, 3 and 6. The two units can mount side-by-side or as Fig. 1 shows, above and below each other in a common housing. Having the components side-by-side and connected by ducting or other passages may cause heat losses and pressure drops from vapor moving between the components, but it may provide easier access to internal parts. Having the components in the same housing, however, should decrease heat losses and pressure drops. The applications reference to “a housing” refers to a single housing or multiple housings containing separate components.

[0076] The process may occur under 0.5 psia ( $\approx 3.5$  kPa or 26 Torr) reduced pressure, which this application may call “vacuum” or “near vacuum,” but other low pressures may be acceptable. The process could use pressures below 0.5 psia, but units operating at lower pressures must be more robust and are costlier to construct and operate. Vapor densities also are lower at lower pressures, which reduces mass flow.

[0077] Mounting the boiler-condenser unit below the compressor unit in the same housing also minimizes leak locations and cuts thermal loss. The processor in the drawings can maintain the low pressure without significant leaks in the system even though it uses low-cost parts with lower tolerances. This is possible because the process's sensitivity to slight pressure variations (leaks) is typically much less stringent than requirements for traditional vacuum chambers having harder vacuum.

[0078] Pumping down the system periodically can renew the desired pressure conditions. Renewed pump-down typically is required only occasionally, perhaps once or twice daily or even weekly. Required pump-downs only should take a few minutes.

[0079] The description refers to three sources of water: (1) incoming contaminated water, (2) processed potable water (also called “freshwater”) and (3) wastewater. Wastewater remains when the potable water is processed out of the contaminated water. “Contaminated water” includes many liquids such as water containing microbes or salts from bodies of water. Well water may hold pesticides, fertilizers, heavy metals, contaminants from failed septic tanks and other

chemicals. Some government or private water delivery systems may deliver water with few contaminants, but consumers may find the water contaminated.

[0080] **Transferring Water into the Boiler-Condenser Unit:** The Fig. 1 system connects to contaminated water source **14** (shown schematically). The water source can be spaced from the remaining components. For example, the water source could be a 55 gal. (208 l) drum, a cistern, a tank or some other source of water outside a house, apartment or office. The processor's internal operating pressure is low, so having a significant pressure head to transfer the contaminated water into the processor is unnecessary. Under the normal, low-pressure operating conditions ( $\approx 0.5$  psia), a pressure head of 30 feet or more (34 feet is hard vacuum) is practical with no inlet pump. Under these conditions, only a throttle valve (needle valve) is needed to regulate the inlet flow to the desired inlet flow rates. A pump may supply the necessary pressure if the contaminated source is more than a 34-foot drop to the processor.

[0081] One could provide a holding tank near the system with a manual or powered pump at a more distant, larger source of contaminated water. The pump could operate when the holding tank requires refilling. If pipes are not available to carry water to a holding tank, people can carry the water in containers from the source.

[0082] Valve **16** (Fig. 1) controls the liquid flow from the source through a line or tube (not shown) into the boiler-condenser unit **100**. A simple pinch valve may suffice because the water from the source typically is at a high-enough pressure to flow into the lower-pressure boiler-condenser unit, but the pressure head may vary as the holding tank fills and empties. The user may adjust the valve if it becomes clogged or worn. Computer control also may open, close and, in response to flow rate, adjust the valve in systems that are more sophisticated.

[0083] Having the components accessible for cleaning may be helpful because water from the source may contain solids, which could collect between the source and boiler-condenser unit **100**. Providing a trap (not shown) upstream from the processor could catch sand and other heavy or undissolved contaminants. Particulates are unlikely to cause problems; they should pass from the processor through the waste stream with little or no effect on the processor. Valve **16** likely is the most sensitive component to particulate contaminants, but opening and then resetting the valve to the desired flow conditions should flush the valve clean. Under certain conditions, inexpensive compression pinch valves on plastic or Tygon<sup>®</sup> tubes can be used.

[0084] **Mounting the Blower Unit Relative to the Boiler-Condenser Unit:** Blower or compressor unit **200** mounts above boiler-condenser unit **100** in housing **280** in Fig. 1. The housing

in Fig. 1 could have a one-foot ( $\approx 30$  cm) diameter, but its diameter depends on the diameter of the shell **110** and the parts surrounding the shell.

[0085] Housing **280** may be plastic due to plastic's low material and fabrication costs, but non-corrosive metals could be used instead. The plastic can be clear to allow one to view the internal components in operation. The housing's wall should be thick and strong enough to resist crushing force of atmospheric pressure acting on the housing's outside while the inside is under near-vacuum. Utilizing ribs in the housing could increase strength and reduces housing's weight and material cost.

[0086] Housing sections **182** and **282** connect to each other near midway between the top and bottom of combined housing **280**. See Fig. 1. But the connection could be closer to the combined housing's top or to the bottom. Though the application refers to the top and bottom of the components because of how the drawings show them, the processor is not necessarily vertical and may be mounted horizontally or at other orientations.

[0087] Boiler-condenser housing section **182** and blower housing section **282** form combined housing **280**. See Fig. 1. The former surrounds boiler-condenser unit **100** and the latter surrounds blower unit **200**. The two housing sections could connect in many ways, but in Fig. 1, threads **284** on blower housing section **282** mate with threads **184** on boiler-condenser housing section **182**. O-ring **186** in groove **187** enhances the leak-tight seal between the two housing units. The systems described in the drawings use many O-rings seated in grooves. The specification doesn't describe, and the drawings don't number all the O-rings or grooves. One of ordinary skill in the art will appreciate many grooves in the drawings, especially the smaller grooves, seat O-rings though the drawings show no O-ring, and grooves may not be numbered.

[0088] During operation, the inside of combined housing **280** is under near vacuum of about 0.5 psia ( $\approx 3.5$  kPa) during operation. The single threaded connection **184/284** is the only potential leak area, but the design with a single connection having an O-ring seal decreases or eliminates leaking. One or more external clamps (not shown) may be secured to the structure at the threads to prevent a user from unscrewing the housing sections **182** and **282** accidentally without first removing the clamps. Clamps also may improve the seal. After removing any clamps and unscrewing the housing sections, one has access to the components within combined housing **280**.

[0089] **The Blower:** Blower or compressor unit **200** includes a multi-stage blower **210**. See Fig. 1. A motor running the blower could mount inside housing **280**, but it would be subject to vapors and could cause thermal variations in the housing. In addition, a source of electricity must extend through the housing to the motor. Therefore, applicants mount motor **274** in motor housing **275**

outside the housing. See Fig. 1. The motor receives electric power from a source of power (not shown).

[0090] To avoid needing a seal in blower housing section **282** through which the shaft would extend, the motor shaft does not extend through the housing section. Any such seal, especially a rotating one, is a source of friction and potential vacuum leaks. The Fig. 1 system can use a magnetically coupled drive to avoid potential leaks. Motor **274** rotates outer magnetic coupler **276** adjacent the outside of blower housing section **282**, and magnetic force from the outer magnetic coupler rotates the inner magnetic coupler **277**. The motor may rotate about 2,000 rpm depending upon configuration and operating conditions. Such a motor uses relatively little electrical power during normal operation. The Fig. 1 system uses one motor **274** to drive blower **210** and shell **110**, but it could use separate motors.

[0091] A user having a motor operating other equipment might use that motor's output instead of dedicated motor **274**. Another source of rotational energy like a wind turbine or water wheel could act as a motor for the system especially with other structure to provide output at a desirable rpm. Such an outside system may be too complex to use instead of a simple, efficient, high-speed electric motor, however.

[0092] Parts mounted inside blower housing **282** have mounting structures. Inner magnetic coupler **277** attaches to and rotates shaft **278** (Fig. 1). The shaft rotates gear or pulley **279**, which drives belt **212** to rotate gear or pulley **214**. The specification refers to gears, pulleys and other circular drivers as "gears" though they may have no teeth. Gear **214** connects to and rotates drive shaft **216** of blower **210**. Bearings such as bearing **218** and **219** support the drive shaft for rotation. Bearings **220** and **221** also support shaft **278**. Even if not visible in the drawings or described in the text, rotating parts usually have bearings for friction reduction. Belts such as belt **212** may be flat or V-shaped to drive its gears or pulleys through friction, or the belts may be toothed to drive toothed gears or pulleys.

[0093] Gear **214** may be about one-fourth the diameter of gear **279**, which causes gear **214** to rotate four times as fast as gear **279** rotates. If motor **274** rotates at 2,000 rpm, gear **214** rotates at 8,000 rpm. Shaft **216** extends from gear **214** into blower **210** where it rotates the blower at that speed. Changing the gears' diameters changes their mechanical advantage to arrive at a proper blower speed.

[0094] A gear train, friction drive or other drive could replace belt **212** and another belt **104** described below. Belt drives are quieter, cost less and are easier to replace than other drives. Their low cost allows the owner to have several replacement belts on hand if one belt breaks.

[0095] Shaft 278 (Fig. 1) passes through blower frame 211 and bearing 221, but it could be off-set outside the blower frame. The shaft extends into gear 102. Shaft rotation rotates gear 102, which, through belt 104, rotates gear 106. Through additional structure described below, rotating gear 106 rotates boiler-condenser shell 110, which also is described below. The relative diameters of gears 102 and 106 and their mechanical advantage, rotate the boiler-condenser shell at about 250 rpm. For reference, a 13-cm radius shell rotating at 250 rpm produces centrifugal force of about 9.1 g ( $\approx 89 \text{ m/sec}^2$ ). Not that 1 system's 13-cm radius shell must rotate at 250 rpm. It probably could rotate more slowly.

[0096] The diameters of gears 279, 214, 102 and 106 in Fig. 1 are not necessarily to scale, but their diameters rotate blower 210 much faster than shell 110 rotates, e.g., 8,000 rpm for the blower versus 250 rpm for the shell. One can change the components' rotational velocities to account for the blower's specifications, the shell's diameter, the processing parameters and other factors.

[0097] Support insert 230 mounts inside combined housing 280. Two parts, upper support insert 232 around blower 210 and lower support insert 234 around boiler-condenser unit 100, form the combined support insert. The lower member attaches to base 185 of boiler-condenser unit housing section 182, and the upper member sits above the lower member. See Fig. 1.

[0098] Structure such as O-ring 285 at the top of the lower member may mate with structure at the bottom of the upper member to attach the members and prevent them from sliding relative to each other and provide a low-pressure seal created by the differential pressure produced by the blower. O-ring 285 need not create a hard seal; it positions members 234 and 232 relative to each other. Using an H-shaped ring is possible. Such a ring (not shown) is shaped as an H in cross-section with a groove facing upward and another facing downward. The wall of upper support 232 fits into the upward facing groove and the wall of lower support insert 234 faces into the downward facing groove.

[0099] **Boiler-Condenser Unit:** Shell 110 of boiler-condenser unit 100 rotates within lower structural support insert 234 and lower housing section 182. Lower insert 234 may have a structure such as bearing support 132 (Figs. 1 and 2), which extends upward at an angle from support insert 234. Extension ring 112 angles downward at an angle from the outside of shell 110. The extension ring and bearing support are aligned (Figs. 1, 2 and 4). The bearing supports are spaced apart annularly along support insert 234. The bearing supports, which support the shell for rotation, also could be a continuous ring, and the extension ring could be divided into spaced-apart extensions from the shell. Both could be continuous too. Bearings 131 mount on each

bearing support **132**, and extension **112** on shell **110** sits on the bearings. The bearings' spacing, size, and their interaction with extensions **112** must support the shell at its weight and its rotation at that angular velocity (e.g., 250 rpm). A larger or smaller diameter shell likely would rotate at a different angular velocity.

[00100] Boiler-condenser shell **110** includes cylindrical section **120** under dome **121**. The dome in the drawings has a substantial vertical portion after the curved portion, but the vertical portion could be shorter with a taller cylindrical section. If so, the upper part of the cylindrical section could be part of the dome just as the lower part of the dome could be part of the cylindrical section.

[00101] The shell's material preferably is high, heat conductive metal like aluminum. Impact extrusion could form the shell's aluminum, cylindrical wall and dome, but other fabrication techniques could be used. Aluminum's lower cost may make it the preferred material over copper or other good conductors. The dome's center may include depression **122**, which receives angled driver **109**. Shaft **107**, which is supported in bearing **108** (Fig. 1), rotates the angled driver. The angled driver engages the depression so driver rotation from the rotation of shaft **107** rotates the shell.

[00102] Angled driver **109** may have teeth engaging mating teeth on depression **122** so the angled driver and depression engage each other. The driver and depression can connect through a spline or other designs without teeth. Friction also could secure the driver to the depression for rotation. An angled driver such as driver **109** in the drawings makes assembly and disassembly during maintenance and repair easier.

[00103] The belt drive, gears and shafts allow one motor **274** in Fig. 1 to rotate blower **210** and shell **110**. Components discussed earlier allow rotation of components at different angular velocities to accommodate the distinct functions of blower unit **200** and boiler-condenser unit **100**. Other drive structures could connect motor **274** and its associated shafts, gears and pulleys to the rotating shell, however.

[00104] **System Operation:** Housing **280** must be evacuated at first to about 0.1 to 0.3 psia (0.69 kPa to 2.07 kPa). Tube **310** (Fig. 1) connects to a vacuum pump (not shown) to lower the pressure in the housing to that low pressure. After the pump initially evacuates the housing, the vacuum pump only runs occasionally to maintain the pressure near 0.5 psia (3.5 kPa). The tube is one of the few parts extending into the housing while the housing is under vacuum. The seal between the fixed tube and the housing and the tube-vacuum pump seal must be good enough to

maintain the desired pressure. A valve (not shown) between tube **310** and the vacuum pump isolates the unit when the vacuum pump is off.

[00105] Contaminated water from water source **14** and valve **16** flows through and into discharge tube **140** inside boiler-condenser shell **110** (Figs. 1 and 2). With the processor at an initial low pressure of 0.1 to 0.3 psia (0.69 kPa to 2.07 kPa) and initial inlet contaminated water enters, the processor's pressure climbs quickly to the 0.5 psia (3.5 kPa) saturation pressure commensurate with the inlet temperature (80°F ( $\approx$  26.7°C)). The tubes in Fig. 1 are straight, but they can have bends to allow connections with elements not aligned with straight tubes. See, for example, bend **140a** in discharge tube (Fig. 7). Elements may be provided to direct water toward the shell's inside, boiler surface. Those elements include nozzles (not shown), which may be as simple as small holes spaced along the discharge tube, that direct the contaminated water toward the shell's inside or boiler surface **114**. Making the holes or nozzles large enough could lessen potential clogging. Incoming contaminated water also can flow out the tube's top **140**. Shell rotation disperses the water along the shell's inside surface **114** and by having vanes or propeller-like structure **144** which rotate with the shell spraying the water. The vanes or propeller throw water toward the shell's inside surface when contaminated water hits them.

[00106] G-forces acting on the water due to rotation of shell **110** cause the water to form a thin film on the shell's inside surface **114**. The water film's thickness affects freshwater production. If the film is too thin, dry spots could form where no water-to-vapor conversion may occur, which decreases the effective heat transfer rates. If the film is too thick, heat transfer suffers.

[00107] Inside surface **114** of shell **110** is under vacuum. More about the temperature and the additional heat source below. At 0.5 psia, freshwater boils at about 27°C ( $\approx$  80°F), but the water's salinity and contaminants affects the boiling point. Graphs and charts comparing the boiling point of water as a function of pressure are available including those at [http://www.engineeringtoolbox.com/boiling-point-water-d\\_926.html](http://www.engineeringtoolbox.com/boiling-point-water-d_926.html).

[00108] Water boils on the inside surface **114** of shell **110**. That vapor is pure insofar as it contains no non-volatile contaminants. The resulting vapor travels out bottom **116** of shell **110**. Lower support insert **234** may have openings like opening **117** (Figs. 1 and 2) to let vapor flow through space **118** between housing **280** and the upper and lower support insert **232** and **234**.

[00109] When the contaminated water boils along inside surface **114** of shell **110**, the pure vapor moves away from the surface. Centrifugal force, which urges water to the shells' surfaces, does not urge the vapor back toward the shell's inside surface, but the non-volatiles like salts and contaminants remain along surface **114** and travel with the contaminated water. Further, the g-forces

caused by the moderate-speed rotation of shell **110** maintain the non-volatiles on the shell's inside surface until they exit at the bottom of shell **110**. Any buildup of salts and contaminants with remaining liquid water causes them to flow along the boiler wall.

[00110] Most contaminated water the system processes would not include condensable volatiles like petroleum or other dissolved gases. Dissolved O<sub>2</sub>, N<sub>2</sub> and CO<sub>2</sub> do not condense at the system temperatures, however. Their presence may raise the pressure inside the system, which could require occasional vacuum pump down use to decrease the pressure to desired levels. If the contaminated water contains volatiles, removing them before the applicants' system processes the water is desirable.

[00111] The vapor from shell **110** travels upward through space **118** toward the upstream, lower pressure end of blower **210**. The blower raises the vapor's pressure and temperature and directs this energized vapor toward the shell's outside surface **113**. The heat of the vapor exiting the blower includes three distinct parts: 1) sensible heat rise (able to be measured by a thermometer), which is superheated steam above the boiling saturation temperature; 2) the latent heat, which is locked up energy due to the phase change energy at boiling saturation; and 3) pressure increase energy, which resulted from the blower pressure rise to a higher condenser saturation temperature. The latent heat and pressure-rise energy causes a useable temperature increase  $\Delta T_{bc}$  between the boiler and condenser to drive the process, which occurs at the higher saturation temperature and pressure in the condenser, and results in phase-change (vapor to liquid) in the condenser with heat transfer from condenser to boiler. Note the superheated vapor must cool in the condenser chamber down to the saturation temperature (by low efficiency, convective vapor heat transfer on the condenser  $\approx 500$  Btu/hr-°F-ft<sup>2</sup>) until the high efficiency phase-change, heat transfer can occur ( $\approx 5,000$  Btu/hr-°F-ft<sup>2</sup>). Phase-change heat transfer occurs when the temperature drops from super-heated conditions to the saturation temperature (and pressure) in the condenser, which had been elevated by the pressure rise from the blower. This is the increased latent energy heat transfer that drives the processor.

[0100] The temperature difference between the boiler and condenser  $\Delta T_{bc}$  at the vapor-liquid saturation conditions is computed by the Clausius-Clapeyron equation:  $\Delta T_{bc} = \left( \frac{\Delta p_{bc}}{p_b} \right) \left( \frac{RT_b^2}{h_{fg}} \right)$ . In this equation,  $R$  is the gas constant,  $h_{fg}$  is heat of vaporization (fluid to gas),  $\Delta T_{bc}$  is the boiler-condenser temperature difference at saturation,  $\Delta p_{bc}$  is the pressure difference generated by the blower between the boiler and condenser, and  $p_b$  and  $T_b$  are the boiler pressure and temperature, respectively. Any method or technique maximizing the heat transfer coefficient without substantially increasing the working temperature  $T_b$  or the temperature difference  $\Delta T_{bc}$  is advantageous.

Thin-film boiling and condensing due to boiler-condenser rotation along with wiping these surfaces to maintain thin and uniform liquid surfaces make such a large heat transfer coefficient possible. More about wiping below.

[0101] Boiling water on a shell's surface transfers heat energy from the surface to the water. Boiling changes phase from liquid to vapor at the same temperature. That phase change requires much more energy (heat of vaporization) than the small, sensible heat energy rise resulting from the super-heated vapor temperature rise between the boiler and condenser. Heat transfer across applicants' shell **110** to the liquid water drives and causes boiling in the boiling chamber, which cools the shell's temperature. But a continuous flow of constant-temperature input feed-water is injected inside the boiler for further evaporation, so the shell is maintained at a steady-state temperature. The tendency towards a lower shell temperature due to evaporation in the boiler is countered by the continuous heat flux transferred from the condensing vapor on the shell's outside surface **113**, causing boiling and maintaining the shell at a constant steady state temperature.

[0102] The needed, added energy for driving the boiling process comes from the blower compression energy stored in the vapor, which provides the heat of condensation driving energy. The added energy transfers across the shell to cause continuous boiling (heat of vaporization energy). As an example: consider the inlet boiler temperature  $T_b = 80^\circ\text{F}$  ( $26.7^\circ\text{C}$ ) with the boiler saturation pressure  $p_b = 0.5$  psia (3.45 kPa), and a vapor-liquid saturation temperature difference  $\Delta T_{bc} = 3^\circ\text{F}$  ( $1.66^\circ\text{C}$ ). The blower energy developed that temperature difference, which produced a condenser pressure rise  $\Delta p_c = 0.05$  psia (0.345 kPa). The boiling energy (heat of vaporization) at  $80^\circ\text{F}$  is 1,096.1 Btu/lb (2,550 J/g), and the condensing energy (heat of condensation) at  $83^\circ\text{F}$  (i.e.,  $80^\circ + 3^\circ$ ) ( $28.3^\circ\text{C}$ ) is 1,097.4 Btu/lb (2,553 J/g). Raising the temperature of water  $1^\circ\text{F}$  ( $1.8^\circ\text{C}$ ) requires only about 1 Btu/lb (2.24 J/g), and raising the vapor temperature  $1^\circ\text{F}$  ( $1.8^\circ\text{C}$ ) only requires about 0.43 Btu/lb (1 J/g). The huge heat of vaporization energy required to boil the inlet water (1,096.1 Btu/lb or 2,550 J/g) is supplied by the similarly large heat of condensation energy released during the condensation process (1,097.4 Btu/lb (2,553 J/g)).

[0103] The temperature of the shells rapidly becomes equal to the temperature of the incoming water because of the shells' low thermal mass (small heat capacity relative to the incoming water heat capacity). If the shells were initially warmer than the input water, they would quickly cool to the same temperature of the input water by transferring their heat to the input water. The unit internal pressure would rise slightly, but if the starting pressure (e.g., 0.3 psia) is less than the input water's saturation pressure (e.g., 0.5 psia), the process equilibrates to the 0.5 psia saturation pressure immediately. If the shells were cooler than the input water temperature, they would

quickly warm up. Input water that does not boil is expelled as part of the wastewater, but the shells would now be equal to the temperature of the input water.

[0104] When the process starts, the internal pressure is reduced to below the saturation pressure of the incoming fluid (e.g., below 0.5 psia, to about 0.3 psia or below). If the input water is 80°F, the water immediately boils, and the internal pressure rises to the saturation pressure (0.5 psia). Boiling starts because the unit pressure is below the saturation pressure of the input water (0.3 psia versus 0.5 psia). Once the boiling process starts, it continues because heat transfer from condensing fresh fluid on the condenser transfers heat to the shells' boiler surface.

[0105] Had the initial internal pressure been above the saturation pressure of the incoming fluid, the processor would not operate. But if the initial internal pressure is below the saturation pressure of the incoming fluid, the process starts immediately. Not reducing the temperature of the incoming fluid during operation (i.e., reducing its saturation temperature and, hence, saturation pressure) to below the unit's internal working pressure is important. Otherwise the process stops. Applicants maintain the temperature of the incoming fluid constant (or close to constant), so the process does not stop.

[0106] If the process stops, turning on the vacuum pump until the internal pressure is below the "new" lower saturation pressure causes the process to start immediately and continue. If the initial starting pressure of the unit is equal to the saturation pressure of the incoming fluid (e.g., 0.5 psia), the unit still operates because some of the input fluid evaporates inside the boiler chamber, is compressed by the compressor and condenses on the condenser. That starts and keeps the boiling process continuing. If the starting internal pressure is equal to the saturation pressure, the unit takes longer to stabilize up to full capacity, but shortly, the unit equilibrates. But the unit does not operate as efficiently with non-condensable gases present because they occupy a partial pressure inside the unit that can be removed by a short duration and intermittent vacuum pump down.

[0107] These factors make starting the unit at a pressure below the working saturation pressure of the incoming fluid desirable. If the incoming temperature is 80°F and the saturation pressure is 0.5 psia, starting the unit at a pressure below 0.5 psia (e.g.,  $\leq 0.3$  psia) overcomes these problems. If the inlet temperature (and, hence, pressure) drops below the internal working pressure of the unit, the vacuum pump could be activated for a brief time to reduce the internal working pressure of the unit to below the saturation pressure of the incoming fluid. Then the process immediately jumps back into operation and stabilizes again.

[0108] Fig. 29 is a block diagram flow chart relating boiling and compression phases, and Fig. 30 is graph relating the temperature and entropy during the process. In Fig. 30, contaminated

water enters the processor (boiler) at state 1 at temperature  $T_1$  and pressure  $P_B$ . As the water boils, it changes phase to state 2 but remains at the same inlet temperature  $T_1$  ( $T_2 = T_1$ ). But its entropy increases (going from liquid state to vapor state). The concentrated wastewater exits the processor at temperature  $T_6$ , where  $T_6 = T_1$ . The vapor travels to the inlet of the blower where the compressor compresses the vapor. The pressure and temperature increase to pressure  $P_C$  and temperature  $T_3$ ; which is super-heated; i.e., above the saturation temperature  $T_4$  (by  $\Delta T_{SH}$ ). Once the superheated vapor transfers its sensible heat energy to the condenser (through low efficiency, convective heat transfer), its temperature drops from  $T_3$  to  $T_4$ . This saturated vapor, which is at a higher temperature and pressure than the boiling vapor, transfers its latent heat energy ( $\Delta T_{BC}$ ) by changing phase from vapor to pure liquid through high efficiency, phase change heat transfer. The vapor's entropy decreases during phase change to pure distillate and exits the processor at temperature  $T_5$ , which is the same temperature  $T_4$  as the saturated vapor in the condenser. Note, if salts are present in the input contaminated fluid, an additional amount of heat energy must overcome the boiling point rise  $\Delta T_{BPR}$ . Therefore, the total temperature difference will be  $\Delta T_{tot} = \Delta T_{BC} + \Delta T_{BPR}$ .

[0109] As vapor exits blower **210** at a higher pressure and temperature, the vapor contacts outside surface **113** of shell **110**. Because boiling occurs from the shell's inside surface, boiler surface **114** transfers energy from the shell's outside surface, with the shell's temperature lower than that of the condensing vapor. The vapor had increased in temperature and pressure from energy supplied by the blower. When the warmer vapor contacts the shell's lower temperature, outside surface, the vapor condenses into liquid water. The phase change from vapor to liquid on the condenser surfaces transfers heat energy back through the shell. That heat energy is transferred to the liquid water on the shell's inside surface for boiling the contaminated liquid. The vapor's higher pressures and temperatures on the shell's outside surface prevents any low-temperature boiling of condensed liquid from the outside surface because the shell always is colder than the condensed vapor and liquid condensate.

[0110] Extracting all the water as potable water from the incoming contaminated water may not be necessary or desirable. While some contaminated water entering the inside of shell **110** of boiler-condenser unit **100** boils, contaminated water that doesn't boil remains as liquid wastewater to carry contaminants with it. Remaining contaminated water and contaminants extracted from non-boiled water flow downward under gravity and centrifugally assisted forces toward the shell's bottom **116**. When the contaminants and wastewater reach the inside wall's bottom of shell **110**, they collect along inside edge **119** and on base **185** of boiler-condenser housing section **182**.

[0111] Openings such as hole **117** (Figs. 1 and 2) for passing vapor from boiler-condenser unit **100** to blower unit **200** are near the bottom of **234** and near base **185**. Positioning the holes so contaminants and wastewater do not pass through the holes is important because centrifugal force on the contaminants and wastewater throws them outward as they exit the shell. Otherwise, added structure could block the thrown water from reaching the holes. Base **185** slopes (lower on the left side of Figs. 1 and 2) so contaminants and wastewater collect at outlet **160**.

[0112] Injecting clean water or steam occasionally through inlet **140** into boiler-condenser shell **110** can clean the shell's inside. Regularly removing seawater or algae infested water from inside the processor when the processor is not in use should lengthen the time before the user must replace the shell.

[0113] Injecting steam at atmospheric pressure into boiler-condenser shell **110** before starting the process and before processor evacuation helps replace non-condensable air (mainly O<sub>2</sub>, N<sub>2</sub>, Ar and CO<sub>2</sub>) with condensable water vapor so only water vapor remains when the system operates. For this option, applicants could use a small external heater for producing steam. Because the heater would operate only briefly, it may not consume substantial electrical power to affect electrical usage adversely.

[0114] **Wipers:** One or more internal wipers may mount inside shell **110** of boiler-condenser unit **100** and extend to the shell's inside surface **114**. In Figs. 1 and 2, internal wiper **170** mounts around inlet tube **140**. The wiper may have multiple struts **172**, and each strut may have a flexible wiper blade **174**. The wiper blade's outer edge contacts the shell's inside surface. Having evenly spaced wipers around the shell balances any small forces from the wipers to the shell. When the wiper blade contacts contaminants and contaminated water, it dislodges them causing them to descend. To reduce friction between the wiper and the shell, the wipers may be formed of or coated with Teflon® or other, low-friction material.

[0115] Pressure from wiper blade **174** against the inside surface of shell **110** need not remove all the liquid. Unlike a vehicle windshield wiper, which leaves glass surfaces temporarily without water, wiper blade **174** doesn't remove all the contaminated liquid from the shell's inside surface. Instead, the wipers thin the fluid film further to increase the boiling heat transfer coefficient substantially. The boiler wipers redistribute the fluid in a thin film on the boiler surface continuously until the excess fluid flows by gravity and wiper excess out of the boiler chamber. Because the wiper blade is not removing all the water from the shell's inside, it doesn't push hard against the inside and should not add much to the system's electric power requirements used to overcome friction between the wipers and the shells. Configuring the boiler wipers in this manner

also keeps the boiling wall surface clean by helping prevent scale or sludge buildup on the boiler inside surface. The boiler wipers, therefore, serve two beneficial features: enhancing thermodynamic heat transfer by thinning the liquid film uniformly and cleaning the boiler wall surface continuously.

[0116] Wipers also can remove water from the condenser-outside surface **113** of shell **110**. As vapor condenses on the outside surface, the water forms droplets that grow as more vapor condenses. When the droplets have enough mass, centrifugal force from the shell's rotation throws off the droplets. But surface tension holds condensed water on the shell. External wipers **176** (Figs. 1 and 2) for the shells' outside surfaces mount on supports **177**, which connect to lower support insert **234**. The condenser wipers remove condensed water that centrifugal force did not remove from the shell's outside surface. Removing the condensed water enhances the condensing heat transfer coefficient. By removing condensed liquid from the shell's outer surface that centrifugal force would not remove immediately or as effectively, more of the shell's metal surface area becomes free of liquid and exposed to vapor, which makes condensation much more efficient.

[0117] All internal wiper blades **170** in Figs. 1 and 2 are at the same level so each contacts the same region of the inside surface of shell **110**. They also could be spaced vertically to contact different regions. External wiper blades **176** also could be spaced vertically.

[0118] The wipers also may mount at an angle to the shell's axis of rotation or a single wiper may form a curved or spiral-like path along shell's surface **110**. The internal wiper **170**, which spreads contaminated water along the boiler surface, may be angled so its surface drags along the boiler surface as the shell rotates. The external wiper **176** for removing condensate from the condenser surface also may present a sharp edge facing the shell's rotation to throw condensate from the condenser's surface.

[0119] Similar concerns about wiper drag friction apply to inner wipers **170** and outer wipers **176**. As pressure from the wiper blades increases, maintaining rotation of shell **110** requires more energy. Applicants estimate four, spaced, Teflon<sup>®</sup>, condenser wipers pressing on the condenser shell with a 4 oz. (1.1 N) force each (drag coefficient of 0.11), spinning a 13.75-in (34.93 cm) shell at 100 rpm ( $\approx 2 \text{ g's}$ ) produces about 0.9 watts of rotational, frictional drag power loss. Similar losses occur for the boiler wipers. Assuming four Teflon boiler wipers also, the total rotational frictional drag power losses incurred from both the boiler and condenser wipers are about 1.8 Watts. But the wipers likely increase total heat transfer coefficient at least by a factor

of 10. Added system performance from using wipers outweighs any small energy penalty for using them.

[0120] Freshwater from outer, condenser surface **113** of shell **110** collects in region **178** around the shell. See Figs. 1, 2 and 4. The water then flows into outlet **179**. Annular disk **130** at the bottom of region **178** is angled to direct the water down toward lower support insert **234**. The outlet may be near the support insert **234** so water flows into the outlet.

[0121] **Rotating Vapor Seal:** The inside and outside of shell **110** are at different pressures. Rubber or plastic seals separating the regions of different pressure could create significant frictional losses as the shell rotates, especially with larger shells or faster shell rotation. Seals between rotating parts also wear, are costly and need regular maintenance, which affects ease of assembly and reliability.

[0122] The seal in Figs. 1, 2 and 4 seek to avoid problems with conventional, rotating vapor-to-vapor seals. Seal **190** (best seen in Fig. 4) includes vertical projection **191** extending upward from the inside end of annular disk **130** and horizontal projection **192** extending outward from the vertical projection's top. The disk extends around the inside of lower support insert **234**.

[0123] Channel **189** (Fig. 4) comprises ring **193** extending outward from shell **110**, hoop **194** extending downward from the end of the ring, and projection **195** extending inward from the bottom of the hoop (together all forming a rotating U-Channel). Channel **189** has a distal end, and stationary disk **192** extends through rotating channel **189**'s proximal end. See Fig. 4. Water **197** collected in the channel, rotates at about 100 rpm, the rotational speed of shell **110**, because the channel revolves with the shell. The rotation produces centrifugal force on the water, which urges the water distally against channel's distal end at hoop **194**. Pressure from vapor on the shell's outside-condenser side acts in region **198** on a first side of the shell, and pressure from vapor from the inside-boiler side of the shell acts in region **199** on a second side of the water. The higher pressure from the compressor moves the water toward the lower pressure from the boiler against the rotated fluid in the channel. Centrifugal force from rotation acts against the pressure-differential force to hold the fluid in the channel. Fig. 4 shows the water positioning in response to the pressure differential. The components' designs prevent force from the pressure differential from overcoming the centrifugal force acting on the water so remaining water in space **196** in the channel becomes a vapor seal between the different pressures.

[0124] The pressure forces caused by spinning a rotating U-channel filled with water, which is being "cut" by a stationary disc extending into a depth  $\Delta R$  of the rotating water (described above), are computed by noting that the fluid pressure  $p$  against the fluid with density  $\rho$  is given

by  $p = \rho g r$ . Because the channel rotates with speed  $\omega$ , the centripetal g forces acting on the trapped water vary with radius  $r$ . The differential pressure is  $P = \rho g(r)r = \rho(\omega^2 r)r \rightarrow dP = 2\rho\omega^2 r dr$ . Integrating this relation gives the total differential pressure possible from the rotating seal yielding  $\Delta p = \rho\omega^2(R_2^2 - R_1^2) = \rho\omega^2 \Delta R(2R_2 - \Delta R) \approx 2\rho\omega^2 R_2 \Delta R$ . If the seal uses a fluid with a density higher than water, the sealing pressure forces increase linearly. The sealing pressure potential, therefore, increases quadratically with rotational speed ( $\omega$ ), and linearly with increased differential liquid seal channel depth ( $\Delta R$ ) or the seal radius ( $R_2$ ). Doubling the seal channel depth radius ( $\Delta R$ ) adds little to the system's overall diameter (compared to  $R_2$ ), but the sealing pressure capability doubles.

[0125] **Removing Potable and Wastewater from the Housing:** Potable water in outlet **179** and wastewater in outlet **160** (Figs. 1, 2 and 7) must be collected outside the processor at atmospheric pressure (14.7 psia (101 kPa) at sea level), but the low pressure at the outlets' upstream ends prevents water from flowing out the outlets. Suction pumps develop insufficient pressure head to remove the wastewater and fresh, potable water from the processor while the processor is operating under near vacuum. Using conventional, positive displacement pumps to push the water from the outlets requires much energy, which is undesirable in this system. Water also must be pumped out without letting in air. Even a small volume of outside air changes the internal pressure and operating conditions.

[0126] Applicants may use a positive displacement bladder pump as one option for the combined freshwater and wastewater output pump system **300**. Fig. 5 shows it schematically. It operates on the freshwater and wastewater simultaneously by alternately pressurizing bladders to force the fluids out against the atmospheric pressure head. This application discusses other means below for removing freshwater and wastewater from the processor.

[0127] Wastewater and contaminants from outlet **160** (Figs. 1, 2, 5 and 7) enter pump system **300** in chamber **302**. See Fig. 5. Two-part housing members **304** and **306**, which O-ring **308** seals, forms the chamber. Outlet **160** is sealed to fitting **310** on housing member **304**. Water can flow from the outlet into the chamber **302** because the outlet and chamber are at the same low, near-vacuum pressure. Spring-loaded hinge plate **312** or another plate-like member, which mounts on housing member **304**, normally is open as in Fig. 5 so it doesn't block gravity water flow into chamber **302**. Expandable and contractible bladder **320** mounts in chamber **302**. The bladder occupies most of the chamber when it expands, but it occupies only a small volume when it contracts.

[0128] With bladder **320** contracted, wastewater and contaminants from chamber **302** can flow by gravity into exit conduit **322** (Fig. 5). The exit conduit is sealed to fitting **324**. Flexible, self-sealing “reed” valve **330** or another type of check valve closes the exit conduit. The pressure above the valve, which is the same as the processer’s pressure, is near vacuum, but the pressure below the valve is atmospheric. Reed valves like valve **330** may be like valves in helium-filled Mylar balloons. The inexpensive valves used with balloons keep helium-filled balloons filled for weeks. Helium’s smaller molecules are more challenging to one-way valves than are the O<sub>2</sub>, N<sub>2</sub>, Ar and CO<sub>2</sub> molecules of air on the other side of the valves in applicants’ system. The liquid water and water vapor inside the bladder pump also help seal the reed valve’s upstream side from air leakage back through the valve.

[0129] When bladder **320** expands, it pushes hinge plate **312** up to close off the entrance from outlet **160** into chamber **302**. Closing the hinge plate prevents back-flow and separates housing **280** and outlet **160** (Fig. 1), which are under near vacuum, from chamber **302** (Fig. 5). The bladder’s expansion decreases the effective volume inside the chamber to raise the hydraulic pressure to greater than ambient pressure at exit conduit **322** (Fig. 5). This urges the wastewater and contaminants past valve **330** and out the exit conduit for disposal. Reed valve **330** or another check valve prevents any backward flow of air into chamber **302**. The bladder’s expansion should provide pressure above atmospheric to overcome any back force from the check/reed valve.

[0130] The system for removing freshwater from outlet **179** is like the wastewater removal system. The outlet and chamber are at the same near-vacuum pressure so freshwater can flow into chamber **342**. Normally open, spring-loaded hinge plate **352** does not block gravity-fed freshwater. Bladder **360** in chamber **342** contracts to occupy only a small volume, which allows the rest of the chamber to fill with water from outlet **179**. Expanding the bladder pushes the freshwater from the chamber past reed valve **360** and through exit conduit **362** to freshwater storage.

[0131] A small, intermittent and controlled pump–vacuum pump arrangement expands and contracts bladders **320** and **360**. Bladders **320** and **360** are flexible, but the walls of chambers **302** and **342** prevent the bladders from becoming overinflated and popping. Chamber **370** contains piston **372** that can move from end to end in the chamber. Compression spring **374** urges the piston “up” (Fig. 5). Vacuum pump **380** can draw air from bladder **320** through tube **388** and from bladder **360** through tube **386** into their collapsed condition when the piston is up. When the bladders collapse, wastewater from outlet **160** and freshwater from outlet **179** can flow into respective chambers **302** or **342**. When the vacuum pump turns off, pressure pump **376** can be activated. Its pressure pushes through tube **378** to push the piston “down,” which exposes tubes **386** and **388** to the pump’s pressure. The pressurized air flows into the bladders to expand them,

which close spring valves **312** and **352**, and then pushes wastewater and freshwater into their respective outlets.

[0132] Components of pump system **300** can be low cost, and the energy required to pump out the fluid is low. To save electricity, neither pressure pump **376** nor vacuum pump **380** operates continually. Instead, the pump system may work intermittently when sensors determine one or both chambers **302** and **342** are filled to predetermined levels.

[0133] **Limiting Condensation on the Housing and other Internal Components:** The system can process incoming contaminated water at a range of temperatures. The ambient pressure (sea level to higher altitudes) should be unimportant because the system operates inside the processor internally at near vacuum. Depending on the temperature of the water boiled from the inside surface of the shell **110** and the temperature of the inside surface of housing **280** and other components, vapor could condense prematurely on the housing's inside surface and on other components. The premature condensing decreases system efficiency and drinkable water throughput. Any premature condensation prevents the transfer of the vapor's phase change energy from its heat of condensation to the shell and is unavailable for relinquishing and recovering the condensation energy back to the boiler because it fails to reach the shell's outside, condenser surface **113**. Condensate on the housing also is not removed from the system as potable water.

[0134] Any vapor condensing away from outside surface **113** of shell **110** varies with the housing's temperature, which environmental conditions affect. Temperatures likely could be between about 60 to 110°F ( $\approx$  16 to 43°C). If housing **280** is sufficiently warm as it could be on a warm day, little or no unwanted condensation may happen. But more vapor could condense on the unwanted surfaces at colder ambient temperatures.

[0135] A small electric heater could heat housing **280**, but electric heaters may be inefficient and may need controls to maintain the housing temperature within proper ranges. Instead of using an electric heater, water from contaminated source **14** (Fig. 1) can maintain the temperature of housing **280** in a proper range. To use the water for temperature maintenance, the housing and the components in the housing mount in canister **400**. See Fig. 6. Motor **274** and motor housing **275**, which are outside housing **280** (Fig. 1), are outside the canister. For access to the housing, the canister may be two parts, an upper part **402** and a lower part **404**. The canister's parts connect at rims **406** and **407**. O-ring **408** between the two rims acts as a seal. The rims may be secured together in many ways, and the canisters could attach without rims. If rims are used, clamps or bolts around the rims could hold them together. The two halves also could be screwed together with threads at the ends of upper part **402** and lower part **404** (analogous to housing **182**

and 282). The seal between the two halves 402 and 404 need not be robust because the water pressure in the canister is not elevated.

[0136] Inlet 412 connects to the source of contaminated water to fill the space between housing 280 and the canister 400. The space may be narrow, e.g., about 0.25 in (0.6 cm) wide. Filling the space requires no significant volume of water. An optional, small, motor-driven propeller 416 (Fig. 6) may circulate the water. The contaminated water used as a thermal insulator inside canister 400 may exit at outlet 410 and is redirected as the input feed water into inlet tube 140. A small pump (not shown) may circulate the water within canister 400 back into the contaminated water source to maintain a constant temperature between inlet 412 and canister 400.

[0137] Using contaminated water inside canister 400 aligns the temperature of housing 282 and other structure in housing 280 with the water temperature being processed so the housing walls and other components' temperatures are in thermal equilibrium with the input contaminated feed-water to prevent or at least limit vapor condensing on the inside of the housing or on other components.

[0138] Though using contaminated water in canister 400 instead of heated air may use less power, using heated air still may be acceptable. Instead of having inlets and outlets 410 and 412 and a propeller 416 to circulate water, a heater fan may draw in and warm air from outside the canister. The fan would circulate the air to warm entire housing 280. Controls may activate the heater fan when warming is necessary.

[0139] The Fig. 6 components for limiting condensation on the housing and other internal components would be useful with the devices in other drawings though the other figures show no such components, and the specification discussing the devices in those other drawings doesn't discuss incorporating the components.

[0140] **Repair or Replacement of Housing Components:** Access inside housing 280 allows cleaning, repair and maintaining the processor's internal parts. If the housing is in canister 400 (Fig. 6), the canister's two sections 402 and 404 are separated first. Then, the two housing sections 182 and 282 (Figs. 1 and 6) are separated. An alternate simpler configuration could involve constructing a sealed cylindrical shell surrounding 182 (similar to 402) and another sealed cylindrical shell surrounding 282 (similar to 404), which is sealed at the respective flange threads 184 and 284. A tube would be necessary to connect flow between 402 to 404.

[0141] Detaching upper support insert 232 from O-ring 285 and lower support insert 234 allows removal of support insert 230 from lower housing section 182. See Fig. 1. Doing so removes

blower **210** and the components tied to shaft **278**. Removing angled driver **109** from depression **122** in shell **110** allows access to boiler-condenser unit **100**.

[0142] Shell **110** then is lifted. Making disk **192** flexible, horizontal projection **193** and disk **195** of seal **190** (Fig. 4) are prevented from interfering with shell removal and insertion. Flexibility should not undermine their sealing functions. Wipers **170** and **176** (Figs. 1, 2 and 6) may be delicate. During assembly/disassembly, inserting a cylindrical tool to expand external wiper **176** to provide clearance for seal **190** may be helpful while the shell is removed. Tube **140** can separate with a simple disconnect similar to **140a** (shown in Fig. 7) when the shell is removed.

[0143] The entire boiler-condenser unit including lower support insert **234** may be removed as one unit instead of removing shell **110** only. Doing so, allows the shell and lower support insert **234** can be removed together for separate assembly/disassembly on a workbench. Doing so requires using quick disconnect fittings for freshwater outlet **179** and contaminated water inlet tube **140** from lower housing **185**. Quick disconnect fittings may look similar to fittings depicted in Fig. 6.

[0144] The Fig. 7 inlet tube **140a** may have a bend, and its bottom may rest on grommet seal **141**. The top of the grommet seal and the bottom of the inlet tube are tapered. A less than 10° taper should suffice. Freshwater outlet **179** has a similar taper to engage the taper at the top of grommet seal **180**. Waste outlet tube **160** has a similar taper as the water inlet tube, and the tapered end engages tapered grommet seal **171**. Tube **310**, which connects a vacuum pump to the processor, may require a special vacuum connector, but is depicted in Fig. 7 between **310** and **161**. Because the outlet tube and vacuum tube don't extend into boiler-condenser unit **100**, they may not need the structure in Fig. 7. Note Fig. 7 doesn't show the bladder arrangement of Fig. 5, which could attach to the freshwater and waste outputs.

[0145] Proper maintenance may call for removing the entire boiler-condenser unit **100** and replacing it with a new unit. Arranging the processor's parts to make replacing only boiler-condenser unit shell **110** and possibly wipers **174** and **176** may make maintenance difficult. Handling could damage the thin shell and other parts like the wipers, which could make a unit less efficient or even inoperative. Trained technicians could replace the boiler-condenser unit and lower support insert and could test systems with replaced parts to assure that the parts all function within tolerances. The entire boiler-condenser system **100** also could be removed with outer support **284** as one assembled unit, provided there are quick disconnect attachments to the inlet feed water **140** and freshwater output **179**.

[0146] Boiler-condenser unit **100** and blower-compressor unit **200** are in the same housing **280** in Fig. 1. Mounting a boiler-condenser unit with a rotating shell and blower-compressor unit in separate housings may be an alternative, but conduits or connecting passages are necessary to convey vapor from the shell's boiler surface in one housing to the blower in the other housing. At least another conduit is necessary to transport the higher-pressure vapor in the other housing back to the shell's condenser surface in the first housing. A system with those conduits likely would need more energy to overcome temperature and pressure losses. It would be less efficient and produce less potable water per unit of energy input. Having two housings under vacuum also requires more seals, which are sources of potential vacuum leaks. Protecting against such leaks also requires a more robust construction, which increases the system's cost.

[0147] **Multi-shell Constructions:** Applicants' '951 patent has multiple, concentric boiler-condenser shells, which also can increase system throughput in a given-size processor. Figure 8 of this application shows components of one version of a multi-shell device. Some components of the multi-shell, boiler-condenser construction also may be used in the Fig. 1, single-shell design here.

[0148] For the multi-shell design, boiler-condenser assembly **600** includes housing **601** (Fig. 8) in a vacuum housing (not shown). Housing **601** in Fig. 8 holds four, concentric, spaced-apart boiler-condenser shells **610**, **620**, **630** and **640**, but applicants' processor could have more or fewer shells. The shells are thin and are of a high, heat-conductive metal like aluminum.

[0149] Only the first and second shells **610** and **620** from the left are visible in Fig. 9, an enlarged part of Fig. 8. The left-side surface of each boiler-condenser shell (Fig. 9) is the inner or boiler side because it faces the shells' axis of rotation **602** and is the surface on which contaminated water boils at near vacuum. The outer, right-side surface of each shell is the shell's outer or condenser side.

[0150] Applicants' Fig. 11 multi-shell water purification system differs from the system in Fig. 8, but many parts are similar. Reference to other drawings may help one appreciate features in Fig. 8. Housing **601** is not closed. Its dome **604** may have openings **606** and **736** (Fig. 8). The housing rotates about axis **602** at the center of stationary center post **650** and the center of cylindrical shells **610**, **620**, **630** and **640**. Similar motor and gear arrangements driving the shell in Fig. 1 show parts that rotate housing **601**, but Fig. 8 does not show the motor or gears. The dome includes depression **608**, which receives angled driver **609**. The driver may have structure securing it in the depression to provide a more positive drive to the housing.

[0151] Center post **650** is fixed to a base (not shown in Figs. 8 or 9) of the device or to the base of the vacuum housing. When the specification compares components positioned relative to the center post, it refers to components mounted closer to the center post as more proximal than components mounted distally, which are farther from the center post. Two, three, four or more stationary struts (Figs. 8 and 9 show only two struts **654** and **658**), extend outward from the center post and are fixed to the center post. Preferably, they are evenly spaced about the center post (e.g., four struts spaced 90° apart). They may be plastic or metal. The struts in Figs. 8 and 9 may have openings **656** and **660** through which vapor or liquid can pass, but the struts' spacing also provides openings, which may lessen or do away with needing separate openings in the struts.

[0152] For simplicity and where appropriate, this description is limited to one boiler-condenser shell, here shell **620** (second to the right of center post **650** in Fig. 8 and left-most in Fig. 9). Except for their diameters, the other boiler-condenser shells and their associated components are like shell **620** and its associated parts. They function similarly but their different surface areas and g-forces process different volumes of contaminated water. The components associated with outside shell **640** may differ from the components next to the other shells because shell **640** is on the outside.

[0153] Annular framework assembly **710** includes lower ring **712**, angled brace **716** and upper ring **718**. The lower ring's free end **714** attaches to shell **620** (Fig. 8), and the upper ring's free end **718** attaches to adjacent shell **630** (visible in Fig. 8). The framework assemblies may be plastic or metal. Boiler chamber **628** includes the inside space between the shell, e.g., shell **630** and its framework assembly **710**. The other three boiler chambers are between a shell and its framework assembly to the shell's left. The four boiler chambers in Fig. 8 are in parallel with each other so a direct flow path connection exists between the four boiler chambers, and they share the same near-vacuum boiler pressure.

[0154] The annular framework assemblies also form the condenser chambers. Framework assembly **711** (the assembly to the outside (right) of assembly **710** in Figs. 8 and 9) forms the condensing side **730** of condensing chamber **732**. As with the boiler chambers, the condenser chambers are in parallel with each other, so a connection exists between them, and they share the same condenser pressure. The pressure in the boiler chambers and the condenser chambers differ, however, by an amount  $\Delta P_{BC}$  produced by the blower compressor.

[0155] The annular framework assemblies such as assemblies **710** and **711** (Fig. 8) are rigid tubular-like fixtures. Supports **626** and **627**, which hold the wipers, are rigid and stationary. They neither impede the vapor's flow-path exiting boiler chambers **628** nor impede the entering vapor

flow-path to the condenser chambers **732**. These vapor paths are in free space entirely around housing **601**.

[0156] The thin, metallic boiler-condenser shells **610**, **620**, **630** and **640** and non-metallic, framework assemblies such as **710** (Fig. 8) create a stiff boiler-condenser structure even without radial support struts. Having radial braces to position shells **610**, **620**, **630** and **640** relative to each other is possible, but depending on their location, braces could interfere with stationary wiper blades **624** and **750**. Because the wipers are important, the design in Figs. 8 and 9 relies on the framework assemblies instead of radial braces for rigidity.

[0157] Contaminated water from a source such as source **14** in Fig. 1 enters the boiler-condenser unit through feed input **670** (Figs. 8 and 9). From there, the water flows into manifold **672** and branches into four tubes **674**, **676**, **678** and **680**. Other sets of tubes could be spaced around the shells. Arrows **671** show the inlet water path. Each tube has one or more nozzles. For simplicity, applicants limit their description to nozzle **690** at the end of tube **676** and its associated boiler-condenser shell **620**. The other boiler-condenser shells and their associated nozzles operate similarly. The pressure head of water entering the feed input must be enough for the nozzles to eject water properly toward the inner wall. This should not be a problem because the boiler chambers are at low-pressure (near vacuum), while the inlet feed **670** is at atmospheric pressure (and throttled by a needle valve). Tubes **674**, **676**, **678** and **680** could connect directly to feed input **670** instead of inlet water first flowing into manifold **672**.

[0158] Before processing contaminated water, the vacuum housing is evacuated. As with the single shell of Figs. 1 and 2, injecting steam at atmospheric pressure into multi-shell housing **600** before starting evacuation exchanges non-condensable air with steam so only water vapor remains when the system operates. Next, a vacuum pump (not shown in Figs. 8 and 9) evacuates the steam and any remaining air from the vacuum housing. The initial evacuation normally occurs while the boiler-condenser assembly remains stationary and the system is not operating.

[0159] Liquid-vapor seals between the boiler and condenser are like seal **190** in Figs. 1, 2 and 4 and are described in more detail below. The seals, which fill automatically when the inlet water is flowing, depend on rotation of boiler-condenser assembly **601** for sealing. Air and vapor inside the boiler-condenser assembly pass in both directions through the seals during the initial evacuation when the boiler-condenser assembly is stationary and the inlet feed-water is not flowing. A direct, uniform-pressure connection between the boiler chambers and the condenser chambers also exists during initial evacuation.

[0160] The vacuum pump is turned off after initial evacuation to maintain a constant vapor-pressure condition, and to prevent it from being a power drain. After evacuation, vapor pressure equilibrium is established. The vacuum pump may run intermittently when the internal processor pressure exceeds operational conditions based on the inlet vapor saturation temperature or unacceptable buildup of trapped non-condensable gases (O<sub>2</sub>, N<sub>2</sub>, Ar, CO<sub>2</sub>, etc.). The system also may require occasional, later evacuations to overcome any small vacuum leaks.

[0161] The normal startup procedure begins with:

- 1) Starting the vacuum pump to evacuate the processor below atmospheric conditions.
- 2) Closing the valve between vacuum pump and processor followed by vacuum pump shutdown.
- 3) Starting blower rotation and raising to operational speed
- 4) Starting boiler-condenser assembly rotation up to operational speed (may occur when blower starts)
- 5) Turning on output fresh and waste pumps (described below) and
- 6) Opening contaminated water inlet to desired flow conditions.

[0162] After the inlet feed water flows into the boiler-condenser assembly, water flows through tube **676** and is distributed to feed each boiler shell including through nozzle **690** (Figs. 8 and 9). The water reaches inner or boiler surface **622** of shell **620** and the other shells' inner surfaces. Centrifugal force produced by rotation of boiler-condenser housing **601** and its shells causes the water to form thin films on the boiler surfaces. In addition, gravity causes the water to flow downward from the nozzles at the top of each shell. Spacing nozzles vertically along the tube may provide water along more of the boiler surface more quickly and evenly.

[0163] Water begins near-vacuum boiling, and the resultant vapor travels to the blower. Figs. 8 and 9 do not show the blower, but it may be like blower 200 in Fig. 1, blower **1210** in Fig. 10 and other blowers in other figures. The descriptions for other figures discuss the vapor's paths to the blowers.

[0164] Optional wipers like wiper **624** cooperate with the centrifugal force to help spread the contaminated water along the shells' inner surfaces, including shell **620**'s boiler surface **622** (Figs. 8 and 9). The boiler wiper attaches to the cylindrical boiler wiper support **626**, which extends upward from strut **658**. Like wipers **174** and **176** in Figs. 1 and 2, the boiler wipers **624** in Figs. 8 and 9 are formed of low-friction material like Teflon® or other materials with a Teflon or other low-friction material coating to decrease friction.

[0165] External condenser wipers may contact the condenser-outside surfaces. Condenser wiper **632** (Figs. 8) mounts on cylindrical support **627**, which connect to strut **654**. Other wipers (not numbered) also mount on similar supports. The condenser wipers contact the condenser surfaces like surface **623** of each shell and remove condensed water that centrifugal force has not yet removed from the shell's outside surface. Leaving a relatively clean condenser surface allows vapor to contact more of the colder, metal surface instead of encountering earlier deposited condensate.

[0166] The connection of cylindrical boiler wiper support **626** to strut **658**, the connection of cylindrical condenser wiper support **627** to strut **654** and the connection of the struts to center post **650** creates rigid assemblies. The parts in Figs. 17, 18 and 19, which are discussed below, may differ from the parts in Figs. 8 and 9, but the drawings show how the assemblies would be rigid.

[0167] Fig. 8 shows only one boiler wiper and one condenser wiper for each shell, and each wiper extends almost the entire height of its shell. The system could have many wipers on spaced-apart supports. Each single wiper also could be divided into separate wipers. With proper wiper positioning, at least one wiper contacts the shell's entire inside surface as the shell rotates. Each wiper also could be angled to feed water to the next wiper. The wipers also may overlap. A single curved or spiraled wiper along each shell's surface could also be used.

[0168] **Operation:** After the processor is evacuated, contaminated water flows from a source through tube **676** and out nozzle **690**. The water is distributed to feed each boiler shell including boiler surface **622** of boiler-condenser shell **620** (Figs. 8 and 9). The surface is under near vacuum at about 0.5 psia. The thin film of contaminated water on the boiler-condenser's inside wall boils at the low pressure. Framework assemblies such as assembly **710** direct the vapor from the boiling chambers (e.g., chamber **628**) toward arrows **708** (near the bottom of Fig. 8). The vapor then follows the path of arrow **709** upward along the outside of support insert **740**. The support insert is spaced from the vacuum chamber housing's inside wall (not shown).

[0169] Vapor from the boiler-inner side **622** of shell **620** reaches the blower or compressor unit (not shown in Fig. 8) after traveling upward along the outside of support insert **740**. The blower compresses the vapor. The blower, which mounts above the Fig. 8 components, may be like blower **200** in Fig. 1. The blower used with the multiple-shell version of Fig. 8 (and others) may have a capacity larger than blower **200** (Fig. 1), which only supplies compressed vapor to a single shell. Structure that causes shaft **607**, angled driver **609** and housing **601** to rotate may connect operably to the structure that rotates the blower.

[0170] Following compression in the blower, the vapor has a slightly increased pressure  $\Delta p$ , which increases the vapor's temperature  $\Delta T$ . Typical pressure rises  $\Delta p$  may be 1 to 4 inches ( $\text{H}_2\text{O}$ ) ( $\approx 0.04$  psia to 0.15 psia (0.25 kPa to 1.0 kPa)) with corresponding temperature rises  $\Delta T$  of about  $2^\circ\text{F}$  to  $9^\circ\text{F}$  ( $\approx 1^\circ\text{C}$  to  $5^\circ\text{C}$ ) under normal operating conditions. Interaction of the blower components acting on the vapor molecules also raises the vapor's temperature slightly.

[0171] The vapor from the blower at its elevated temperature and pressure passes through openings **606** in the dome and through openings, e.g., **656**, or spaces between struts **654**.

[0172] The condenser surface is colder than the vapor because the vapor's temperature rises  $2^\circ\text{F}$  to  $9^\circ\text{F}$  as its pressure increases through the blower. The condenser surface also is colder than the vapor due to the contaminated water's phase change from liquid to vapor. The energy from the phase change transfers heat from the shell's outside surface to the contaminated water, which causes boiling and decreases each shell's temperature (except for the continuous replenishing of the constant temperature inlet feed-water).

[0173] Centrifugal force caused by shell rotation may expel now-liquid water from the condenser surface **623** of shell **620** (Fig. 8), but surface tension may hold some or most condensate on the condenser surface. Vapor cannot contact the condenser surface directly where condensate remains, but having the vapor contact the condenser surface is important for vapor to transfer its heat of condensation to the condenser shell enough to vaporize the boiler side. Removing condensate quickly improves the condensation's heat transfer coefficient and overall thermodynamic efficiency. Therefore, applicants use wipers **632** mounted on condenser wiper bracket **627** to throw condensate off the condenser surface.

[0174] Continuous thinning of boiling fluid from the rotational induced g-forces on the boiling fluid as enhanced by the wiper blades probably boosts the boiling heat transfer coefficient by an order of magnitude or more over conventional boiling distillation. Likewise, the centrifugal force throwing off condensate as enhanced by condenser wipers helps create freshly exposed metal surfaces for condensation. That also should boost the condenser heat-transfer coefficient by an order of magnitude or more. Applicants' system should have heat transfer values between 2,000 to 6,000  $\frac{\text{Btu}}{\text{ft}^2 \cdot \text{hr} \cdot ^\circ\text{F}}$  ( $\approx 1.1 \times 10^4$  to  $3.4 \times 10^4 \text{ W/m}^2\text{C}$ ) versus values one-tenth or less for conventional boiler-condenser systems.

[0175] Condensate thrown off condenser surface **623** by centrifugal force or by external wiper **632** contacts framework assembly **711**, which is to the right or outside, condenser surface **623** in Fig. 8. Because the framework assembly rotates with housing **601** and many internal parts including the shell, the framework assemblies urge the condensate upward and over the framework

assemblies. See arrows **717** in Figs. 8 and 9. The water then is thrown through openings **736** in housing **601** (right side of Fig. 8).

[0176] Changing the phase of vapor into liquid water on the condenser surface like surface **623** transfers the thermal energy by the heat of condensation from the condenser surface, which transfers heat to the shells like shell **620**. Condensation recovers most of the heat energy that caused water to boil from boiling surface **622**. The blower (not shown in Fig. 8) produces this heat energy in vapor compression energy and some vapor temperature rise. During condensation, this energy is transferred to the shell and acts as the only energy source to cause boiling on the shells' inside surface. The vapor temperature increase due to the blower causes the heat necessary to drive the boiling on boiling surface **622**. The system recovers energy used to boil the contaminated water minus entropy and thermodynamic inefficiency losses of the compressor and the small excess heat energy ( $\Delta T$ ) required to drive the process.

[0177] At least some contaminated water that reaches boiler surfaces, like surface **622** (Fig. 8), remains liquid and doesn't boil. It becomes wastewater with contaminants from the input contaminated water. The wastewater flows downward along the boiling wall surface until it reaches the bottom of the shell **620**. Centrifugal force on exit and gravity direct the wastewater to a common waste exit (not shown in Fig. 8 but could be like the waste exit in Fig. 1).

[0178] **Seals:** Seals must hold the pressure differentials between the compressed vapor from the blower in the condensing chambers like chamber **732** and the pressure in the boiling chambers like chamber **628**. The sealing requirements between each fixed boiler and condenser chamber wall are low pressure, so the sealing requirements during fabrication and assembly for each fixed chamber are not stringent. Under normal operation, the pressure differential  $\Delta p$  may be about 0.04 psia to 0.15 psia. Two rotary seals, which use principles like seal **190** in Fig. 4 uses, hold that pressure differential.

[0179] First seal **760** (upper-left portion of Fig. 8) includes disk **762** fixed to center post **650**. The disk extends into annular channel member **771** (U-shaped in cross-section). The annular channel member attaches near the top of shell **610** and rotates with the shell. It holds fluid like contaminated water **770**. Channels through center post **650** and a tube from the channel to the annular channel member of the seal (not shown) may provide the contaminated water for the seals. The pressure differential ( $\Delta p$ ) between vapor boiled from boiler surfaces like surface **622** and the compressed vapor from the blower exerts different pressure forces on the fluid in the rotary seal. The pressure difference creates a differential height column in the rotary seal's channel member **771**. In Fig. 8, the pressure on fluid **770** above disk **762** exceeds the pressure below the disk due

to pressure forces from the blower. The pressure difference displaces the column of fluid **770**, but the channel member rotates during system operation. Centrifugal force acting on the fluid above and below disk **762** keeps enough fluid above and below the disk to prevent vapor flow through the seal.

[0180] The other rotary seal, seal **784**, operates on similar principles. Disk **786** extends outward from strut **658** and into annular channel member **787** at the bottom of housing **601** (right side of Fig. 8). Liquid **794** in the annular channel member above disk is subjected to lower-pressure vapor from the boiler side of the shells like boiler side **622** of shell **620**. Higher-pressure vapor from the blower acts on the liquid below the disk so the fluid assumes a position like the position of fluid **794** in Fig. 8. Housing rotation produces centrifugal force, which urges the liquid above and below disk **786** to hold the liquid in the channel member. The liquid seals higher-pressure vapor from the lower-pressure vapor. The effective radius of seal **784** is greater than the radius of seal **760** because seal **784** is farther from center post **650** so g-forces on the liquid in seal **784** are greater than the g-forces on the liquid in seal **760**.

[0181] A trickle of water from inlet **670** also feeds the two liquid-vapor seals **760** and **784** simultaneously. Channels through center post **650** and tubes from the channel to the annular channel member of each seal (not shown) may provide the contaminated water for the seals. The tubes can be controlled to allow water flow only when the seals need the water. There are other ways to fill the seals' channels from a separately controlled filler tube. Other options include pre-filling the annular channels with other fluids or grease, which remains in the seals. Using the trickle of water arrangement, when the channels are full, boiler-condenser assembly rotation automatically activates them. Any water exceeding the two seals' capacity overflows into the boiler chamber.

[0182] The vapor pressure differential that the seal can block depends on the fluid density ( $\rho$ ), the fluid height differential ( $\Delta r$ ) on opposite sides of stationary disks **762** or **786** and the g-force applied to the fluid in the channel. The g-force is a function of the rotational speed ( $\omega$ ) and the radius from the channel to axis of rotation **602**. Proper design of annular channel member **771** provides flexibility over the allowable pressure differences ( $\Delta p$ ) and operating rotational speeds ( $\omega$ ) required to achieve a rotating vapor seal.

[0183] **Support for the Boiler-Condenser Housing:** Housing **601** and its internal boiler-condenser assemblies rotate about axis of rotation **602** of center post **650**. See Fig. 8. Bearings **810**, which mount on angled support **812** on support insert **740**, allow rotation of housing **601**. The angled supports may be at a 45° orientation. Three such bearings and supports spaced 120° apart

may be used. Bearings **810** interact with bearings **820**, which mount on angled support ring **822**. The support ring also may slant at 45° to be complementary to angled support **812**. The bearings support the housing in the Fig. 8 position and permit its rotation.

[0184] Housing **601** and its internal boiler-condenser assembly (including the boiler-condenser shell, bearings, seals, wipers, inlet feeds, and central axis) may be removable as a unit from its Fig. 8 operating orientation for replacement or maintenance.

[0185] The system also could use a housing that accepts a one, two or more boiler-condenser shells and components. Those variations could provide differing amounts of potable water throughputs. The compressor chosen for different numbers of shells could operate over a range of operating conditions, i.e., speeds of rotation to accommodate the increased vapor flow rates.

[0186] **Multiple-Shell Device Shown in Figures 10 through 28:** Figures 10 and 11 and details in Figs. 12–28 show a multi-shell boiler-condenser design joined with the blower and its associated structure.

[0187] **Vacuum Housing:** Boiler-condenser unit **1000** mounts in vacuum housing **1002**. The vacuum housing may have a top or upper part **1003** and bottom or lower part **1004** (Fig. 11), which attach and seal together. Threaded attachment **1208** may be used, and various sealing parts like O-rings **1006** may seat at the attachment. Users can gain access to the boiler-condenser assembly by separating the housing's top and bottom. The vacuum housing may have a diameter of about 1 foot ( $\approx 30$  cm), and applicants' device of that size should produce 40 gal. ( $\approx 150$  liters) daily. Other sizes are possible.

[0188] The upper part **1003** and lower part **1004** of vacuum housing **1002** are of equivalent size in Fig. 10, but one could be taller than the other. The vacuum housing may be plastic, metal or glass, but the material at its chosen thickness should be strong enough to resist collapsing from outside, atmospheric pressure when the inside the housing is at its working pressure of about 0.5 psia. Plastic's lower cost and lighter weight may make it preferable. The housing could be glass or transparent plastic to let users see inside the housing. The device could have a sealable opening (not shown) through the vacuum housing to allow cabling for system instrumentation especially for prototypes. Wireless monitoring also is acceptable.

[0189] **Blower-Compressor Unit:** Blower unit **1200** includes a multi-stage blower **1210** mounted in the upper portion of blowing housing **1212**. See Fig. 10. Motor **1214** (shown schematically in Fig. 10) mounts outside vacuum housing **1002** where it can attach to an outside source of electric power (not shown). Small electric motors like motor **1214** are very efficient and waste little power. Motor **1214** mounts in the center of the upper portion of blowing housing

**1212** above dome **1220**. See Figs. 10 and 11. The motor's connection to other parts of the system affects its location choice. Compare the center location in Fig. 10 with the position of motor **274** in Fig. 1. The motor uses magnetic couplers to rotate parts inside the vacuum housing. It rotates upper magnetic coupler **1216** in cutout **1222**, which rotates lower magnetic coupler **1224**.

[0190] The motor could mount inside vacuum housing **1002**. Instead of the using a transmission like that described in these paragraphs, the device could use separate, small electric motors adjacent the parts that move or rotate. The motors can be protected from internal conditions, but separate motors mounted inside the housing still need connections to electricity. Using batteries may be feasible subject to the time and expensing to change them. Rechargeable batteries using wireless charging could avoid having wires through the vacuum housing, but wireless-charged rechargeable batteries are costly.

[0191] Lower magnetic coupler **1224** rotates shaft **1230** (Fig. 10), which rotates gear **1232**. The gears drive associated gears with belts or chains. One also can use pulleys and associated drive belts, which transfer rotation by friction, gear-to-gear transmission and other mechanisms that transfer rotation among parts. Gear **1232** rotates gear **1234** through a drive belt (not visible in Fig. 10). The latter gear connects to and rotates shaft **1236**, which rotates gear **1238**. Gear **1238** rotates gear **1242** through drive belt **1240**. Gear **1242** is fixed to blower drive shaft **1246**, which rotates the parts of blower **1210**. Bearings like bearing **1250**, **1252**, **1254** and **1256** support shafts **1230** and **1246** for rotation. Other bearings may support other rotating parts. Flanges **1260** and **1261** (Fig. 10) act as balance wheel zones and support drive shaft **1246** and hold the blower parts in place.

[0192] The gears or pulleys are sized to act as a transmission for rotating the blower at speeds that may differ from the speed of motor **1214**. Choosing the gears' diameters affects their mechanical advantage and the blower's speed. Gears **1232**, **1234**, **1238** and **1242**, which are not necessarily to scale in Fig. 10, have diameters causing blower **1210** to rotate much faster than shell **1010** rotates, e.g., 8,000 rpm for the blower versus 250 rpm for the shell. Choosing the gears' diameters accommodates the speed change from the blower's velocity to the boiler-condenser housing velocity. Using different diameter gears allows modifications to the components' rotational velocities to account for the blower's specifications, the shells' diameters, the processing parameters and other factors.

[0193] Rotation of blower shaft **1246** (Fig. 10) also rotates gear **1262**, which, through a connecting belt (not shown), rotates gear **1263** on shaft **1264**. Rotation of shaft **1264** rotates gear **1266** to rotate gear **1268**. That gear attaches to and rotates intermediate shaft **1270** (Fig. 11). Rotation of

shaft **1270** and gear **1268** rotates boiler-condenser's dome **1220** and the rest of boiler-condenser housing **1008**. Bearing **1078** (Fig. 11) limits rotating friction.

[0194] **Boiler-Condenser Unit:** Boiler-condenser assembly **1000** has three major subassemblies that nest together. See Fig. 17. Nozzle-wiper support assembly **1015** (Figs. 12 and 17) is at the lower part of Fig. 17. That assembly nests within shell subassembly **1119**. Condenser-wiper sub-assembly **1154** nests in the shell subassembly. Dome **1220** is at the top of the boiler-condenser assembly and lower bearing support **1063** is near the bottom.

[0195] Boiler-condenser assembly **1000** mounts in boiler-condenser housing **1008**. See Figs. 10, 11 and others. The boiler-condenser assembly holds one or more concentric, spaced-apart boiler-condenser shells. The boiler-condenser shells may be like those in Fig. 8, but structure with the shells in Figs. 1–8 may differ. Figs. 10, 11, 12, 13, 15, 17 and 18 show four shells **1010**, **1020**, **1030** and **1040**, but the device could have more or fewer shells subject to the diameter of boiler-condenser housing **1008**, the shells' spacing and the size of vacuum housing **1002**. The shells are thin, high, heat-conductive metal like aluminum, but other materials having high thermal conductivity may be acceptable. Because the shells are so thin in cross-section compared to other components' thickness, they appear as lines in the drawings including Figs. 10 and 11, but see two shells **1020** and **1030**, which Fig. 14 enlarges.

[0196] The rotating elements of boiler-condenser assembly **1000** include shells **1010**, **1020**, **1030** and **1040** and framework assemblies, which support the shells. Two such as framework assemblies are assemblies **1110** and **1111**. The shells and framework assemblies revolve about vertical axis **1052** through center post **1050**. Wiper cylinders **1016**, **1026**, **1036** and **1046** (Fig. 19) are stationary. They support tubes **1090**, **1091**, **1092** and **1093** for directing contaminated water to the shells' boiling surfaces. The wiper cylinders for the boiler surfaces also support optional boiler wipers. Condenser wiper cylinders **1156**, **1157**, **1158** and **1159** (Fig. 19), which support condenser wipers, also are stationary. See also Figs. 12 and 13. These stationary parts are fixed relative to the center post or to parts fixed to the center post.

[0197] Upper nut **1079** (Fig. 11) pushes down on dome **1220**, which secures bearing **1078** between the outside of the nut and dome's upward projection **1053**. The nut also pushes down on upper struts **1054** (Figs. 11, 12 and 20) to secure the struts and condenser wiper assembly to the center post. Intermediate nut **1055** is threaded to center post **1050** and pushes down on bushings **1194** and **1195** (Fig. 12). The latter engages struts **1058** of nozzle-wiper support assembly **1015** (Figs. 12 and 17). The upper and intermediate nuts and their engagement with the condenser wiper assembly and nozzle-wiper support assembly make boiler-condenser unit **1000** rigid.

[0198] **The Shells' Boiling Surfaces:** In figures such as Fig. 13, which show only the boiler-condenser assembly's right side (in cross-section), the left-side surface of each boiler-condenser shell faces the axis of rotation **1052** at the center of stationary center post **1050** and is the shell's inner or boiler side. For figures that show at least part of the shells to the left of the axis of rotation, the right side of each visible shell is the inner or boiler side. In Fig. 14, surface **1022** is shell **1020**'s inner, boiler surface. The other shells have corresponding inner boiler surfaces. The right side or outside surface **1033** of shell **1020** (Fig. 14) is the shell's outer or condenser side. The other shells have corresponding condenser sides, which may not be numbered.

[0199] Boiler-condenser housing **1008** for mounting boiler-condenser assembly **1000** includes cylindrical sidewall **1062**, dome **1220** (Figs. 10, 11, 13 and 15) and bearing support **1063**. The bearing support acts as a base (Figs. 10, 11, 13 and 24). The cylindrical sidewall and bearing support are threaded together at threads **1084** or are otherwise attached. See also Figs. 16 and 24. The dome curves downward, and its threads engage sidewall **1062**. See threads **1086** in Fig. 12. the cylindrical sidewall and the dome or bearing support may join using other connections. The shapes of the dome and bearing support also may vary.

[0200] Boiler-condenser housing **1008** is not sealed. Openings **1061** in dome **1220** (Fig. 12) may occupy much or most of the dome's area. The openings allow vapor from blower unit **1200** to enter boiler-condenser housing **1008**, and the large opening limit any pressure drop. Bearing support **1063** also is open near its center **1095** (Fig. 24). The flows of liquids and vapors are discussed below.

[0201] Driver **1074** mounts at the bottom of shaft **1270** (Figs. 10 and 11). The driver rotates boiler-condenser housing **1008** with the housing's cylindrical shells **1010**, **1020**, **1030** and **1040** about axis **1052**. The driver engages depression **1064** in fitting **1053** of dome **1220** (Figs. 11 and 12). The latter shows a threaded connection. Spring **1098** may urge driver **1074** into fitting **1053**. Instead of a threaded connection, the driver and depression may have other structure to engage each other. The driver's structure engages indentions or an arrangement associated with the fitting. Noncircular shapes, splines and grooves or any other attachment also may provide positive drive for the dome and housing to prevent the fitting and dome rotating about shaft **1270**.

[0202] Fitting **1053** at the top of center post **1050** supports dome **1220** for rotation about bearing **1078** (Figs. 11 and 12) around the center post. The center post extends through cylindrical extension **1007** of the bottom **1009** of vacuum housing **1002** (Figs. 10, 11 and 15). Nut **1011** threaded to the bottom of the center post secures the center post to the vacuum housing. Bearing support

**1063** acts as a base for the rotating boiler-condenser unit housing. Bearings **1087** (Figs. 11, 15 and 16) facilitate rotation of the bearing support about the stationary center post.

[0203] Bearing support **1063** (Figs. 15 and 24) has an L-shaped (in cross-section) central hub **1109**, with a vertical portion **1108** and horizontal portion **1109**. The vertical portion is against bearing **1087**, which also mounts against the outside of center post **1050**. The center post has a smaller diameter region extending from shoulder **1141** upward (Fig. 16). The central hub's horizontal portion supports the bearing vertically. Dome **1220** at the top of boiler-condenser unit **1000** and bearing support **1063** at the bottom of the boiler-condenser unit supports the boiler-condenser unit for rotation about center post **1050**. See Fig. 24 and further discussion below about the bearing support. This construction allows dome **1220**, bearing support **1063** and cylindrical sidewall **1062** to rotate about the stationary center post as shaft **1070** rotates.

[0204] Fixed upper and lower sets of struts **1054** and **1058** (Figs. 10, 11, 12 and 13) extend outward from the center post. See Figs. 15, 16, 18 and 19, which do not show all struts. Each set of struts may include two, three, four or more struts (See Figs. 17, 18 and 19).

[0205] **Flow of Contaminated Water into System:** Contaminated water from a source like source **14** in Fig. 1 passes through the feed input **1070** in center post **1050** (Figs. 11, 15 and 16) and enters the boiler-condenser assembly through one or more ducts **1071** near the top of the feed input. The feed input may have a fitting **1069** (Figs. 11 and 15) for attaching to the water source. The pressure head from the source of contaminated water raises the water to the ducts. Each duct extends radially from feed input **1070** through outlet **1072** through center post **1050**. As boiler-condenser housing **1008** rotates, centrifugal force directs the water from the ducts and outlets into a manifold below at least one lower struts. Four short tubes **1080**, **1081**, **1082** and **1083** (Figs. 11, 13 and 15) extend into the water in the manifolds. Each short tube connects to a respective elongated tube **1090**, **1091**, **1092** and **1093**. The rotation-created pressure head on the water in the manifold generates a pressure head in the four tubes causing water to flow upward into the elongated tubes (Figs. 10, 11, 13 and 15).

[0206] Manifold **1073** mounts below strut **1058** in the drawings, but the other struts also could have manifolds. Applicants could use a single manifold with one set of radially aligned tubes for each shell because centrifugal force and wipers spreads the incoming water into a thin film around each shell. Four manifolds spaced 90° apart, one below each of the four lower struts with corresponding tubes and four ducts **1071**, distribute the contaminated water more evenly.

[0207] Elongated tubes **1090**, **1091**, **1092** and **1093** may extend through bulges such as bulge **1094** extending outward from cylindrical supports **1016**, **1026**, **1036** and **1046** (Figs. 18 and 19).

The Fig. 17 exploded view shows the relationship of nozzle – wiper support assembly **1015** with other components. The cylindrical supports combined with the struts such as strut **1058** to form rigid and stationary nozzle support subassembly **1015**. One molded-plastic piece could form the support subassembly including the cylindrical supports and the struts.

[0208] To eliminate the need for the manifold, the four short tubes may connect directly to outlets **1072**. If so, centrifugal force still creates a pressure head to direct the water through short tubes **1080**, **1081**, **1082** and **1083**. The short tubes could be separate elements that connect to elongated tubes **1090**, **1091**, **1092** and **1093** (best seen in Figs. 13 and 18), or they could be integral parts of each elongated tube.

[0209] Pressure caused by centrifugal force on the contaminated water in manifold **1073**, short tubes **1080**, **1081**, **1082** and **1083** and elongated tubes **1090**, **1091**, **1092** and **1093** forces the water out the top of the elongated tubes. The water hits the rotating shell's inner surface outside the tube, and centrifugal force grabs the water on the shell's inside boiling surface. Angling the tops of the elongated tubes toward the shells direct the water toward the shells. One or more nozzles along the length of each elongated tube also could spray water toward its shell.

[0210] Fig. 19 shows other sets of tubes spaced every 90° around cylindrical supports **1016**, **1026**, **1036** and **1046**. More or fewer tubes could be used. If the outside of bulge **1094** extends outward far enough, it may act as a wiper, but it may be too hard and generates friction by exerting too much force on the shells. The bulges in Fig. 19 have elongated slots like slot **1095**, which can grip a flexible wiper. Fig. 19 does not show the flexible wipers for the shells' boiling surface, but they may be like wiper **1150** that act on the condenser surface (Fig. 20). The wipers may be Teflon,<sup>®</sup> other low-friction material or another material coated with Teflon or other low-friction materials to reduce friction between the wiper and its shell. The wipers may be curved or straight and may extend almost the entire length of the shell's inner-boiler surface. The system could use multiple wipers for each boiler or condenser surface. See Fig. 19. Angling or overlapping the wipers also may be advantageous. A second slot such as slot **1097** allows mounting a flexible wiper facing in the opposite direction, which allows the wiper to affect the contaminated water on the boiler surface if the boiler-condenser unit rotates in the opposite direction.

[0211] **Annular Framework Assemblies.** The system also includes annular framework assemblies. They (1) support components associated with cylindrical shells **1010**, **1020**, **1030** and **1040**, (2) direct vapor from the boiling shell surfaces, (3) direct vapor to the condenser surfaces, (4) maintain the pressure differential between opposite sides of the shells and (5) rigidify the rotating components. The framework assemblies in shell subassembly **1119** (Figs. 17 and 25) are like the framework assemblies in Fig. 8. Each shell has an associated framework assembly

rotating with the shells (best seen in Figs. 13, 14 and 25), but only assemblies on opposite sides of shells **1020** and **1030** are described here.

[0212] Annular framework assembly **1111** is associated with shells **1020** and **1030**. It includes lower ring **1112**, angled brace **1111** and upper ring **1118**. The lower ring attaches to shell **1020**, and the upper ring attaches to adjacent shell **1030** (Figs. 13, 14 and 25). Shell **1040** depends from the top of framework assembly **1110**. The arrangement leaves open the bottom of the boiler chamber, the space between a shell's boiler surface and the framework assembly closest to that boiler surface. Boiled vapor can flow through that open space. The arrangement also allows vapor compressed from compressor/blower **1200** to reach the opposite, condenser surface of the shell while preventing compressed vapor from reaching the shell's boiling surface. The framework assemblies also keep pressures on opposite sides of the shells at the lower boiler pressure and the higher pressure from the compressor.

[0213] No framework assembly is outside shell **1040**. Instead, rim **1088** of cylindrical wall **1120** projects downward and inward from below rim **1088**. See Fig. 25. The bottom of shell **1040** attaches to that downward projection. The framework assemblies and the shells form a unitary unit **1119** (Fig. and 25). Rotation of dome **1067**, bearing support **1063** (discussed below) and cylindrical wall **1120** rotate framework assemblies and their associated shells about axis **1052** through stationary center post **1050**.

[0214] The space facing toward axis of rotation **1052** between a boiling surface and its adjacent framework assembly, e.g., surface **1032** of shell **1030** and framework assembly **1111**, is a boiling chamber (e.g., chamber **1128**, best viewed in Fig. 14). Vapor there from the boiled contaminated water first moves away from the shell's boiling surface. Though centrifugal force holds contaminated water along the boiling surfaces, the force doesn't affect the vapor.

[0215] **Shells' Boiler Surfaces Generating Vapor:** The system is under near-vacuum pressure ( $\approx 0.5$  psia) during operation. Contaminated water exiting tube **1096** reaches inner or boiler surface **1032** of shell **1030** (best seen in Fig. 14). Centrifugal force caused by rotation of housing **1000** and its shells causes water to form a thin film on each boiling surface. Gravity also causes water to flow downward from shell's top **1032**. Optional wipers such as wiper **1024** (Fig. 14) cooperate with centrifugal force and gravity to spread contaminated water into the thin film along inner, boiler surface **1032** of shell **1030**. Brace **1057** (Fig. 14) on the strut like strut **1058** and other braces on other struts may secure boiler cylinders like cylinder **1016** (Fig. 19). The wipers also may attach to the elongated tubes.

[0216] At near-vacuum ( $\approx 0.5$  psia), contaminated water on the inside, boiler surface of each boiler-condenser shell (e.g., surface **1032** of shell **1030**) boils causing water vapor to move away from the inside of boiler surface. Not all the contaminated water boils. Non-volatile contaminants remain in solution with contaminated water that doesn't boil. Enough contaminated water remains for gravity and force from any wipers such as wiper **1024** to urge contaminants as wastewater downward along the boiler surface (Fig. 14). The wastewater fans out when it passes the bottom of the boiler surface and lower strut **1058**. The bottoms of condenser wiper cylinders **1156**, **1157** and **1158** (Fig. 20) extend below the bottom of respective shell **1020**, **1030** and **1040**. As centrifugal force on exit directs the wastewater outward, it hits the bottom of the next-adjacent cylindrical wiper support, loses its kinetic energy and drops onto slanted surface **1402** of upper diverter **1400** (Figs. 15 and 16). The stationary upper diverter extends around and is fixed to center post **1050** below struts like strut **1058**.

[0217] Outer shell **1040** has no cylindrical wiper support outside the shell. Wastewater from the outer shell sprays onto upper portion of curved surface **1406** of upper diverter **1400** (Fig. 15). The curvature directs the wastewater onto the diverter's slanted surface **1402**. Wastewater from the three, cylindrical wiper supports and the curved surface flows inward along the upper diverter's slanted surface where the wastewater encounters openings like opening **1744** at the inside of the upper diverter (Fig. 15).

[0218] Bearing support **1063** mounts for rotation about a lower portion of the center post below stationary upper diverter **1400** (Figs. 11, 15 and 16). The bearing support includes an upright cylindrical wall **1100** with a threaded top **1084** (Figs. 15, 16 and 24). The upright cylindrical wall extends upward from curved intersection **1102** with slanted, disk-shaped section **1101**. See Fig. 24. The bearing support's central region and its horizontal surface **1101** are spaced from center post **1050** and are not below the upper diverter's openings like opening **1744**. The bearing support's central portion **1104** is generally open inward from depending cylindrical wall **1107** to central hub **1105**. See Figs. 15, 24 and 26. The position of opening **1744** causes wastewater flowing through the diverter's openings to miss the bearing support's horizontal surface.

[0219] Short, wide arms **1106** (Figs. 16 and 24) connect cylindrical wall **1107** and central hub **1105** of bearing support **1063**. The arms may have angled faces **1117**, which strike wastewater and accelerate wastewater downward as the arms revolve with bearing support revolution. Optional short plates **1117** on extension ring **1125** (Figs. 16, 23 and 24) also force water down as they revolve. The extension ring can be formed as part of depending cylindrical wall **1107** or fabricated separately and attached to the depending cylindrical wall.

[0220] Stationary collection ring **1410** mounts below bearing support **1063** (Figs. 16 and 26). The collection ring has in inner hub **1412** fixed to center post **1050**. Arms (not visible) extend outward to attach collector bowl **1414** to the inner hub to create space **1415** between the inner hub and collector bowl. The collector bowl includes an outer rim **1416**, which extends upward from disk **1418** (Figs. 16 and 26). Projection **1420** extends downward from the inside of the disk. Wastewater flowing down through the bearing support's central portion **1104** flows through space **1415** between the inner hub and the collector bowl. Disk **1418** of the collector bowl tilts down toward the center so any wastewater reaching the disk and not flowing directly through space **1415** flows inward along the disk to space **1415**.

[0221] Belt **1700** (Figs. 11, 15, 16 and 23) rotates gear **1770**. The belt extends around ring **1730**, which extends below bearing support **1063**. See Fig. 23.

[0222] Each boiling chamber's bottom is open allowing vapor to flow downward. A direct connection exists between the four boiler chambers, so they share the same near-vacuum pressure. Vapor from all the boiling chambers moves into and through region **1027** (Figs. 15 and 16). The cross-sectional drawings may look as if components occupy most of the region's space, but the region has enough empty space for the vapor.

[0223] Outer concentric cylinder **1188** and inner concentric cylinder **1187** are stationary and surround the boiler-condenser assembly. See Figs. 10, 11, 12, 13, 15, 16, 23 and 26. Spacing the concentric cylinders apart creates channel **1190**. The bottom of cylinders **1187** and **1188** have feet around them to create windows through which vapor can flow. See window **1189** in Figs. 16 and 23. The top of outer concentric cylinder **1188** extends into H-shaped gasket **1191** (Fig. 11).

[0224] Vapor in region **1027** from the shells' boiler surfaces flows through windows **1189** into channel **1029** between outer concentric cylinder **1188** and vacuum housing **1002** (Figs. 10, 11, 12, 13, 15 and 16). From channel **1029**, the vapor travels through openings (not shown) in top cover **1217** of blower housing **1212** into blower inlet **1218** (Figs. 10 and 11) at the lower pressure (top) side of blower **1210**.

[0225] Sidewall **1202** of blower housing **1212** attaches to top cover **1217** and base **1205** (Fig. 10). Threaded connection **1208** between parts may be used, but they may attach differently. Threaded connections may make maintenance easier. O-rings **1203** and **1204** and vibration dampers **1209** may mount between blower **1210** and the sidewall. Cylindrical extension **1206** of the blower housing's base extends downward in Fig. 10. The bottom of the cylindrical extension engages H-shaped annular ring **1191** on top of outer concentric cylinder **1188**. See Figs. 10, 11 and 12.

[0226] The blower compresses the vapor and directs the vapor through exit opening **1226** in the blower housing base **1206** (Fig. 12). Compression in the blower increases pressure of the vapor  $\Delta p$ , which causes the vapor's temperature  $\Delta T$  to increase because  $\frac{P}{T} = k$  (where  $k$  is a constant,  $P$  is pressure and  $T$  is temperature – Gay-Lussac's Law).

[0227] Typical pressure rises  $\Delta p$  may be 0.04 psia to 0.14 psia (.28 kPa to .97 kPa) with corresponding temperature rises  $\Delta T$  of about 2°F to 13°F ( $\approx 1^\circ\text{C}$  to  $5^\circ\text{C}$ ) under normal operating conditions. The elevated-pressure vapor flows from blower **1210** through openings **1061** in dome **1220** into boiler-condenser housing **1008**.

[0228] The annular framework assemblies like assembly **1110** (Figs. 10, 11, 13 and 14) support the shells. The framework assemblies are rigid strut-like fixtures. Supporting cylinders like supports **1026** and **1156**, which hold the wipers, also are rigid. The thin metallic boiler-condenser shells **1010**, **1020**, **1030** and **1040** and non-metallic framework assemblies like **1110** (Figs. 10 and 11) create a stiff boiler-condenser structure even without radial support struts. Radial braces between shells **1010**, **1020**, **1030** and **1040** would interfere with stationary wiper blades **1024** and **1150**. Because wipers are important, the Figs. 10 and 11 design relies on framework assemblies.

[0229] Framework assemblies like assembly **1110** also prevent vapor flow from the compressor into the boiling chambers like chamber **1028** and against the shells' boiling surfaces. Instead, the compressed vapor flows on the other side of the framework assemblies to reach the outside or condenser side of each shell. The framework assembly like assembly **1111** to the outside of shell **1030** forms condenser chamber **1031** between the framework assembly and the condenser side of shell **1030**. The framework assemblies neither impede the boiling vapor's flow-path exiting the boiler chambers like chamber **1028** nor impede the entering vapor flow-path to the condenser chambers like chamber **1124**. These vapor paths are in free space entirely around housing **1000**.

[0230] As with the boiler chambers, e.g., chamber **1028**, the condenser chambers such as chamber **1124**, also are in parallel and at the same near-vacuum pressure. The pressure in the boiling chambers is lower than the pressure in the condensing chambers, however.

[0231] When contaminated water boils from the boiler surfaces like surface **1032**, shell **1030** transfers heat energy to the contaminated water. The heat transfer from shell to contaminated water causes each shell to lose heat energy, which decreases its temperature. The thin shells' high heat-transfer coefficient also decreases the temperature of the shells' outside surfaces. Vapor reaching the condenser surfaces is at a higher temperature due to its pressure increase through the blower so that "warm" vapor reaching condenser surface **1033** encounters a relatively cold surface where the vapor condenses as freshwater.

[0232] Changing the phase of vapor into liquid water on condenser surface **1173** transfers the thermal energy from the heat of condensation to the condenser surface, which transfers heat to the shells like shell **1020**. Condensation recovers heat energy that caused water to boil from boiling surface **1022**. This heat energy and the energy transfer during condensation are the only energy sources to raise the shells' temperature to cause the heat of boiling on boiling surface **1022**. The system recovers energy used to boil the contaminated water minus thermodynamic-inefficiency losses of the compressor and the small excess heat energy ( $\Delta T$ ) required to drive the process.

[0233] Centrifugal force caused by shell rotation may expel condensed water from the condenser surface, but surface tension may hold condensate on the condenser surface. Removing condensate quickly improves condensation and overall efficiency because condensate remaining on the condenser surface limits or prevents vapor from contacting the high, heat-transfer condenser surface.

[0234] To aid removing condensate held on the condenser surface by surface tension, each condenser surface, e.g., surface **1032**, has one or more wipers. Condenser wiper assembly **1154** (Figs. 17 and 20) includes four wiper support cylinders **1156**, **1157**, **1158** and **1159**, which depend from struts **1054**. (Fig. 20 looks upward; the struts are near the top of the boiler-condenser. See Figs. 10 and 11.) The cylinders, which are stationary, are around the outside, condenser surface of each shell.

[0235] Condenser wipers like wiper **1150** contact condenser surface **1173** to throw condensate off the surface. The external wipers mount on fittings like fitting **1153** (Fig. 20), which are inward facing projections like projection **1153** of cylinder **1152**. The wipers attach to slots in the wiper fittings. Fig. 20 shows wiper fittings every 90°, and wipers may attach to any desired fittings. Each wiper may be one piece or may include two or more wipers. The vertical edge of each wiper may extend outward in the same direction as the shells rotate, or the wipers may extend in the opposite direction to "cut through" water on the shell as the wiper reaches the water. The wipers are spaced from the framework assemblies and don't reach to the lower ring such as ring **1112**.

[0236] Freshwater condensate thrown off condenser surface **1173** by centrifugal force and the wipers contacts spiraled ridges of the annular framework assembly such as ridge **1037** on framework assembly **1111**. See Figs. 11, 13, 14 and 25. Each framework assembly has one continuous ridge in the drawings, but each framework assembly could have two or more ridges. The ridges need not be continuous; they could be interrupted. The framework assemblies' revolutions around axis **1022** combined with the spiraled ridges urges the condensate upward and over the

framework assemblies. Even without the spiraled ridges, the angle of the framework assembly still urges freshwater upward. When the condensate reaches the top of a framework assembly, centrifugal force throws the water toward inside wall **1176** of dome **1220** and outward through openings **1177** (Fig. 12). The water sprays onto outer concentric cylinder **1188** where it loses its rotational kinetic energy and flows downward in channel **1190** between the outer and inner concentric cylinder **1188** and **1187**. From channel **1190**'s bottom, the water flows into annular groove **1775** at the top of pitot pump **1712** (Figs 11 and 15). The groove slants with a deeper portion above opening **1707** into pitot pump **1712**, which is discussed below.

[0237] **Removing Freshwater and Wastewater:** The bladder system for removing wastewater and freshwater from the device in Fig. 5 could remove them from the device in Figs. 10 and 11. That system overcame outside atmospheric pressure pushing against the vacuum chamber's vacuum to allow wastewater and freshwater removal. As discussed with Fig. 5, conventional pumps use considerable energy and might allow outside air into the vacuum chamber.

[0238] Instead of the bladder system in Fig. 5, the processor of Figs. 10 and 11 and accompanying figures use pitot pumps (also called "pitot-tube pumps") to raise the pressure of the potable water and wastewater. B. Schiavello, "Tutorial on Special Purpose Pumps Pitot; Progressing Cavity; Air Operated Diaphragm; and Hydraulically Actuated Diaphragm," Proceedings of the 14th Int'l Pump Users Symposium, available at [www.911metallurgist.com](http://www.911metallurgist.com). The article is incorporated by reference. Pitot pumps are variations of centrifugal pumps, but they typically use a rotating pitot tube to pass through the fluid being pumped. Applicants do the opposite; they rotate water in a chamber, and the water encounters the pitot tube within the chamber. The pressure head of a pitot pump is a function of the radius of the tube arm, the area of the opening of the pitot tube and the velocity of the fluid. More on applicants' pumps' structure below.

[0239] Two pitot pumps **1712** and **1722** separately pump freshwater and wastewater from the device. Separate motors could run each pump, or one motor could run both pumps, but devices in Figs. 10 and 11 rely on motor **1214**, which powers the blower and rotates the shells, to power the pitot pumps through gears and pulleys described below.

[0240] Bearings **1726** and **1727** for freshwater pitot pump **1712** support upper shaft **1724**, and bearings **1728** and **1729** support lower shaft **1725** (Figs. 11, 15 and 16). The upper shaft's bottom attaches to upper magnetic wheel **1738**, which is above bottom wall **1004** of vacuum housing **1002** (Figs. 11, 15 and 16). Components rotating the upper magnetic wheel are discussed below. Magnetism from rotation of the upper magnetic wheel rotates lower magnetic wheel **1739**. The plastic bottom wall allows the upper magnetic wheel's magnetism to drive the lower magnetic wheel.

[0241] Magnetic force between the upper and lower wheels **1738** and **1739** also secures freshwater pitot pump **1712** to the bottom **1004** of vacuum chamber **1000**. Similarly, the magnets of upper and lower wheels **1738** and **1739** exert enough force to secure wastewater pitot pump **1722** to the bottom **1004** of vacuum chamber **1000**. The respective O-rings in grooves **1466** and **1467** of the freshwater pitot pump and those in O-ring grooves in the wastewater pitot pump (not numbered) seal the pumps to the vacuum chamber's underside.

[0242] Gear or pulley **1770** attaches to upper shaft **1724**. See Figs. 11, 15 and 16. The shaft-support assembly, which includes the upper shaft, its gear and bearings **1726** and **1727**, is an "off-centered" concentric. Bolts (not shown) extend through shafts **1746** and **1747** to secure plates **1749** and **1750** together. See Fig. 16. The plates secure bearings **1726** and **1727** and gear **1770** together. Upper boss **1752** on plate **1749** seats and can rotate in cavity **1753** of lower diverter **1740**. Lower diverter **1740** has an O-ring **1438** that seals the lower diverter to inner concentric cylinder **1187** (Figs. 10, 11, 16 and 26). Inside portion **1743** of the lower diverter extends upward (Figs. 15, 16 and 26), and the inside of the vertical portion is threaded at **1194** to secure fitting **1192** (Figs. 16 and 26). Three posts **1447**, **1448** and **1449** extending from lower diverter **1740** (Fig. 23) act as feet to support the lower diverter against base **1004** of vacuum housing **1002**.

[0243] Upper shaft **1724** is off-centered because the shaft, gear and bearings are not at the center of plates **1749** and **1750**. Rotating plates **1749** and **1750** cause the shaft, gear and bearings to move laterally. Upper magnetic wheel **1738** is in cylindrical bowl **1783** (Figs. 16 and 28). As those figures show, the bowl's diameter is larger than the magnetic wheel's diameter to allow positioning of the wheel in the bowl. Note the space between the magnetic wheel and the bowl in Figs. 15 and 16.

[0244] Pitot pump **1722** for wastewater and the components for powering the pump are like those running pitot pump **1712** for freshwater. Upper shaft **1724** and lower shaft **1725** rotate between respective sets of bearings **1754** and **1756** and bearings **1758** and **1759** (Fig. 11). Upper magnetic wheel **1768** attaches to the upper shaft, and lower magnetic wheel **1769** attaches to the lower shaft. The upper magnetic wheel's rotation causes the lower magnetic wheel's rotation.

[0245] Gear or pulley **1771** attaches to upper shaft **1724** and bearings **1756** and **1757** (Fig. 15). Like the shaft-support assembly for freshwater pitot pump **1712**, this assembly also is an off-centered concentric. Shafts **1773** and **1774** receive bolts (not shown) for holding plates **1749** and **1750** together (Fig. 15) with gear **1771** and bearings **1756** and **1757** between the plates. Upper boss **1779** on plate **1749** seats and can rotate in cavity **1780** of lower diverter **1740**. Cavities **1753** and **1780** in the lower diverter also are visible in Fig. 27.

[0246] Upper shaft **1746**, gear **1771** and bearings **1756** and **1757** are not at the center of plates **1749** and **1750**. Pivoting plates **1749** and **1750** moves the shaft, gear and bearings. Upper magnetic wheel **1768** mounts in cylindrical bowl **1784** (Fig. 15). The bowl's diameter is larger than the magnetic wheel's diameter to allow positioning of the wheel in the bowl.

[0247] Belt **1700** (Figs. 15 and 16) rotates shaft **1756** through gear **1771** for wastewater pitot pump **1722**. Supports **1436** and **1437**, which are like those around shaft **1725** in Fig. 15, may be tightened together to balance the force between them. Bolts (not shown) extending through slots **1440** and **1442** secure the supports together. Through magnetic coupling of wheels **1768** and **1769**, rotation of upper shaft **1454** and its wheel **1768** transfers rotation to lower wheel **1769** and lower shaft **1755**.

[0248] During assembly, drive belt **1700** is loose over gear **1771** below bearing support **1436** (Figs. 15 and 23). The belt also passes over gear **1770** on upper shaft **1724** for freshwater pitot pump **1712**. Pivoting plates **1750** and **1738** and plates **1723** and **1437** moves respective gears **1770** and **1754** to positions for proper tightening of the drive belt. When the drive belt is at its proper tension, screws (not shown) secure plates **1750** and **1738** and plates **1723** and **1437** to lower diverter **1740** (Figs. 15, 16 and 23). Fig. 27 shows screw holes **1785**, **1786**, **1787** and **1788**. Reinforcing the screw holes, especially on the diverter's top side, may be desirable because the lower diverter is thin.

[0249] Instead of the off-center arrangements described above, components such as an idler or tensioner pulley could guide and maintain the drive belt's tension.

[0250] Moving plates **1749** and **1750**, gear **1770** and upper shaft **1754** for freshwater pitot pump **1712** changes the position of upper magnetic wheel **1738**. The upper wheel may move out of alignment with the lower magnetic wheel **1739** unless the pitot pump could be rotated so the two magnets self-align. Self-alignment can occur if the diameter of cylindrical bowl **1783** (Figs. 16 and 28) surrounding the upper driving magnet is larger than the magnet's diameter. The drawing shows those proportions. Similar structure of wastewater pitot pump **1722** and magnetic wheels **1768** and **1769** also allow self-alignment of the wastewater pump's components.

[0251] Pitot pump **1712** for freshwater mounts in pump housing **1703** (Figs. 11, 15, 21 and 22), beneath base **1004** of vacuum housing **1000** (Figs. 10, 11, 15 and 16). Pitot pump **1712** includes rotating cavity **1717**, which lower shaft **1725** drives. The lower shaft rotates through belt **1700** rotating gear **1770**, which rotates shaft **1724**, the pair of magnetic wheels **1738** and **1739** and shaft **1725**. Pitot tube **1715** within the pitot pump includes upright section **1716** extending from plate **1705** through opening **1741** into pump cavity **1718**. Pitot tube **1716** has a horizontal, curved

section **1717** extending near the cavity's inner wall **1718**. The pitot tube terminates at circular opening **1719**, which may be tapered.

[0252] The pitot pump's rotating cavity **1717** is at the near-vacuum pressure inside vacuum housing **1000**. Cavity rotation causes water collected in the cavity to rotate. How freshwater flows into the cavity is discussed below. Vanes **1704** (Fig. 22) aid water in the cavity to rotate at or near cavity wall's **1718** velocity. The rotating water encounters the pitot tube's opening **1719**, flows into pitot tube **1715** where the pressure increases. By designing the cavity's rotational velocity and the radii of curved section **1717** and opening **1719**, the water pressure can rise to atmospheric pressure (14.7 psia or  $\approx 101$  kPa) or above. With the water above atmospheric pressure, it can flow through the pitot tube's upright section **1716** and out opening **1741** (Figs. 21 and 22) where it can be collected in a container (not shown).

[0253] A reed valve like valves **330** and **331** in Fig. 5 or another type of check valve can mount downstream of opening **1741** to prevent atmospheric pressure air from flowing back through the pitot pump and into the processor if the pitot pump is off or has no freshwater. The pitot pump's design must account for the pressure drop through the check valve, but energy used to raise the pressure 5 or 10 psia to overcome the pressure drop through a check valve should not affect the system's efficiency and power usage significantly.

[0254] Pitot pump **1712** receives freshwater as follows. Base **1004** of bottom portion **1002** of vacuum housing **1000** has two slanted ring grooves **1430** and **1432** (Fig. 28). Outer ring groove **1430** collects freshwater, and inner ring groove **1432** collects the wastewater. Both ring grooves are inclined. Opening **1431** is at the low point of the outer ring groove, and opening **1433** is at the low point of the inner groove **1432**. The pitot pumps also have slanted ring grooves. Opening **1431** drains freshwater into inclined ring groove **1465** around the top of freshwater pitot pump **1712**. Opening **1433** drains wastewater into ring groove **1469** of pitot pump **1722**.

[0255] Slanted ring groove **1465** for freshwater pitot pump **1712** is circular so that opening **1431** of outer groove **1430** is over part of the pitot pump's inclined ring groove despite the pitot pump's angular orientation. The pump's inclined ring groove **1465** is between O-ring grooves **1466** and **1467**. See Figs. 11, 15 and 21. The O-rings create a seal between the pitot pump and the underside of base **1004** of lower portion **1002** of vacuum housing **1000**. The ring groove and O-ring grooves may be molded into the pitot pump's top surface. The pump's ring groove slants with a low point above opening **1707**. Freshwater flowing into the ring groove seeks the groove's low point, flows into opening **1707** and down into the freshwater pitot pump.

[0256] Wastewater pitot pump **1722** may match the other pitot pump **1712**. It has inclined ring groove **1469** (Figs. 11 and 15), part of which aligns with opening **1433** inside the lower part **1002** of vacuum housing **1000**. (Fig. 28). Opening **1433** is at the low point of vacuum housing's inside ring groove **1432** (Fig. 28). The pitot pump's inclined ring groove **1469** is under opening **1433** notwithstanding the pitot pump's angular orientation. The low point of the pitot pump's inclined ring groove **1469** is at opening **1745**, which leads into the pitot pump. See Figs. 11 and 15.

[0257] For the wastewater pitot pump **1722**, the wastewater flowing through opening **1744** reaches channel **1745** around the wastewater pitot pump (Figs. 11 and 15). Water pressure raised by the head of wastewater in channel **1745** causes the wastewater to flow through inlet **1459** (Fig. 11). Pressure from water in the conduit directs the water into the pitot pump's chamber **1772**. The chamber rotates using components like those rotating chamber **1717** of pitot pump **1712** for freshwater (Figs. 11, 15 and 21). Chamber rotation causes the wastewater to rotate and move into pitot tube **1781**. The water is pressurized in the pitot tube to 14.7 psia or higher and exits outlet **1782**. A check valve (not shown) could prevent flow back into the outlet.

[0258] The angular orientation of pitot pumps **1712** and **1722** in lower housing **1002** changes depending on the lateral positions of gears **1770** and **1771**. After adjusting the off-center arrangements of upper shaft **1724**, gear **1770** and bearings **1756** and **1757** and of upper shaft **1754**, gear **1771** and bearings **1756** and **1757** to tension drive belt **1700**, pitot pumps **1712** and **1722** center themselves magnetically—upper magnetic disk **1738** to lower disk **1739** and magnetic disk **1768** to disk **1769** (Figs. 11 and 13). Regardless of each pitot pump's angular position, the slanted ring grooves **1775** and **1469** in the respective pitot pump always are under the upstream source of freshwater or wastewater so the fluids flow into the pitot pump's entrance.

[0259] **Seals:** During operation, seals contain the pressure differentials between the compressed vapor from the blower in the condensing chambers like chamber **1124** and the pressure in the boiling chambers like chamber **1038**. The sealing requirements are not stringent because of the low-pressure difference. Under normal operation, the pressure differential  $\Delta p$  may be about 0.04 psia to 0.14 psia ( $\approx$  .28 kPa to .97 kPa). As with the other designs discussed earlier, applicants use special rotary seals like seal **190** in Fig. 4 to hold that pressure differential.

[0260] The first or upper seal **1160** comprises ring **1162** (Figs. 11, 12, 13 and 25), which is fixed to center post **1050**. The ring extends into channel member **1164**, which is at the top of innermost shell **1010**. The channel member rotates with the shells. By diverting contaminated water otherwise flowing into feed input **1070** into another conduit **1165** through the center post, the channel member fills with contaminated water. See Fig. 13. The top of conduit **1165** intersects short piece of Tygon® or other appropriate flexible polymer tubing **1166**, which empties into the seal's

channel member **1164** and fills it. When the processor is working and the seal is filled, the user can block flow into the seal. Letting contaminated water always flow into the seal should be acceptable because any overflow from the seal flows onto the boiler side of shell **1010** for processing. Especially if the system uses one shell only, the system could eliminate tubes such as tube **1090** and their associated structure and just use overflow contaminated water from the upper seal. The flow rate of contaminated water into the seal would be modified.

[0261] The pressure differential ( $\Delta p$ ) between vapor boiled from boiler surface **1022** and the compressed vapor from the blower exerts different pressure forces on the rotary seal's fluid. The pressure difference creates a differential height column in the rotary seal's channel member **1171** (See Fig. 13). The pressure on the fluid above ring **1162** (Figs. 11 and 13) is greater than the pressure below the ring due to pressure forces from vapor after the blower raises its pressure. The pressure difference displaces the column of fluid, but the channel member rotates during system operation, so centrifugal force acts on the fluid above and below ring **1162** to retain fluid in the channel member. Enough fluid remains above and below the ring to prevent vapor flow through the seal.

[0262] Lower or second rotary seal **1181** (Figs. 10, 11, 13 and 15) operates on similar principles. A stationary ring extends into a channel, which contains water. The pressure above and below the ring is different. Rotation of the channel generates centrifugal force on the water in the channel. The pressure difference above and below the ring provides a different force on the water above and below the ring, but the centrifugal force on the water forces the water into the channel to retain the water in the channel. The water blocks vapor from passing beyond the seal.

[0263] The structure for lower seal **1181** includes ring **1186**, which is pinned between vertical support **1743** of lower diverter **1740** (Figs. 15 and 16) and annular fitting **1192**. The vertical support and annular fitting are threaded together at **1194**. The ring extends outward into channel member **1185** at the bottom of rotating bearing support **1063**. See Figs. 16 and 26. Applicants use one or more short lengths of Tygon or other appropriate flexible polymer tubing (not shown) extending between conduit **1165** through center post **1050** and small hole **1174** (Fig. 24) through lower diverter **1740** to add water to the channel. Wastewater flowing out the tubing flows into channel member **1185**.

[0264] Fig. 16 shows a single conduit through annular fitting **1192**, but the fitting could have several conduits to provide wastewater at spaced-apart locations of channel member **1185**. If so, lower diverter **1740** could have multiple holes, each attaching to Tygon tubing. Each piece of tubing would connect to conduit such as conduit **1195** in fitting **1192**. Wastewater flows through the tubes and through opening **1174** in ring **1175** (Fig. 23).

[0265] Water in the channel member above ring encounters lower-pressure vapor from the shells' boiler sides like boiler side **1022** of shell **1020** than the water below the ring, which is higher-pressure vapor from the blower. Centrifugal force from bearing support's rotation urges liquid above and below ring **1186** to hold the liquid in the channel member and create a seal. The effective radius of lower seal **1181** is greater than the radius of upper seal **1160** so g-force on the liquid in seal **1181** could be greater than the g-force on the liquid in seal **1160**. The designs of the two seals can account for the different radii and g-forces.

[0266] The vapor pressure differential that can be sealed depends upon the fluid density ( $\rho$ ) (slightly less than 1 g/cm<sup>3</sup> for 70°F (21°C) water), the fluid height differential ( $\Delta r$ ) on opposite sides of stationary rings **1162** or **1162** and the g-force applied to the fluid in the channel. The g-force is a function of the rotational speed ( $\omega$ ) and the radius from the channel to axis of rotation **1052**. Proper design of channel members **1171** and **1185** provides flexibility over the allowable pressure differences ( $\Delta p$ ) and operating spin speeds ( $\omega$ ) required to achieve a rotating vapor seal.

[0267] Lower rotary seal **1181** receives contaminated water while the processor runs so some water overflows the lower seal. Any overflowing contaminated water flows onto upper surface **1793** of lower diverter **1740**. The surface is inclined and contoured to direct the overflow water to hole **1794** (Fig. 26). Stand-off tube **1451** (Figs. 23 and 26) projects downward from the diverter below hole **1794**. Surrounding ring **1452** creates a seal between the stand-off tube and the bottom of lower diverter. Excess contaminated water flows into the stand-off tube. The stand-off tube is a port to the bottom of the lower housing for creating the process's near-vacuum by evacuating the entire processor.

[0268] The contaminated water flowing through stand-off tube **1451** cannot drain directly while the system operates because the top of the stand-off tube is at near-vacuum pressure and cannot flow outside where the pressure is atmospheric (14.7 psia). Draining the stand-off tube while the system is not in operation and the internal pressure is atmospheric allows removal of water in the system. The stand-off tube could drain to a valve, and a tube leading downstream from the valve could be S-shaped. The S-shape acts as a trap to prevent fluid and vacuum flow.

[0269] The stand-off tube also connects to a vacuum pump to evacuate the vacuum housing and to apply a vacuum occasionally to account for small pressure increases. The vacuum pump would not run if any water were trapped in the S-shaped drain tube. If fluid accumulates inside the drain tube, the user would close a valve (not shown), and the tube would be detached and then drained.

[0270] Applicants could provide a container downstream from stand-off tube **1451**. The container captures the drained water, but the tube leading to the container remains above the drained water. A valve would be provided between the stand-off tube and the container. A tube connects the vacuum pump to the container above the drained water. When the vacuum housing requires additional vacuum, the valve between the stand-off tube opens. Because the tube to the vacuum pump and the stand-off tube are above the water in the container, the vacuum pump can draw vacuum directly through the stand-off tube. When the container has too much water, the valve to the stand-off tube is closed, and a second valve on a drain tube from the container opens to drain the container.

[0271] **Operating the System:** Before operation begins, vacuum chamber **1002** is evacuated. Standoff tube **1451** is attached to a vacuum pump to lower the pressure in vacuum housing **1008** to near vacuum,  $\approx 0.5$  psia. The tube is one of the few parts crossing through the housing between vacuum and atmospheric pressure. Therefore, the seal between the tube and the housing must be good enough for the vacuum. The system may not operate during the initial evacuation so boiler-condenser housing **1008** and blower **1210** remain stationary. This system also may use vacuum seals (discussed below) that only seal when the boiler-condenser assembly **1000** rotates. Air and vapor inside the housing pass through the seals during the initial evacuation. The boiler chambers like chamber **1028** and condenser chambers like chamber **1031** are at the same vacuum during initial evacuation.

[0272] Motor **1214** activates to rotate blower/compressor **1200**. Seals are re-activated with fluid to seal the low vapor pressure difference developed by the blower between condenser chambers like chamber **1124** and the boiler chambers like chamber **1128** (Fig. 14) of boiler-condenser assembly **1000**.

[0273] The vacuum pump shuts off when the vacuum chamber reaches its normal operating near-vacuum pressure. The incoming contaminated water may contain dissolved  $O_2$ ,  $N_2$ , Ar,  $CO_2$  or other non-condensable gases. When the water boils, the non-condensable gases become a component of the vapor, but they don't condense and remain in the vapor. Their presence adds to the internal pressure, i.e., decreases the vacuum. Occasional, later evacuations may be needed during the system's operation to maintain the desired vacuum.

[0274] When the stand-off tube it is not being used to evacuate the housing, it can act as a drain for incoming contaminated water overflowing lower rotary seal **1181**. Any excess contaminated water drips onto the top-side of lower diverter **1740**. The diverter's top surface directs water to opening **1744** (Fig. 26), which aligns with stand-off tube **1451**.

[0275] Housing **1000** and its internal boiler-condenser assembly (including the bearings, seals, wipers, inlet feeds, and central axis) may be removable as a unit from its Figs. 10 and 11 operating orientation for replacement or maintenance.

[0276] The system also could use a housing that accepts one, two or more boiler-condenser shells and components. Such variation could provide varying amounts of potable water throughputs. The compressor chosen for different numbers of shells should be capable of operating over a range of operating conditions, i.e., speeds of rotation to accommodate the increased vapor flow rates.

[0277] Continuous thinning of the boiling fluid from the rotational induced g-forces on the fluid as enhanced by the wiper blades increases the boiling heat transfer coefficient by an order of magnitude or more over conventional boiling distillation. Likewise, g-forces throw condensate from the condenser surfaces, and the wiper blades remove liquid that g-forces don't throw off. These combined actions create fresh, exposed metal surfaces for condensation, which should enhance the heat transfer coefficient of the condenser by an order of magnitude or more. Applicants' system should have heat transfer values between 2,000 to 6,000  $\frac{\text{Btu}}{\text{hr ft}^2\text{°F}}$  ( $\approx 1.1 \times 10^4$  to  $3.4 \times 10^4 \text{ W/m}^2\text{°C}$ ). 1 Btu/hr  $\approx$  0.29 watts. The heat transfer values are about an order of magnitude greater than values for conventional boiler-condenser systems.

[0278] Figs. 31 – 39 show another version of the processor. The drawings show a single boiler/condenser shell. The system could be modified, however, to use multiple shells. Most components of this version **1500** are within housing **1502** (Fig. 31). The housing includes upper housing plate **1504**, cylindrical housing wall **1506** and bottom housing plate **1508**. The top and bottom of the cylindrical housing wall seats in grooves **1510** and **1512** of the housing plates. O-rings **1514** and **1516** seat in the grooves so that the inside of the housing is sealed. The housing connects to a vacuum pump (not shown) to lower the pressure in the housing to near-vacuum. The vacuum pump only operates during the initial evacuation, but it also may operate occasionally if the incoming contaminated water contains dissolved O<sub>2</sub>, N<sub>2</sub> or CO<sub>2</sub>. These gasses do not condense, so they may raise the pressure. The occasional vacuum pump operation may have to decrease the pressure within the housing back to desired levels.

[0279] Blower/compressor **1520** is inside compressor housing **1560** (Fig. 31), which mounts within housing **1502** (Fig. 31). Three-stage compressor **1520** is fixed inside compressor housing **1560** (Fig. 31), which is formed from cylindrical support **1568** with top and bottom cylindrical walls **1595** and **1590**. O-rings **1562** and **1564** prevent backflow of compressed vapor from the compressor. The top and bottom cylindrical walls attach to the top and bottom compressor

housing **1520**. The three-stage compressor has three rotors **1522**, **1524** and **1526** mounted in respective stators **1528**, **1530** and **1532**. A three-stage compressor is used because it fits in this version of the processor, but different numbers of stages could be used. Blower motor **1540** rotates the compressor's rotors. The motor mounts within motor housing **1542**, which is open to atmospheric pressure. The motor rotates compressor shaft **1544** through a magnetic coupling comprising magnets **1546** and **1548**. The motor rotates shaft **1550**, which connects to and rotates magnet **1546**. Rotation of magnet **1546** rotates magnet **1548**, which attaches to and rotates compressor shaft **1538**. Air gaps **1552** and **1554** surround the magnets to prevent friction from other structure acting on the magnets. Using the magnetic drive avoid potential leaks caused by conventional rubber or plastic seals around the compressor shaft.

[0280] The top **1544** of compressor shaft **1538** extends through upper bearing **1556** inside bearing support **1558**. One or more pins or screws (not shown) may secure the bearing support to top of blower **1520**. Lower bearing support **1574** holds bearing **1576**. The upper and lower bearings **1556** and **1576** allow the compressor shaft to rotate freely. Balance ring nut **1578** at top **1544** of the shaft allows rotational balancing of shaft **1544** and rotors **1522**, **1524** and **1526** in compressor **1520**. The motor may rotate about 2,000 rpm depending upon the chosen configuration and operating conditions. These small motors are efficient and normally waste little electrical power.

[0281] Boiling and condensing of water vapor on the boiling/condenser shell is discussed later. Limiting the discussion to compressor **1520** and its related structure, arrow **1580** shows the vapor path from the shell to the compressor. Lower cylindrical support **1590** has spaced-apart vapor passage windows **1592**. Vapor passing through the windows is at a pressure lower than vapor exiting compressor **1520**. Fig. 31 has eight such windows though not all are visible. The vapor from the window passes through openings **1594** into the compressor, which raises the pressure of the vapor.

[0282] Compressor **1520** may raise the pressure of the vapor  $\Delta p$  0.04 psia to 0.14 psia (0.28 kPa to 0.97 kPa). The corresponding temperature rises  $\Delta T$  will be about 2°F to 13°F ( $\approx 1^\circ\text{C}$  to  $5^\circ\text{C}$ ) under normal operating conditions. The elevated-pressure vapor flows from blower **1210** through openings **1596** in top wall **1570**. From there, the vapor flows along paths following arrow **1598**.

[0283] The vapor contacts condenser surface **1602** of shell **1600**. Contaminated water boils from the boiler surface **1604** as discussed below. Heat transferred across the shell by vapor condensation on the condenser side is the sole energy source to cause boiling and phase change on the boiler side. As the boiled vapor evaporates from the filmed wastewater, heat energy is removed at the same rate that heat energy is transferred across the shell from vapor condensation. The rate of evaporation (in gallons per day or liters/hour) is linearly proportional to, and governed by, the

excess temperature difference,  $\Delta T_{BC}$ , generated by the added compression energy generated by the blower. The temperature of the shell remains fixed at the constant temperature of the input wastewater. The shell is colder than the compressed vapor exiting the blower, which causes condensation to occur on the shell condenser surface. Shell **1600** also is thin, e.g., 0.004 in. to 0.015 in. ( $\approx 0.10$  mm to 0.38 mm) and formed of material with a high heat-conductivity. When higher temperature vapor from compressor **1520** contacts the colder-temperature condenser surface, the vapor changes phase and condenses as pure water on the surface. Wipers for removing condensate from the condenser surface and components for collecting the pure water are discussed later.

[0284] Contaminated water enters the processor from inlet **1610**. The inlet connects to a Tygon<sup>®</sup> tube **1614** or another conduit. The inlet in Fig. 31 can be positioned at different circumferential positions that do not interfere with other structure. The tube extends upward at **1616** and bends downward at bend **1618** into upper seal **1620**. The seal uses principals similar to those used by seal **190** (Fig. 4).

[0285] Contaminated water from the end of the bend top **1616** flows into bottom **1624** of channel **1616** below blade **1628**. Seal **1620** extends outward from the blower support cylinder **1568** (Fig. 31) so the channel revolves around the axis of this cylinder. Contaminated water below the blade flows over the blade and into top **1624** of the channel. Centrifugal force from the shell's rotation urges contaminated water to the outside (left in Fig. 31). The top **1622** of channel **1616** is subjected to the higher pressure of vapor from compressor **1520**, so the sum of the pressure force and the centrifugal force acting above the blade is greater than the centrifugal force alone acting below the blade. The size of channel **1616** and the length of blade **1638** prevent the inside edge of water above the blade to pass the blade's outer edge so seal **1620** maintains a seal when the shell rotates. Paragraph [0124] describes the seal's mathematics.

[0286] Channel **1622** containing the "plug" of water above the blade is longer than the channel **1616** below the blade. The incoming water, therefore, overflows the seal. The inside of channel **1616** is positioned close to the top of boiler surface **1604** of shell **1600** allowing the overflow of water to spread and reach the boiling surface. "Centrifugal" force keeps the contaminated water on the boiling surface, and gravity and the centrifugal forces spread the contaminated water along the boiling surface.

[0287] Some water of the contaminated water boils, and the resulting vapor will become pure water. What remains from the contaminated water that doesn't boil remains as liquid wastewater where it becomes more concentrated with contaminants as water vapor exits the contaminated water. Gravity and centrifugally assisted forces from contaminated water at the top of shell **1600** cause the wastewater to flow downward toward the shell's bottom.

[0288] The wastewater reaches lower seal **1630** and contacts blade **1632**, which extends radially inward beyond shell **1600**. See Fig. 32. The wastewater flows around the outside edge of the blade in upper part **1634** of the seal and into the lower part **1636** of the seal. Centrifugal force from shell rotation causes the wastewater above and below the blade to form a plug. The lower part of the seal is under higher pressure from the compressor than the upper part of the seal, which is subject to the lower pressure from the boiler surface of the shell. The centrifugal force on the water forms a plug of wastewater to act as a seal, preventing vapor from flowing through the seal.

[0289] The inside edge of wastewater in the upper part **1634** of the seal becomes aligned with the boiler surface because the full seal cannot accept more wastewater. The wastewater flows off the inside diameter portion of the blade extending radially inside shell **1600**. To facilitate wastewater flow, the blade may be angled downward on the inside diameter of the blade.

[0290] Like upper seal **1620**, the top and bottom of lower seal **1630** are subjected to different pressures (top under pressure from boiler and bottom under higher pressure from compressor). The seals size, the lengths of upper part **1634** and lower part **1636** of the seal, and the length of blade **1632** are designed so water will not flow through the seal when shell **1600** rotates.

[0291] Wastewater that flows off blade **1632** passes through an opening **1638** cutout at the bottom of lower cylindrical support **1568**. Fig. 31 has eight such openings, but not all are visible in Fig. 31. The wastewater collects between the outside of lower cylindrical support **1590** and the cylindrical wall **1568** of compressor housing **1560** where it can flow into wastewater outlet **1640**. Removal of wastewater from the outlet is discussed below.

[0292] Returning to the pure water vapor boiled from boiler surface **1604** of shell **1600**, the vapor follows the path shown by arrow **1580** through the compressor **1520**. Fig. 32 show the continuation of the arrow. The vapor passes through cutouts **1646** at the top of support **1595**. The support structure **1648** holds wipers facing and in contact with the shell's condenser surface **1602**. The wipers are discussed below. The vapor condensing on the condenser surface will form droplets, that fling off the surface from the shell's rotational g forces, but the condenser surface retains at least some thin condensate. Surface tension holds this condensed water on the shell. Wipers help remove condensate from the shell and leave exposed metal surface for forming new condensate. This considerably enhances the condensing heat transfer coefficient and improves overall thermodynamic efficiency, so the processor uses less energy per each unit mass of freshwater produced.

[0293] External wipers **1650** mount on wiper support **1648**. In Fig. 31 and 32, the eight wipers extend vertically the length of the condenser surface **1602**. Each external wiper has an inward facing wiper blade **1652** in contact with the condenser surface. As with other versions of the processor, the wiper blades could be angled or divided into sections. To decrease friction between the wiper blades and the condenser surface, the blades may be formed of Teflon® or another low-friction material. The external wiper also may present a sharp edge instead of a flat surface facing the condenser surface. Internal wipers, which spread contaminated water along the boiler surface, are not shown in Figs. 31 or 32, but they could be added.

[0294] Other versions of the water processor used one motor to drive all rotating parts. this version uses two separate motors, one, motor **1540**, drives the compressor and the other, motor **1660** drives the shell's rotation and other structure. Motor **1660** is best seen in Figs. 35 and 36.

[0295] Motor **1660** mounts below lower outer housing plate **1508**. The motor rotates shaft **1662**, which rotates lower magnetic coupler **1664**. Bolt **1666** secures the magnetic coupler to the shaft. Upper magnetic coupler **1670** mounts in slot **1672** of housing plate **1508**. The slot leaves thin wall **1674** between the magnetic couplers. Bolt **1676** secures the upper magnetic coupler to shaft **1680**. Shaft **1680** extends upward from the upper magnetic coupler through bearing **1684** and **1686** and attaches to and rotates driver **1682**.

[0296] Before describing that driver rotates shell **1600**, the shell subassembly (Fig. 33) is discussed. Shell subassembly **1690** includes the thin, high heat conductive shell and upper **1692** and lower **1694** shell supports, which add rigidity to the thin shell. Circular rim **1696** in the lower shell support attaches to the bottom of the shell and complementary circular rim **1698** in the upper shell support attaches to the top of the shell. The rims may have small shoulders **1701** and **1702** to provide more support for the shell. See Figs. 36 and 37.

[0297] Upper shell support **1692** also forms the structure of upper, rotating, U-channel seal **1620** that receives blade **1628** (Figs. 31, 32 and 37). Lip **1704** and rim **1706**, which are above the seal receive ring bearing **1708** (Figs. 31 and 37). The right side of the bearing is stationary, and the left side rotates as the upper shell support revolves with the shell. Upper ring bearing supports **1712** and **1714** are stationary. An annular piece of foam **1716** is between upper outer housing plate **1504** and the upper ring bearing supports. Fig. 37 also shows O-ring **1718** between the condenser and boiler sides of the shell preventing vapor from flowing between them. Stationary ring support **1726** is glued or otherwise attached to the upper seal's blade **1628**. Set screw **1720** attaches the stationary ring support to cylindrical wall **1568** of compressor housing **1560**.

[0298] Lower shell support **1694** (Figs. 31, 32, 33 and 36) shares similarities with upper shell support **1692**. Rim **1696** attaches to the bottom of shell **1600** (Fig. 36). The rim is at the top of lower seal **1630**. Bearing support **1722** supports bearing **1724**. The outside of the bearing is stationary; the inside rotates. The outside of structure **1726** below the lower seal receives the top of bearing **1724**, and the inside of the structure is an annular ring **1730** that extends around the lower shell support.

[0299] When shell motor **1660** rotates driver **1682** through magnetic coupler **1664** and **1670**, the driver engages the vertical surface of annular ring **1730** to cause shell **1600** and its associated structure to rotate. The outside of driver **1682** may be rubber or other substance with high friction to prevent slipping between the annular ring and the driver. Other connections between the drive and the annular ring such as teeth and gears are contemplated, but applicants think the friction drive will be quieter.

[0300] Fig. 36 also shows stationary ring support **1726**. O-ring **1728** preventing vapor from flowing between the condenser and boiler sides of the shell. Set screw **1732** may attach the stationary ring support and cylindrical wall **1568** of compressor housing **1560** together.

[0301] Contaminated water inlet **1610** and wastewater outlet **1640** have been discussed. Freshwater from the shell's condenser surface **1602** and condenser wipers **1650** flows downward following the path of arrow **1734** to freshwater outlet **1736**. But the vacuum inside the processor prevents wastewater from flowing through wastewater outlet **1640** or freshwater flowing through freshwater outlet **1736** because the ends of the outlets are at atmospheric pressure. Applicants use pitot pumps **1740** and **1742** (Fig. 39) to pull the freshwater and wastewater through the outlets. The pitot pumps are similar to pumps **1712** and **1722** in Figs. 10 and 11. The pitot pumps in Fig. 39 mount to rotate about the same horizontal axis, but they can mount differently, such as rotating about vertical axes like the pumps in Figs. 10 and 11.

[0302] Pitot pumps **1740** and **1742** are similar enough so only pump **1740** is discussed. One of ordinary skill can modify pump **1742** is necessary.

[0303] The housing for pitot pump **1740** includes base **1746** and cylindrical upper housing **1748** attached to the base. See Fig. 38 Groove **1750** receives an O-ring (not shown) to seal the base and upper housing. One side **1752** of a magnetic coupler mounts for rotation with rotating shaft **1754** in recess **1756**. Bearing **1758** and **1760**, which are supported by the bearing support structure **1762**, support the shaft for rotation. One or more screws **1764** attach the bearing support structure to the cylindrical upper housing.

[0304] Pitot pump **1740** includes rotating cavity **1770** in space **1772** (Fig. 38). Washer **1774** is in the rotating cavity, and screw **1776** attaches the rotating cavity through washer **1774** to shaft **1774**. Shaft rotation causes cavity **1770** to rotate.

[0305] Rotating cavity **1770** is at the near-vacuum pressure inside housing **1502**. Water from the freshwater outlet **1736** (Fig. 31) flows into pitot tube inlet **1778** (Fig. 38). The pressure in inlet **1778** and rotating cavity **1770** is the same—near vacuum—so pressure differences do not prevent flow. Rotation of cavity **1770** causes water collected there to rotate with the cavity, and centrifugal force urges the water against the outside **1782** of the rotating cavity. Vanes **1780** aid water in the cavity to rotate at or near the velocity cavity wall's **1718** velocity.

[02100] Pitot tube **1786** has an upright section **1778** extending through plate **1768** and into rotating cavity **1770**. The upright section bends into horizontal, curved section **1788**. As Fig. 38 shows, the circular, open end **1790** of the curved section is near the cavity's inner wall **1718**. The open end may be tapered, and it should be aligned with the axis of the rotating cavity.

[0306] As cavity **1770** and the water inside the cavity rotates, the water reaches the pitot tube's open end **1770** and flows into pitot tube **1786**, which causes the pressure to increase. The water pressure can rise to atmospheric pressure (14.7 psia or  $\approx 101$  kPa) if the cavity's rotational velocity and the radii of curved section **1778** and opening **1790** are designed properly. When the water pressure is above atmospheric pressure, it can flow through the pitot tube's upright section **1786** and through opening **1792** and into a container or other collector (not shown).

[0307] Ideally, freshwater outlet **1736** (Fig. 31) is positioned to connect with inlet **1778** of freshwater pitot pump **1740**. Wastewater outlet **1640** (Fig. 31) also would be positioned to connect with the inlet for wastewater pitot pump **1742**. Tygon® or other tubing could carry freshwater and wastewater from their outlets to the respective pitot pump inlet.

[0308] Fig. 39 shows how pitot pumps **1740** and **1742** mount together on pitot pump assembly **1800**. The assembly includes left-side (Fig. 39) plate **1802** associated with freshwater pitot pump **1740** and right-side plate **1804** associated with wastewater pitot pump **1742**. Screws of other fasteners **1808**, **1810**, **1812** and **1814** attach the plates to opposite sides of center plate **1806**. Each end **1820** and **1822** can be attached to the bottom of the processor (not shown in Fig. 39).

[0309] Center plate **1806** has a center groove **1826**. Motor **1660**, which also drives rotating shell **1600** (Fig. 31), attaches to one side **1828**. First pulley **1830**, which is aligned with center groove **1826**, mounts of a shaft (not shown) that extends through the center plate. The motor rotates the first pulley. Belt **1834** around the first pulley extends to second pulley **1832** on shaft **1838** in the groove. Fig. 39 does not show the second pulley, but see Fig. 40, which shows it. The

components in Figs. 39 and 40 can be positioned so motor **1660** also can rotate disk **1682** to rotate the shell subassembly **1690**. If required, mechanisms could be provided to transfer the motor's rotation to rotate the disk and the pitot pumps.

[03010] Bearings **1840** and **1842** support shaft **1838** for rotation. See Fig. 40. The left side of the shaft connects to and rotates one side **1844** of a magnetic coupler. The other side **1752** (Figs. 38, 39 and 40) of the magnetic coupler is on the other side of wall **1846** (Fig. 40). That side rotates rotating cavity **1770** as discussed. Shaft **1838** also rotates the rotating cavity of wastewater pitot pump **1742**.

[03011] Like other embodiments, the outlets from the pitot pumps such as outlet **1792** from pitot pump **1740** may have a reed valve (not shown) like valves **330** and **331** in Fig. 5 or another type of check valve. They can prevent atmospheric pressure air from flowing back through the pitot pump and into the processor if the pitot pump has no freshwater or wastewater or if the pump is off. They may be a pressure drop through the reed or check valve—5 or 10 psia—so the pitot pump's design must account for the pressure drop. Any energy to raise the pressure 5 or 10 psia should not affect the system's efficiency and power usage significantly.

[03012] The processor may have sensors to measure the pressure and temperature at different locations. Production models may not include sensors. They may be more useful in test versions. Fig. 40 has four sensors, sensors **1850** and **1852** are used to compute the differential pressure between the boiler side and condenser side of the processor. Sensor **1854** measures the temperature of the boiler side of the shell, and sensor **1858** measure the condenser-side temperature. Sensor **1856** measures the boiler-side pressure. The sensors may connect wirelessly to a computer.

[03013] When the housing is being evacuated, internal structure may prevent or slow full evacuation. some areas may not be evacuated fully. The region between wiper support **1648** and cylindrical wall **1506** (Fig. 31) is an example. The processor may have a vaporizing equalizing passage **1880** between condenser surface **1602** of shell **1600** and the outside of wiper support **1648**. The passage allows the vacuum on both sides of the wiper support to be equal.

[03014] The processor may require regular disassembling for maintenance and cleaning. Over time, contaminants may accumulate on the shell, especially boiler surface **1604**. Wastewater passing through pitot tube **1740** and outlet **1792** also may clog with contaminants. To facilitate assembly, repair, cleaning and reassembly, components may be designed for those tasks.

[03015] Wiper support **1648** extends into the open ends of U-shaped seals **1654** and **1656** (Fig. 31). The other ends of the U-shaped seals contact top **1502** and bottom **1508** of processor

housing 1500. The top and bottom may have grooves to receive the U-shaped seals' other end. The cylindrical wall **1568** also may mount in U-shaped seals 1658 and 1659 (Fig. 32).

[03016] Unlike Fig. 1 and other embodiments that use a support extending between upper and lower housing components, the Fig. 31 embodiment uses no central shaft support between the upper and lower housing end plates to support internal components. That structure is advantageous because structures supporting internal components are self-supporting. They can be "placed" as subsystems inside outer cylindrical housing **1500**. This allows the use of thinner material for outer cylinder **1506** and the upper and lower housing plates 1049 and 1596. Tolerance variations of the housing and internal components from fabrication errors or by vacuum induced deflections of the housing avoid a mismatching of internal components. Housing deflections do not translate to tolerance variations or stress on the internal parts.

[03017] The Fig. 31 embodiment is constructed as a separate outer housing subsystem with a self-contained boiler/condenser subsystem unit inserted into the outer cylinder housing subsystem for assembly or replacement. The outer housing may be one-piece sealed at the bottom with a screw-down lid on top or similar arrangement. The boiler-condenser subsystem could contain the boiler-condenser bearings, boiler-condenser shells (single or multi-shell), boiler-condenser wipers (inner and outer for either single or multi-shells), boiler-condenser dividers (between each boiler-condenser chamber), and stationary boiler-condenser top and bottom support structure to hold the bearings, wipers, and inlet feed water tubes. This allows the boiler-condenser subsystem to be assembled externally and become a replaceable modular item for maintenance.

[03018] The bottom stationary support structure of this boiler-condenser subsystem would be fastened to the bottom of the vacuum housing **1508**. Blower subsystem **1520** also would be a separate unit with support structure that could be placed into the outer housing and clamped into place to support the blower subsystem. The fresh and waste output streams exit the bottom of the purifier under low-pressure conditions, and flow into the external pitot pump subsystems. The pitot pumps pressurize the freshwater and wastewater outputs, so they can exit to atmospheric conditions. A check valve or reed valve prevents backflow into the processor. A separate motor or a belt system drives the pitot pumps. The pitot pumps may be mounted side-by-side or co-linear.

[03019] The description is illustrative, not limiting and is for example only. Although this application shows and describes examples, those having ordinary skill in the art will find it apparent they can make changes, modifications or alterations. Many examples involve specific combinations of method acts or system elements, but those acts and those elements may be combined in

other ways to achieve the same objectives. Acts, elements and features discussed only with one embodiment are not intended to be excluded from a similar role in other embodiments.

[03020] “Plurality” means two or more. A “set” of items may include one or more of such items. The terms “comprising,” “including,” “carrying,” “having,” “containing,” “involving,” and similar words in the written description or the claims are open-ended, i.e., each means, “including but not limited to.” Only the transitional phrases “consisting of” and “consisting essentially of” are closed or semi-closed transitional phrases regarding claims. The ordinal terms like “first,” “second,” “third,” etc., in the claims don’t by themselves connote any priority, precedence, or order of one claim element over another or the temporal order in which acts of a method are performed. Instead, they merely are labels to distinguish one claim element having a certain name from another element having a same name (but for the ordinal term’s use). Alternatives like “or” include one or any combination of the listed items.