

FIELD OF INVENTION

This invention relates to inhibiting corrosion in systems of condensing hydrocarbons which contain water and chlorides. One system of particular commercial interest is the overhead of crude oil atmospheric pipestill.

BACKGROUND

Crude oil refineries include an atmospheric pressure pipestill (APS) which fractionates the whole crude oil into various product fractions of different volatility, including gasoline, fuel oil, gas oil, and others. The lower boiling fractions, including naphtha, from which gasoline is derived, are recovered from the overhead fraction. The fractions with intermediate volatility are withdrawn from the tower as sidestreams. Sidestream products include kerosine, jet fuel, diesel fuel, and gas oil. The higher up on the column the sidestream is withdrawn, the more volatile the product. The heaviest components are withdrawn in the tower bottoms stream.

Figure 1 is a simplified process flow diagram of a typical crude oil atmospheric pipestill unit. The crude is preheated in preheat exchangers against overhead product and then heated up to about 500° to 700° F in a direct-fired furnace. The feed is then flashed into the atmospheric pipestill which operates at a pressure between one and three

This Sheet Has Been Replaced




1

REPLACED SHEETS		SG
☒	Description : paged ...1... to paged ...3...	
☒	Claim(s) : paged ...34... to paged ...34...	
☐	Drawing(s) : paged to paged	
☒	Abstract : paged ...37... to paged ...7...	
DATE OF RECEIPT		

atmospheres gauge pressure. Overhead tower temperature ranges typically from 200° to 350° F. Figure 1 shows a two-stage overhead condenser system; alternative systems use one condenser stage. The overhead and sidestream products are cooled and condensed and sent to other units to be processed into final products. The bottoms stream goes to a second distillation tower (not shown) that operates under a vacuum and distills more light products out of the APS bottoms. Steam is added to the bottom of the tower to promote stripping of light products from the bottoms. Also, water is added to the top of the column to wash away soluble salts which often accumulate in the top trays and overhead components. The stripping steam and wash water coming into the system are substantial; the overhead naphtha gas stream coming off the top of the tower typically contains 20 to 40 mole % water.

The corrosion that is the subject of this invention occurs in the overhead components of the atmospheric pipestill which include the top tower trays, the piping that comes off the top of the tower and the reflux lines, the heat exchangers, the condensers and rundown lines, and the distillate drums where the condensed overhead stream is separated into liquid naphtha product and reflux. Materials commonly used in APS overhead trays and components include carbon steel, Monel 400 and 410 stainless steel. Corrosion damage can be very severe, including metal loss severe



enough to cause leakage to the external environment and internal heat exchanger leaks, plugging of trays and other internals which interfere with tower operation and control and impair energy efficiency. In addition, corrosion in the APS can cause operating problems in downstream units.

Because of the severity of the corrosion, even one day of uncontrolled corrosion can have serious consequences.

Corrosion in the overhead exchangers is the major concern.

Corrosion in the overhead system is caused by hydrogen chloride produced by hydrolysis of chloride salts found in crude oil. Crude oils contain salts dissolved in water entrained from the production well and from saltwater picked up during tanker shipment. Generally, the chloride salts are sodium chloride, magnesium chloride, and calcium chloride. Depending on the source of the saltwater, the amount of each salt in the crude can vary considerably. Sodium chloride is stable and does not hydrolyze significantly in the atmospheric crude tower system. HCL is released when $MgCl_2$ and $CaCl_2$ are hydrolyzed by water present in crude oil:



The chloride salts begin to hydrolyze at temperatures in the range of 350°F to 450°F, which occur in the preheat exchangers.

The HCl produced in the preheat system does not cause corrosion there because there is no liquid water present. The HCl, however, goes through the pipestill and passes into the overhead gas.

Temperature decreases moving up the tower and into the overhead system. At some point, temperature falls below the dewpoint temperature of the process gas and water condenses on the equipment surfaces in a thin film. This point is called the "initial condensation point" or "ICP." Water continues to condense as the process gas moves downstream and is further cooled. The overhead gas is totally condensed in the overhead condensers, is accumulated in a condensate drum, and is removed from the bottom boot of the condensate drum. Operators usually maintain the temperature at the top of the tower at least 30° to 40° F above the water dewpoint to avoid corrosion in the top trays. The trend, however, is to reduce tower top temperature to improve recovery of naphtha, and this drives the dewpoint down into the tower. Accordingly, the water dewpoint usually occurs in the overhead system, but it can occur within the distillation tower if the composition of the process streams and tower operating conditions combine to raise the dewpoint above the top tower temperature. Spot or



"shock condensation" can occur upstream of the ICP if there are cold-spots on upstream surfaces where, for example, insulation is worn and the tower shell is exposed to cold wet weather or at cold spots on heat exchanger tubes in the condensers. Accordingly, the locations where condensation initially occurs are uncertain and changeable as operating and ambient conditions change.


The ICP and shock condensation points are important because that is where chloride concentration is highest and pH lowest. Initial condensates, if untreated, exhibit pH's as low as one or even fractional pH's, and the danger of catastrophic corrosion at these points is great.

Corrosion by acidic chloride condensates is driven by the hydrogen ion concentration (pH) via the reaction:



Hydrogen sulfide, which is formed in the pipestill from organic sulfur compounds in crude oil, also dissolves in water condensate and accelerates acidic chloride corrosion. Although the source of the corrosive attack is HCl, the product of corrosion is iron sulfide, not iron chloride. Iron sulfide is precipitated by the reaction between H₂S and soluble iron chlorides from the corrosion reaction between HCl and the steel equipment, thus liberating additional HCl.





Note that the HCl is regenerated by the H₂S. Hydrochloric acid thus acts as a catalyst for formation of iron sulfide, and is not consumed.

The APS streams also contain low molecular weight carboxylic acids (acetic, propionic, butyric acids) which increase corrosion at the ICP and subsequent condensation zone.

The water coming overhead from the tower is totally condensed in the overhead exchangers and is accumulated in the condensate drum. The bulk water condensate contains chlorides, sulfides, and ammonia, and is mildly corrosive. Experience indicates that bulk water condensate should be maintained in the pH range of about 5 to 6.5 to minimize corrosion in the system. pH in the bulk condensate is controlled by adding a neutralizer, such as ammonia, to the overhead system.

In addition to being subject to severe corrosion at the ICP and points of shock condensation, APS systems are also vulnerable to severe corrosion upstream of the ICP where ammonium chloride precipitates as a solid out of the gas phase onto internal surfaces. Ammonium chloride is formed in the system by the reaction between ammonia and HCl. Ammonia comes into the pipestill in the incoming crude oil and other incoming process streams, and is often



intentionally added to neutralize HCl in the overhead bulk sour water condensate. At equilibrium, the partial pressure of ammonium chloride over the internal surface on which ammonium chloride has deposited equals the vapor pressure of ammonium chloride at the temperature of the internal surface. Figure 3 is a graph of vapor pressure of ammonium chloride versus temperature. If the partial pressure of ammonium chloride above the internal surface exceeds the vapor/equilibrium pressure, then ammonium chloride will precipitate on the surface and accumulate.

Ammonium chloride deposits are hygroscopic and, when exposed to wet process gas streams flowing by, absorb moisture, forming a wet paste with a pH of about 3.5, which is a highly corrosive environment. Ammonium chloride deposits are only a problem if they form above the water dewpoint. If they form below the dewpoint where water is condensing profusely along with the ammonium chloride, then the deposits will be washed away. But, if ammonium chloride condenses above the dewpoint and water is not condensing on these surfaces, ammonium chloride deposits will not be washed away by water and the deposits will build up.

APS corrosion problems are on the increase. The increased corrosion is attributed to several causes. Salt content of crude oils now being run in refineries have increased, generating more chlorides. Also, crudes are heavier, which makes them harder to desalt. Ammonia



concentrations in pipestills have risen because of refinery
- operating changes in other units. - Also, refiners are
running lower tower top temperatures to increase yields of
profitable distillate fuels, such as jet fuel, and also to
raise energy efficiency of the operation. Reducing top
temperature often brings the water dewpoint upstream from
the overhead equipment into the tower.

The first defense against overhead corrosion is crude
oil desalting. A desalter is shown in the flow plan of
Figure 1. In the desalter, crude is mixed with about 5%
water, which dissolves the salt. The salty water is
separated from the crude and discarded. However, oil/water
emulsions form that are difficult to break. Chemical de-
emulsifiers are added to break the emulsion. Electrical
devices which charge the water drops to enhance separation
are also used. Up to about 90% of the salt can be removed
with a single stage of water washing and separation. Salt
removal effectiveness depends on the nature of the crude.
Heavier oils are more difficult to desalt than light crudes.
A second wash stage is commonly used to remove additional
salt.

Caustic (NaOH) is commonly injected into the crude
downstream of the desalter to reduce chlorides in the
pipestill overhead system. The caustic reacts with the
magnesium and calcium chloride to form sodium chloride,
which is more thermally stable and so will not hydrolyze.



However, caustic treat must be limited since caustic causes furnace coking and induces operating problems in downstream units. New catalysts being used in downstream units in response to environmental control demands being imposed on refineries are poisoned by caustic. In most instances, it is impractical to remove enough salt with desalters and/or caustic addition to completely eliminate HCl corrosion. Moreover, operating upsets in the pretreat systems occur, which periodically introduce large doses of chlorides.

Accordingly, chloride neutralizers are added to the APS system to inhibit corrosion. The most common neutralizer is ammonia. It can be added as ammonia gas or as an aqueous solution usually into the overhead lines between the pipestill and the overhead condensers. Ammonia is effective for increasing the pH of the overhead bulk water condensate to within a safe pH range, which is about 5.5 to 6.5. But, ammonia does not neutralize condensate acidity at the ICP and shockpoint environs where corrosion is most virulent. This is because ammonia is volatile and ammonium chloride unstable in the water phase at ICP and shockpoint temperatures.

These concepts can be visualized by referring to Figure 2, which is a graph of temperature versus pH of condensate for a typical APS system. Curve I is the pH curve for an unprotected system. The pH at the initial point of condensation which, in this example, occurs at



230° F, is below 1. pH rises to about 4 moving downstream along the curve left to right to 180° F where the water is totally condensed. Obviously, this situation is unacceptable since the system internals will experience catastrophic corrosion at the low pH's indicated.

Curve II is for a system protected with ammonia. Note that ammonia protects the system well upstream of the zone of initial condensation, but provides no pH elevation at the virulent zone of initial condensation.

Curve III is the pH curve required to adequately protect the system. Note that the pH is uniformly elevated into the corrosion safe 5 to 6 pH range across the entire condensation zone.

Current commercial practice to protect APS units from corrosion is to inject organic amines into the APS overhead system. The amines used are volatile, so they appear in the gas phase upstream of the ICP where they react with some of the HCl in the gas stream before the HCl reaches the condensation zone. However, there may not be sufficient time and contact in the gas phase to neutralize all the HCl upstream of the condensation point. Accordingly, some of the HCl must be neutralized in aqueous solution after it is absorbed by the condensate water phase.

Suitable neutralization amines include morpholine, methoxypropylamine, ethylenediamine, monoethanolamine, and dimethylethanolamine. APS overhead neutralizing amines are



usually added as aqueous solutions, typically about 50% water. The most common injection points are in the overhead lines between the pipestill and the overhead exchangers, the sidestream inlets to the tower, and directly to the crude oil coming into the tower. Common practice is to control the neutralizer addition rate to maintain the pH of bulk water condensate in the separator drums to between 5.5 and 6.5, and preferably 5.5 to 6.0. If the proper amines are selected, adequate pH elevation is achieved over the entire condensation zone when the pH of the bulk condensate is maintained over 5.5.

Filming inhibitors are usually injected into the overhead system to further reduce corrosion in the upstream sections of the overhead system. They are proprietary formulations, usually oil soluble, which protect equipment by forming a barrier on the steel surface. Film inhibitors are effective in the downstream sections of the condensing zone where chloride concentrations are moderate, but are not effective at ICP and shock points.

A disadvantage of using amines to control corrosion in condensing systems containing chlorides is that the amines react with chlorides to form hydrochloride salts which deposit on internal surfaces. The salts deposit on surfaces at temperatures above the water dewpoint, upstream of the condensation zone, often in the top trays of the system tower. The salt deposits are hygroscopic and absorb




moisture from the process gas to form highly corrosive viscous fluid or paste which induce underdeposit corrosion.

Amine salts are not a problem if they deposit in the condensation zone because they are continuously washed away by condensate. Some operators mitigate the problem by periodically washing the overhead system with water to remove deposits.

Instances of salt deposition above the dewpoint in pipestills are increasing because refineries are running heavier and dirtier crudes, which generate larger amounts of chlorides and, to protect their units, operators are increasing neutralizer amine treat rates. Ammonium chloride deposition above the dewpoint is also increasing because ammonia in crude is increasing. Accordingly, there is a need in the refining industry for new technology to inhibit corrosion in wet hydrocarbon condensing systems containing chlorides which does not compound the problem by inducing troublesome salt deposits above the dewpoint. The present invention is a novel process which accomplishes this objective.

RELATED ART

Corrosion control in crude distillation units is discussed in two papers which were presented to the National Association of Corrosion Engineers: Rue, J.R. and Naeger, D.P., "Advances in Crude Unit Corrosion Control," Corrosion '87, Paper No. 199, National Association of Corrosion



Engineers, Houston, Texas; , and Rue, J.R., and Naeger, D.P.,

5 "Cold Tower Aqueous Corrosion: Causes and Control," Paper No. 211, National Association of Corrosion Engineers, Corrosion '90, Las Vegas, Nevada. The papers discuss the amine salt deposition problem, which is the focus of the present invention, but the authors advocate techniques which minimize and suppress chloride hydrolysis to solve the problem.

10 The amine salt deposition problem is addressed in U.S. Patent No. 5,211,840, which teaches that amine salt deposition can be avoided by using weak base amines, those having pKa between 5 and 8. The inventors discovered that hydrochloride salts of weak amines have less propensity to deposit on tower internals than salts of strong amines and ammonium chloride. The patent says the amines may be added to the distillation unit at any point in the overhead system prior to the location where the condensate forms.

15 Specifically, the patent teaches:

that it is necessary to add a sufficient amount of the neutralizing amine compound to neutralize the acidic corrosion causing species. It is desirable that the neutralizing amine be capable of raising the pH of the initial condensate to 4.0 or greater. The amount of neutralizing amine compound required to achieve this objective is an amount sufficient to maintain a concentration of between 0.1 and 1,000 ppm. based on the total overhead volume. The precise neutralizing amount will vary depending upon the concentration of chlorides or other corrosive species.



The patent also teaches:

blending a minor amount of highly basic amine with a low pka amine. These blends would be advantageous to use in systems where a sub-neutralizing quantity of highly basic amine can be used without causing above the water dewpoint corrosion and/or fouling problems.

The patent cites 4-picoline and 3-picoline as examples of low pka amines, and methoxypropylamine and ethanolamine as highly basic amines. The patent defines minor amounts to be less than 20% of treatment.

The amine salt deposition problem is addressed in U.S. Patent No. 4,430,196, which teaches the use of a member or members selected from the group of dimethylaminoethanol and dimethylisopropanolamine.

The amine salt deposition problem is also addressed in U.S. Patent No. 4,806,229, which teaches:

that certain amines having the following formula corresponding to Formula 1 below:



wherein n is 2 or 3 and R is a lower alkyl radical of not more than 4 carbon atoms, when added to a crude oil charge or a various other points in the system, effectively eliminates and/or controls corrosion that ordinarily occurs at the point of initial condensation of water vapors within or leaving the distilling unit. Illustrative of compounds falling within Formula 1 are methoxypropylamine, ethoxypropylamine, methoxyethylamine, and the like. The most preferred compound is methoxypropylamine.

State of the art techniques and equipment for injecting and controlling addition of neutralizing agents to the APS system and other refinery distillation towers are described



in pending U.S. Patent Application Serial No.07/867,890,
which is incorporated herein by reference. In one
embodiment of the disclosure, the pH of condensate removed
from the tower system is continuously measured with a
standard pH electrode. The pH signal is sent to a
controller, which compares it with the pH setpoint, and the
controller throttles the pumping rate of the amine pump used
to inject neutralizer into the APS system to bring the pH of
the bulk condensate reading to the setpoint. Preferably,
the condensate is bulk water condensate taken from the
overhead accumulator drum water boot, but condensate can be
removed from some intermediate condensation point in the
tower overhead system. A corrosion safe range for bulk
water condensate pH is typically 5 to 6.5.

U.S. Patent Nos. 4,335,072 and 4,599,217 describe
devices which attach to the treated system and monitor
corrosion rate and treatment. The devices are termed
"Overhead Corrosion Simulators" ("OCS"). These patents are
incorporated herein by reference. An Overhead Corrosion
Simulator is a small condenser heat exchanger cooled with
flowing cooling water which is installed onto the pipestill
overhead system such that it withdraws a small overhead gas
slipstream from the pipestill overhead. The slipstream is
withdrawn from a point sufficiently upstream where the tower
temperature is above the initial point of water condensation
so that no water condensation has yet occurred. The OCS



cools the overhead stream in small temperature increments from initial condensation through total condensation. The condensate at each stage of cooling is continuously collected and rate of corrosion and/or pH are continually monitored using conventional instrumentation techniques. Using the OCS, corrosion rates and pH, at each point in the system where water condensation is occurring, are simulated and continually monitored and conditions at the all important point of initial condensation continually observed even if the point shifts upstream or downstream in the APS overhead system.

GENERAL DESCRIPTION OF THE INVENTION

The present invention is a process for inhibiting corrosion in systems in which wet hydrocarbons containing chlorides are condensed. The process is particularly useful for protecting atmospheric pipestill units used to fractionate crude oils.

One aspect of this invention is addition of a blend of amines to the condensing system at a rate sufficient to elevate pH across the entire condensation zone, and particularly at the point of initial condensation and points of shock condensation, to prevent corrosion of system internals. A key element of the present invention is formulation of the amine blend to include a sufficient



number of different amines to avoid inducing deposition of the hydrochloride salts of any of the amines on internal surfaces located upstream of the ICP which are at temperatures above the system water dewpoint temperature.

5 In one embodiment of this present invention, the amine neutralizer blend used to protect the system is also formulated to preclude and remove formation of ammonium chloride deposits upstream of the condensing zone.

10 Another aspect of this invention is that the neutralizer amine blends are customized to the system being treated to achieve an optimum pH profile along the condensation zone at minimum amine treat rate while precluding deposition of amine hydrochloride salts and ammonium chloride.

5 Still another aspect of this invention is to use an Overhead Corrosion Simulator installed to take off a slipstream of overhead gas from the system upstream of the ICP to control the rate of addition of amine blend going into the APS.

BRIEF DESCRIPTION OF THE DRAWINGS

FIG. 1 is a simplified process flow diagram of a typical crude oil atmospheric pipestill unit;

FIG. 2 contains plots of condensing zone temperature versus pH of the condensed water at that temperature. Curve



I is typical of an untreated system. Curve II is representative of a system improperly treated with ammonia only. Curve III is for a system properly treated with amine neutralizers.

FIG 3 is a graph of the vapor pressure of ammonium chloride versus temperature.

DETAILED DESCRIPTION OF THE INVENTION

Table 1 contains a listing of commercially available amines which are suitable candidates for inclusion in the neutralizer treatment blend packages of this invention, together with the key properties that affect their performance as corrosion inhibitors. The list contains many of the amines currently used in commercial service, but it is not comprehensive and we do not intend to infer that the scope of appropriate amines is limited to those included.

Several properties and characteristics must be considered when selecting an amine for a treatment blend:

The amine must be cost effective, reasonably priced per unit weight of HCl, neutralized, and should not require elaborate or expensive handling procedures to meet environmental and safety concerns.

The amine must be thermally stable at temperatures it will encounter in the treated system. For APS systems, the amine must be stable up to at least 400° F.



The amine must be volatile enough to be in the gas phase at conditions upstream of the condensation zone, but also condense along with water in the condensing zone. Amines with boiling points in the range of 200° F to 300° F usually have the requisite volatility characteristics. Also, the amine should be more soluble in water than oil.

Ideally, the melting point or sublimation temperature of the hydrochloride salt of the amine should be low relative to the temperatures in the treated system, not adhere to metal, and be readily dispersible in hydrocarbons to minimize buildup of hydrochloride salts on internals.

The amine blend is formulated to elevate pH to corrosion-safe levels across the entire condensation zone, from the point of initial water condensation, where highest chloride concentrations and lowest pH's are observed, through to the overhead condensate drums where the overhead is totally condensed and bulk sour water is accumulated, and at all intermediate water condensation points in the system. Highest treat intensity is required at the point of initial condensation. The amine blend is custom optimized to the condensation pattern of the treated system to minimize amine treat rate. Different APS units will require different blends, depending on their operating conditions and crude being run.

Chlorides in APS systems have increased. Where chloride concentrations in APS bulk condensate were



typically in the 30 to 50 ppm range, values as high as
- 600 ppm are currently being observed. Correspondingly high
doses of amines must be administered to control corrosion.
The amine treat rate cannot simply be increased by
increasing the amine pumping rate to the treated system.
The total amount of each amine in the blend must be limited
so that the partial pressures of the hydrochloride salts of
the amines at points upstream of the initial condensation
point do not exceed partial pressure at which the salt will
deposit on system internals. The required increased treat
rate is achieved by increasing the number of amine species
in the blend. Typically, blends of at least three, and as
many as ten, amines are required for most applications.

In accordance with the present invention, the treatment
blend is formulated to limit the amount of each amine in the
blend so that the partial pressure of the hydrochloride salt
of each amine formed in the system by reaction with HCL does
not exceed the partial pressure at which it will deposit
from the gas phase upstream of the point of initial water
condensation.

Another aspect of this current invention is that the
amine neutralizer blend is formulated to contain sufficient
amines with basicity greater than ammonia ($K_b > 1.8 \times 10^{-5}$)
to react with enough of the chlorides to bring the
vapor pressure of ammonium chloride below the level where it
can precipitate on internal surfaces upstream of the



condensation zone. Amines that are more basic than ammonia have a higher affinity for chlorine than ammonia, so they form the amine hydrochloride in preference to ammonium chloride. Ammonium chloride deposits are undesirable because they are corrosion sites and induce pluggage operating problems.

The amines selected have condensing and volatility characteristics close to water and are soluble in water so that they condense with and dissolve in the condensate and therefore are available to neutralize HCl absorbed by the condensate. Depending on its temperature versus its vapor/oil/water solubility partition characteristics, an amine will be very effective in one sector of the condensation zone and less effective in another. The pH versus temperature curve of Figure 2 for a system can be moved and shaped by changing the amine formulation. Ideally, the amine mixture can be optimally custom blended to achieve the desired pH elevation to corrosion protect the system at a minimum amine treat rate.


The amine blend is custom matched to the condensation pattern by selecting at least one amine for the blend which is effective and efficient in each sector of the condensation zone. Minimizing amine treat rate by optimizing the amine blend formulation reduces the cost of the treatment, eliminates operating problems due to high amine concentrations in downstream units, and mitigates



deposition of amine hydrochloride salt deposition.

Determining an appropriate amine blend formulation is part science and part art. Experimental confirmation that the amine blend candidate works is required.


Also, there is still much of what goes on in the system that is not fully understood. For example, we have observed that the hydrochloride salts of some of the amines used in amine neutralizer blend formulations have water of hydration attached to them. Depending on conditions in the tower, the number of waters of hydration associated with an amine salt may vary. The volatility of amine hydrochloride salts varies with the number of waters of hydration. Since the water of hydration associated with an amine at system operating conditions is generally not known, the limiting partial pressure to avoid salt deposition is also uncertain. Moreover, there may be interactions between amine components that affect salt deposition, particularly if dibasic amines such as ethylene diamine are used. Accordingly, candidate amine blends must be tested in a pilot distillation unit which simulates the tower system to be treated. Likely as not, the candidate formulation will have to be revised and tested several times to determine the best formula. Moreover, if subsequently the system operating conditions or the crude oil composition change, it is likely that the amine blend formula must be changed to maintain optimal corrosion control.



Developing a candidate amine blend begins with obtaining and analyzing those overhead system operating parameters which control the treatment. Operating pressure, condensing temperature, overhead gas rate, composition, and concentration of chlorides, water, ammonia and non-condensable gases in the overhead, are all required data. These parameters can be obtained by direct measurement or from simple material balances around the overhead system by conventional procedures. Most of the chlorine and ammonia formed in the system appear in the condensed water phase collected in the overhead condensate collection drums. Accordingly, chloride rate can be calculated by simple material balance, knowing the condensate rate and its chloride and ammonia concentration. Non-condensable gases are discharged usually from a vent line off the top of the condensate accumulator drums and are directly measured.

The water condensation rate and pH/chloride/corrosion rate vs temperature profiles in the tower must be obtained. These data can most conveniently be obtained using an Overhead Corrosion Simulator installed on the tower to remove and cool a slipstream from the tower to be protected, taken at a convenient point upstream of where water condensation begins.

The minimum theoretical or stoichiometric rate of amine addition is the number of mole equivalents of amine per minute required to stoichiometrically neutralize the HCl



5 flowing through the tower. The actual amine addition rate
to be used is 1.05 to 1.20 x the stoichiometric rate, the
excess added to insure complete neutralization. The base
equivalents of amine required are distributed among a number
of suitable amines such that none of the amine hydrochloride
salts formed exhibit a partial pressure high enough for the
salt to deposit on system internals upstream of the
condensation zone. For purposes of this calculation, to be
conservative it is assumed that all the amines form their
hydrochloride salts quantitatively. Moreover, to provide a
further margin of safety, it is good practice to blend the
amines so that there will be no salt deposition even if
temperatures in the overhead fall 50° F below actual
operating temperatures. The ideal gas law can be used to
make the required calculations.

10 In addition, the amine blend is formulated so that
sufficient amounts of amines with basicity (K_b 's) greater
than ammonia are fed to the treated system to preclude
deposition of ammonium chloride upstream of the point of
initial water condensation. The molar ratio feed rate of
high K_b amines to ammonia should be at least 1.1.

15 Both the amine salt and ammonium chloride deposition
computations have an inherent degree of uncertainty.
Accordingly, it is good practice to test the candidate amine
blend formulation in a lab unit which simulates the treated
system to confirm that the candidate amine blend adequately



elevates the pH vs temperature curve to corrosion-safe levels across the condensation range, that the amine blend is optimally efficient for the system being treated, and that no deposits of amine salt or ammonia form upstream of the condensation zone.

The lab unit used to simulate APS systems is a small continuous distillation tower with 20 trays, a reboiler, an overhead condenser, and a condensate collection vessel. The unit simulates the upper trays and overhead system of the treated system. The lab unit is operated at one atmosphere total pressure, whereas the APS operates at several atmospheres. However, the partial pressures of the components in the overhead system, naphtha, HCl, amines, nitrogen (to simulate non-condensable gases), and ammonia, are all maintained at the same ratios as in the APS so the simulation is valid. A naphtha is selected which matches the composition of the naphtha in the overhead stream in the treated system. For most APS units, full range naphtha is an appropriate test feed to match the gas in the overhead. Feed rates of HCl, water, ammonia, and nitrogen (to simulate non-condensable gases) to the lab unit are fixed to duplicate the partial pressures of these components in the APS system. The lab unit is made of a transparent material such as glass or plexiglas so that salt deposition in the tower can be visually observed.



A corrosion probe and thermocouple which can be moved through the unit is provided to obtain the corrosion vs temperature curve upstream of the dewpoint. A pH probe is used to measure pH of the condensate below the dewpoint.

The candidate neutralizer amine blend is injected into the lab column at a convenient point upstream of the condensation zone, typically about five trays from the top of the column.

A typical run lasts several hours, during which the pH/corrosion rate vs tower temperature profile is continually monitored across the observed water condensation zone in the tower. The amine feed rate is increased to bring the pH at the point of initial condensation in the corrosion-safe 5.0 to 6.0 pH range. The unit is checked visually for deposition of ammonium chloride and/or amine hydrochloride salts.

In APS units, the conventional method of controlling the rate of injection of amine blend into the APS is to throttle the feed rate to maintain the pH of the bulk condensate which accumulates in the water boot of the overhead condensate drum within a corrosion-safe range, typically 5 to 6. The amine pumping rate can be controlled manually or by closed-loop automation.

An alternate and preferred method of controlling the rate of addition of the neutralizer amine blend involves use of an Overhead Corrosion Simulator. Control can be



accomplished manually by an operator who periodically looks at the OCS pH and/or corrosion rate profile and increases or decreases amine blend flow rate by adjusting the setpoint on the amine feed pump rate controller to maintain a corrosion-safe pH profile. The operator will pay particular attention to the point of initial water condensation where the pH is lowest and corrosion risk highest. The system can sound an alarm if pH falls or corrosion rate rises at any point if the OCS falls out of control specification. Alternatively, the control can be automated with commercially available instruments. A scanner peak picker instrument can be provided which periodically scans the pH profile in the OCS and picks out the lowest pH. The low pH signal is sent to the amine feed rate controller on the feed pump, which compares it with the setpoint. The controller adjusts amine pump feed rate to maintain the point of lowest pH at the setpoint.

The amine blend can be injected into the overhead system or into any convenient downstream point below the decomposition temperature of the amines. Preferably, the amine blend should be added as far upstream as possible away from the condensation zone to allow maximum time for the vapor phase reaction between the amines and HCL to occur. A suitable addition point for an APS unit is to the kerosine stripper return line. The amine neutralizer blend is



usually administered as an aqueous solution, typically about
-50% water.

EXAMPLE 1

Ammonium chloride deposition was induced in lab
distillation unit simulating APS overhead.

Stream components	Mol %	Rate
Naphtha (IBP-321 F; EP-352 F)	66.26	70 ml/min
Water	33.70	3.62 ml/min
Non-condensibles	0.004	5.35 cc/min
Ammonium hydroxide	0.0012	0.028 g/min
HCl	0.0012	0.025 g/min

Salt deposition in the top five trays started
immediately after initiation of flow of ammonium hydroxide
and HCl. Fouling quickly worked its way into the overhead
condensers. The run had to be terminated after 75 minutes
because the top trays were severely fouled and the column
was flooding. Corrosion rates in excess of 400 mpy were
recorded at locations above the water dewpoint temperature.
Corrosion rates above 5 mpy are excessive.

EXAMPLE 2

The same as Example 1 except that the following amines
were added five trays from the top of the column:

Amine	Rate, moles/min
MOPA	0.031



MEA

0.021

No solid salt deposition was observed either in the column or overhead condenser. The run was terminated after 4 hours, but could have gone on indefinitely. However, corrosion rates in excess of 400 mpy were again recorded above the water dewpoint temperature.

EXAMPLE 3

Same as Example 1, but only for 15 minutes, to form coating of ammonium chloride on the top column trays and in the condenser. Then the customized multi-amine blend was introduced. Not only did fouling stop, but the salt deposits in the top trays and the overhead condenser vanished over a period of about one hour. Most significantly, corrosion rate above the water dewpoint dropped to only two mpy after the salt deposits vanished.

EXAMPLE 4

This example shows one calculation procedure indicating how an amine blend for corrosion treating an APS can be formulated using the present invention:

APS stream Component	Moles per Hour
Naphtha to overhead	5124
Water overhead	361
Chlorides overhead	0.023



Ammonia overhead	0.020
Non-condensable gases overhead	2.8
Total overhead stream	5,488.69
Operating Conditions	
Total pressure	2311 mm Hg
Tower top temperature	370 F
Water dewpoint temperature	230° F
Total condensation temperature	110 F

The initial estimate of equivalents of amines required to control corrosion is 10% more than the theoretical amount required to neutralize the chlorides, 1.1×0.023 chloride moles per hour rate = 0.025 moles per hour of amines.

The candidate amine blend will include MOPA, MEA and morpholine. Calculate maximum moles per hour of each amine that can be fed to the system so that partial pressure of each hydrochloride salt does not exceed its dewpoint/sublimation pressure at 210°F, which is a 20°F safety margin below the water dewpoint temperature. (The ideal gas law is applicable for these calculations.) The maximum amine rate is the total overhead flow rate 5488.69 moles per hour x vapor pressure of the amine hydrochloride at 210°F in mm Hg divided by total system pressure, 2311 mm Hg.



Amine Salt	VP at 210 F	Max. amine rate	Act. Amine rate
MOPA-HCl	0.008 mm Hg	0.019 Moles/hr	0.012 Moles/hr
MEA-HCl	0.008	0.019	0.012
Morph-HCl	0.002	0.005	0.002
Total		0.043 Moles/hr	0.026

This computation indicates that if the required 0.025 moles per hour amine feed rate were satisfied with a blend of 0.012 moles/hr of MOPA, 0.012 moles per hour of MEA and 0.002 moles per hour of morpholine, there would be no deposits of the hydrochloride salt of an amine at temperatures above the water dewpoint -- assuming that no anomalous effects due to association of waters of hydration with amine salts or salt interactions occurred which effect the vapor pressure of the salts. Within the constraints of maintaining the total amine flow rate at the rate required to neutralize the chlorides and not exceeding the precipitation partial pressures of the amine salts, the ratios of the amine components can be varied; and this is often done to optimize and shape the pH profile across the condensation zone.

MOPA and MEA have K_b 's higher than ammonia and, since for this case the total amine 0.024 moles per hour feed rate exceeds the molar rate of chlorides coming overhead in the system, there is no risk that ammonium chloride will deposit above the water dewpoint. In the general situation, it would be assumed that amines with K_b 's higher than ammonia



would react quantitatively with chloride and the remaining chloride would form ammonium chloride with the residual chloride. Then the partial pressure of ammonium chloride would be computed and, using Figure 3, it would be verified that ammonium chloride would not precipitate at temperatures above the water dewpoint.

The candidate blend of MOPA, MEA and morpholine is tested in a lab APS simulation test. The pH profile across the water condensation zone is observed. The amine blend feed rate is increased until the pH profile is entirely in the corrosion safe range, above pH 5.0. The amine feed rate is compared with the theoretical stoichiometric rate required to neutralize the chlorides to determine that the excess amine ratio required is reasonable. The lab column is checked visually to verify that no amine salt deposits form. Also, corrosion probe is checked to insure that the corrosion rate is below 5 mpy. Finally, the ratio of amines in the blend is varied without exceeding the maximum amine limit of any component to determine the optimum amine blend ratio for the three component mixture which provides the required pH curve elevation at minimum total amine feed rate.

If amine salt deposits are observed upstream of the water dewpoint line using the MOPA, MEA, morpholine candidate blend, even if calculations made using vapor pressures of the hydrochloride salts indicate no deposition



should occur, then it is probable that one or more of the amine hydrochlorides has less water of hydration associated with it at conditions in the system, and the less hydrated salt has significantly lower vapor pressure than the more unhydrated salt. The candidate amine mixture is reformulated with additional amine components and the new mixture tested in the APS simulation lab unit. This process is repeated until a satisfactory amine blend for the APS system to be treated is developed.



TABLE I
AMINES FOR CORROSION CONTROL

AMINE	$K_b \times 10^5$	Boiling Pt, °F	NEUTRALIZATION EFFICIENCY (EQUIV. WT.)	SOLUBILITY RATIO WATER/OIL	MELT PT. OF HCl SALT, °F
AMMONIA	1.8	—	17	>98%	644 (sublimes)
MOPA	13	243	89	>98%	206
MEA	32	338	60	>98%	170
EDA	51.5/0.037	242	30	>98%	530 (sublimes)
nPA	51	118	59	>98%	320
MORPHOLINE	0.21	262	89	>98%	350
DMA	54	45	45	>98%	333
DMEA	1.6	282	89	>98%	135
DEAE	5.2	322	117	>98%	270
DAMP	93/0.832	327	51	>98%	176

This Sheet Has Been Replaced





4

We claim:

1. A process for inhibiting corrosion in condensing systems comprising hydrocarbons, water and chlorides, said process comprising feeding a blend of amines to the said condensing system at a rate which maintains the pH of the water condensate at all points in the condensing zone of said condensing system above the pH at which significant corrosion of the construction materials of the said condensing zone occurs, said blend of amines formulated using a sufficient number of different amines so that no hydrochloride salt of any of the amines in said amine blend can deposit as a liquid or a solid on any internal surfaces of the said condensing system which is above the water dewpoint temperature of said condensing system.

2. A process for inhibiting corrosion in condensing systems comprising hydrocarbons, water and chlorides, said process comprising feeding a blend of amines to the said condensing system at a rate which maintains the said water condensate pH at all points in the condensing zone of said condensing system above the pH at which significant corrosion of the construction materials of the said condensing zone occurs, said blend of amines formulated from a sufficient number of different amines so that for each amine the partial pressure of its hydrochloride salt does





11 not exceed the vapor-liquid/equilibrium pressure for that
12 salt at the water dewpoint of the said condensing system.

1 3. The process of claim 1, in which the said amine
2 blend contains one or more amines with K_b higher than
3 ammonia and the feed of said amine blend to said condensing
4 system contains sufficient amines with K_b higher than
5 ammonia to prevent formation of deposits of solid ammonium
6 chloride on said internal surfaces in said condensing system
7 which are above the said water dewpoint of the said
8 condensing system.

1 4. The process of claim 1, in which one or more of
2 the said amines in said amine blend has K_b higher than
3 ammonia, and enough moles of said amines with K_b above
4 ammonia are fed to said condensing system to reduce the
5 partial pressure of ammonium chloride in said condensing
6 system so that ammonium chloride can not condense on
7 surfaces in the said condensing system which are at
8 temperatures above the said water dewpoint temperature of
9 the system.

5. The process of claim 1, in which the said blend of
amines is custom formulated to the said condensing system so
that the pH profile throughout the condensing zone of said
condensing system is above the pH at which significant





5 corrosion of the construction materials of the said
6 -condensing system occurs and the amine feed rate is minimum.

1 6. The process of claim 1, in which the said feed
2 rate of said blend of amines is controlled using an Overhead
3 Corrosion Simulator to monitor the pH versus temperature
4 profile in the said condensing zone of said condensing
5 system.

1 7. The process of claim 1, in which the said
2 condensing system is an atmospheric pipestill used to
3 distill crude oil into product fractions.

1 8. The process of claim 1, in which the said amine
2 blend is determined by testing a candidate blend of amines
3 in a lab unit which simulates the said condensing system,
4 increasing said amine feed rate to elevate the pH profile in
5 the water condensing zone above the said corrosion safe pH,
6 observing if said hydrochloride salt deposits of one or more
7 components form above the water dewpoint temperature, and,
8 if said deposits do form, increasing the number of
9 components in said amine blend while reducing the feed rate
10 of each component until the said safe pH elevation is
11 achieved without said amine salt deposition above the said
12 water dewpoint.

